Appendix B- Technical evaluation

The minimum weighted final score (threshold) required for a tender to be considered from a technical perspective is **80%.**

Evaluation Criteria				
No.	**Factor**	**Weight**	**Sub Factor**	**Score**
	Company background and suitability to provide the work:			
1	Proof of registered installer	10%	Yes	10%
2	Provide Method statement clearly indicating how the installation of the UPS and batteries work will be executed	20%	Yes	20%
			No	0
3	The contractor to provide proof of previous experience in installation of UPS and batteries. Reference letters, or previous orders/contracts	20%	0 to 1 year	5%
			1 to 2 years	15%
			> 3 years	30%
4	The contractor to supply all trade test qualification for the Electrician who will perform the installation	20%	Yes	20%
			No	0
5	Provide proof that the UPS comply to the following specifications: Safety: (CB certified) IEC 62040-1; CB certified EMC: EC 62040-2 Performance: IEC 62040-3 RoHS: EU directive 2011/65/EU	20%	Five (5) certificates submitted	20%
	WEEE: EU directive 2012/19/EU			
6	Supplier to confirm on the company letter head that they will be able to supply and install UPS and batteries at all three laboratories.	10%	Yes	10%
			No	0%
	Total	**100%**		
	Threshold	**80%**		