Eskom	Invitation to Tender Enquiry No: E3791GXMPMAT

ESKOM HOLDINGS SOC LTD

ADDENDUM: INVITATION TO TENDER

FOR

SO3 PLANT MAINTENANCE AND SPARES SUPPLY AT MATLA POWER STATION FOR A PERIOD OF FIVE (5) YEARS, ON AN AS-AND-WHEN-REQUIRED BASIS DURING PLANNED OUTAGES, OPPORTUNITY OUTAGES, INTERIM REPAIRS AND ROUTINE MAINTENANCE.

ADDENDUM FOR THE FOLLOWING:

TENDER NUMBER: E3791GXMPMAT

- **Revised Tender Closing Date**

Closing Date	Revised Closing date
27 November 2026 at 10H00	07 December 2026 at 10H00

QUERIES AND RESPONSES FOR CLARITY BELOW

No.	Queries	Responses
1.	Ceramic balls, item 23 on the supplied scope of work Bill of Material (BOM)	The correct dimension for the diameter of the balls is 1 inch; there is a typo on the specification indicated on the scope of work. Corrected on the attached scope of work on page 60 of 66 and on the Invitation to tender - Scope of work (page 89),Bill of quantities (page 105)
2.	The tender technical evaluation criteria for this contract stipulate under section 3.3 as a mandatory technical evaluation criterion that the Principal Contractor must have an ISO 3834 accreditation provided or issued by SANAS/SABS accredited entity/body.	This is indicated as a minimum requirement for service providers eligibility to perform maintenance on the SO3 plants at Eskom according to the Work Instruction for the Evaluation and Assessment of Service Providers unique identifier 240-101716464. This criterion as indicated on the tender technical evaluation criteria for this tender does not make provisions for the Joint Vendor option for consideration. Therefore, only service providers with ISO 3834 accreditation will be considered for the tender.

Kind Regards,



Signature
Lebogang Letsholo
Acting Manager Procurement – Matla Power Station
Date: 18/11/2026