



REQUEST FOR QUOTATION (RFQ)

DATE ISSUED	07 February 2022
PROJECT NAME	Generator voltage regulator
CLOSING DATE AND TIME	10 February 2021 Any time before 11:00
DELIVERY TIME	
NAME OF PROPOSER/TENDERER	
TELEPHONE NUMBER	
CSD SUPPLIER NUMBER (MA NUMBER)	
FAX NUMBER	
EMAIL ADDRESS	
PHYSICAL ADDRESS	
COMPANY REGISTRATION NUMBER	
VAT REGISTRATION NUMBER	
QUOTE PRICE (INCL VAT)	
SIGNATURE	
ENQUIRY: NAME: TEL: E-MAIL:	Thato Mathose 012 334 5000 tmathose@sansa.org.za
SPECIFICATION OF THE PRODUCT/SERVICE REQUIRED	Generator AVR Please supply voltage regulator for 400V 3 phase 60 HZ generator with the following specs: Input voltage 170 to 250 VAC high 105 – 125 VAC low Output voltage (F+ F-) 76-110VAC high 45-55 vac low Output current 5 amp Field resistance 10-100 ohms high

	Temp, range	5- 100 ohms low -40 to 40 oC
	Frequency range	25 – 70 Hz
	Residual volts	4 V AC at AVR

Email quotation with the RFQ document to: tmathose@sansa.org.za