

	<h2>Clarification Response</h2>	<p>Doc Ref: PSEV-16 Version Date: Sept 2019 Revision: 1 Page 1 of 1</p>
---	---------------------------------	--

TENDER CLARIFICATION

REQUEST FOR QUOTATION MOOKODI EXTENSION & 1ST 500MVA TRANSFORMER STRINGING & CABLING

Clarification 05	Request For Proposal No. E2621NTCSAMWP,
------------------	---

The following clarification is needed in response to queries and questions raised by Tenderers.

Clarification Request in **BLACK** and Clarification Response in **RED**

Items	Clarification / Discussion
01	The proforma given addressed the patch panels but not the Boxes and Leads
01	See attached proforma and we need patch leads for these
02	<ul style="list-style-type: none"> •Items 64-65 Protection Panels on the BOQ have no reference such as drawings and the Design report is not sufficient
02	<p>Submit it to Siemens we have contract with them for:</p> <ul style="list-style-type: none"> -400kV Transfer buscoupler -400kV Buscoupler without transfer -400kV Bus section -400/132/22kV Transformer scheme -132kV Buscoupler without transfer -132kV Bus section scheme
03	there are any drawings to support the Miscellaneous BOQ tems 75-85.
03	We have contract with Sivtec, for protection above. See attached drawings
04	<p>Could you please provide us with more details regarding the existing SCADA system and the overall project requirements?</p> <p>Typically, the minimum required information would include the following:</p> <ul style="list-style-type: none"> • Detailed SCADA system specifications • Estimated tag count and system size • List of field devices, OEM systems, and network infrastructure • Network architecture and communication protocols • Site drawings or SLDs (if available) • Backup of the existing SCADA system, if possible
04	Please refer to attached patch boxes the SCADA equipment will be procured by NTCSA