

PART 4: AFFECTED PROPERTY

Core clause 11.2(2) states.

"Affected Property is property which

- Is affected by the work of the *Contractor* or used by the *Contractor* in Providing the Service
- is in the documents which the Contract Data states it is in."

In Contract Data, reference has been made to this Part 4 of the contract for the location of the Affected Property.

1. Description of the Affected Property and its surroundings.

1.1. General description.

Name of depot	Quantity	Diameter of the tank	Height of the tank	Capacity of the tank	Length of the tank
Coligny (North West Province)	2	7.74 m	9.60 m	46 5570 L	-
Klerksdorp (North West Province)	1	2.34 m	-	30 000 L	5.500 m
Rustenburg (North West Province)	2	2.40 m	-	23 000 L	7.3 m
Germiston (Gauteng Province)	3	7.64 m	9.80 m	449 500 L	-
Kaserne (Gauteng Province)	2	2.02 m	-	28 364 L	9.880 m
Sentrarand (Gauteng Province)	2	3.05m	16.4m	119 760 L	-
Koedoespoot (Gauteng Province)	1	7.64 m	4.93 m	225 890 L	-
Millsite (Gauteng Province)	2	10.02 m	11.02 m	930 000 L	-
Springs (Gauteng Province)	2	2.00 m	-	36 890 L	11.75 m
Kroonstad (Free State Province)	2	4.92 m	11.93 m	191 169 L	-
Sasolburg (Free State Province)	1	2.89 m	16.4 m	107 500 L	-
Bethlehem (Free State Province)	3	2.89 m	16.4 m	107 500 L	-
Bloemfontein (Free State Province)	2	26.29 ft	33.0 ft	17 657.33 ft3	-

Thabazimbi (Limpopo Province)	1	2.95 m	-	80 000 L	12.80 m
Tzaneen (Limpopo Province)	2	2.89 m	16.45 m	107 900 L	-
Phalaborwa (Limpopo Province)	1	2.95 m	-	57 790 L	8.46 m
Polokwane (Limpopo Province)	1	7.52 m	9.50 m	500 000 L	-
Beaconsfield (Northern Cape Province)	1	9.47 ft	42.64 ft	2 885.63 ft3	-
De-Aar (Northern Cape Province)	3	7.00 m	8.00 m	300 000 L	-
Klawer (Northern Cape Province)	2	19.74f t	34.44 ft	9711.53 ft3	-
Upington (Northern Cape Province)	2	25.03 ft	25.0 ft	12 177 ft3	-
Ground-Zero-Sishen (Northern Cape Province)	2	Self-bunded tanks.		68 000 L	-
Bellville (Western Cape Province)	2	5.00 m	10.0 m	475 000 L	-
Saldanha (Western Cape Province)	6	9.47 ft	41 ft	2 839 ft3	-
Voorbaai (Western Cape Province)	2	8.00 m	12.00 m	303 000 L	-
Worcester (Western Cape Province)	2	5.00 m	11.00 m	300 000 L	-
Cambridge (Eastern Cape Province)	2	7.50 m	5.40 m	252 000 L	-
Swartkops (Eastern Cape Province)	2	8.00 m	12.00 m	465 000 L	-
Danskraal (Kwa-Zulu Natal Province)	2			23 000 L	

Masons-Mill (Kwa-Zulu Natal Province)	2	7.52 m	11.93 m	529 600 L	-
Newcastle (Kwa-Zulu Natal Province)	2	6.02 m	8.90 m	253 200 L	-
Richards-Bay-iNsezi (Kwa-Zulu Natal Province)	2	10.02 m	11.93 m	940 250 L	-
Vryheid (Kwa-Zulu Natal Province)	2	2.89 m	16.40 m	107 500 L	-
Wentworth (Kwa-Zulu Natal Province)	2	10.02 m	11.94 m	941 000 L	-
Ermelo (Mpumalanga Province)	2	10.02 m	11.94 m	941 000 L	-
Komatipoort (Mpumalanga Province)	1	2.89 m	16.40 m	108 000 L	-
Lydenburg (Mpumalanga Province)	2	7.70 m	10.30 m	250 000 L	-
Ogies (Mpumalanga Province)	1	2.40 m	2.90 m	64 500 L	12.00 m
Waternval-Boven (Mpumalanga Province)	1	No dimensions available because this is an underground tank.		68 000 L	-
Witbank (Mpumalanga Province)	1	2.50 m	-	55 000 L	8.57 m
Nelspruit (Mpumalanga Province)	2	7.50 m	9.50 m	420 000 L	-

1.2. Existing buildings, structures, and plant & machinery on the Affected Property.

APPENDIX

1. THERMAL RELIEF SYSTEM

