

TENDER CLARIFICATION

Integrated Physical Security System and maintenance support for thirteen (13) substations within Transmission Division

Clarification 05	Request For Proposal No. MWP2421TX
-------------------------	---

The following clarification is needed in response to queries and questions raised by Tenderers.

1	What frequency is the access card? 13.56MHz
2	How many cards will you require? Provision and costing should be made for 200 cards per site, but the intension is for the supplier to programme the existing Eskom cards (MIFARE.DESFire EV1) on their system. •
3	In the pricing schedule the supply of equipment is separate from the installation. Is it correct for us to assume that the equipment will be supplied and invoiced separate to the installation? This is correct, where supply is a stand-alone item, it will be paid separate and Installation the same.
4	Normally when trenching is required at Eskom sites, there is normally a requirement for scanning to be done along the area that trenching will need to be done and then a Civils Working Permit has to be issued before we can break ground. I believe this is normally done ERI from Eskom that will do these scans and issues the certificate so would we as the bidders need to cost for this in our solution or is the assumption that whomever the bid gets awarded to, ERI will do the work for each Eskom site at Eskom's cost? Any scanning that might be required will have to be costed by the bidders and will be done by the appointed Contractor.