


FOUNDATION			
DESCRIPTION	USE FOR	DRAWING NO.	REV NO.
CIVIL STANDARDS	SECTIONAL VIEWS	D-EC-1977	13
FENCE	PALISADE FENCE	D-EC-2113 SI-S2	-
	PALISADE FENCE LABEL BRACKET	D-EC-1949	1
BMI & BM2	BENCH MARK	D-EC-1977	13
TRENCH COVER	750mm TRENCH COVER	D-DT-5254-1A	0
	TRENCH KERBING	D-EC-1977	13
	ROAD KERBING	D-EC-1977	13
	STONE KERBING	D-EC-1977	13
KERBING	750mm TRENCH COVER SUPPORT	D-DT-5254-6A	0
GLG2, G3 & G4	GATE RAMPS	D-EC-1950	2
INTERNAL FENCE	INTERNAL FENCE	0.54/394-398	-

- NOTES:**
- ALL WORK TO BE DONE IN ACCORDANCE WITH S.A.N.S. 1200 LATEST REVISION.
  - ALL LEVELS TO BE SET-OUT FROM BENCH INDICATED AS  $\odot$ .
  - H.V. YARD TO HAVE A CLEAN, HARD, SOUND CRUSHED STONE OF A MIN. 26/38mm NOMINAL SIZE, 100mm THICK LAYER. THIS SHOULD APPLY AFTER INSTALLATION OF ALL EQUIPMENT AND CABLES.
  - ALL PANELS TO BE TAKEN AS STANDARD PANELS UNLESS OTHERWISE STATED.
  - FOR PAVING REFER TO PROJECT SPECIFICATION 1.3.25. THE PAVING AROUND THE CONTROL BUILDING IS TO HAVE A FALL OF 1:200.
  - THE PALES TO BE USED IS TO BE THE "CLASSIC PALISADE" D SECTION (SEE D-DT-2113 SHT 1) WITH COUNTERSUNK BOLT AND SHEAR NUT.
  - ALL CABLE TRENCHES ARE 750mm WIDE UNLESS STATED OTHERWISE.
  - THE OUTLET DRAINAGE PIPE MUST BE TO INVERT LEVEL.

LEGEND	
SYMBOL	DESCRIPTION
$\otimes$	FENCE CORNER POST
$\boxtimes$	FENCE 5m GATE HINGE POST
$\times$	FENCE POST INTERMEDIATE
$\boxtimes$	FENCE 1m GATE HINGE POST
$\ast$	FENCE GATE SUPPORT POST
*	CABLE TRENCH BRACE D-DT-5254-6A REV 0

SHEET 10	TRFR 3 PLINTH LAYOUT
SHEET 09	TRFR 1 & 2 PLINTH LAYOUT
SHEET 08B	SECTIONS & CLAMPS
SHEET 08A	SECTIONS & CLAMPS
SHEET 07	GENERAL ARRANGEMENT
SHEET 06	STEELWORK LAYOUT
SHEET 05	FOUNDATION LAYOUT
SHEET 04	EARTH MAT LAYOUT
SHEET 03	LEVEL & DRAINAGE
SHEET 02	SITE PLAN
SHEET 01B	STATION ELECTRIC DIAGRAM
SHEET 01A	STATION ELECTRIC DIAGRAM
DRG NO.	REFERENCE DRAWINGS:

3	DRAWING UPDATED	BMI	MG	RR	04/04/2017	
2	REFURBISHMENT OF ON 66kV & 66kV BUS-COUPLER ADDED	BK	MG	ST		
1	REDRAWN TO THE NEW STANDARD & 11kV FEEDER ADDED	ST	MG	NMW	23/05/2002	
0	FIRST ISSUE, 11kV YARD CHANGED SUPERCEDES DRAWING 5,17/4115	CL	MG	NMW	16/08/1999	
REV	REVISION DESCRIPTION	BY	CHKD	AUTH	DATE	PROJECT NO.



**Eskom Distribution**

**GOODHOPE TEXTILE**

66/11kV  
TRENCH AND FENCE

D-EC-1541

SET	SHEET	REVISION
11	11	3

AUTH: N.WEBBER  
 DATE: 16/08/1999  
 CHKD: M.GALLANT  
 DATE: 16/08/1999  
 DRAWN: C.LOTTERING  
 DATE: 05/07/1999