

GENERAL RELAYS TECHNICAL EVALUATION CRITERIA

Schedule A and B

| Material Number 0125245 | | |
|--|---|-------------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B (Do not Tick or Cross, actual text on Schedule B column) | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Part number | 4PST (XTRM10A31A) | |
| Relay Type | Control | |
| Current range | 10A | |
| Voltage rating | 600VAC | |
| Number of poles | 3 | |
| Contact Arrangement | 3NO,1NC | |
| Coli Voltage | 110-120VAC | |
| Enclosure Rating | Bakelite | |
| Terminal Captive | Instantaneous with clip-on mounting plate | |

CONTROLLED DISCLOSURE

When downloaded from the EDMS, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

| Material Number 0125275 | | |
|---|--------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B (Do not Tick or Cross, actual text on Schedule B column) | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Part number | 3VU1300-1MK00 | |
| Relay Type | Overload | |
| Current range | 4-6 A | |
| Contact Arrangement | 8NO,1NC | |
| Reset Type | Manual | |
| Enclosure Rating | Plastic | |
| Terminal Captive | Screw Clamp | |
| Mount | Panel | |

| Material Number 0125483 | | |
|---|--------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B (Do not Tick or Cross, actual text on Schedule B column) | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Part number | CT1-10 | |
| Relay Type | Overload | |
| Current range | 2.2 - 3.6A | |
| Contact Arrangement | 1NO,1NC | |
| Reset Type | Manual | |
| Terminal | Captive Clamp | |
| Mount | Rear Mount | |

| Material Number 0125547 | | |
|--|--------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Product brand name | Siemens | |
| Part number | 3UA5500-2B | |
| Relay Type | Overload | |
| Current range | 12.5-20 A | |
| Voltage rating | 380VAC | |
| Number of poles | 3 | |
| Contact Arrangement | 1NO,1NC | |

CONTROLLED DISCLOSURE

When downloaded from the EDMS, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

| | | |
|-------------------------|--------|--|
| Reset Type | Manual | |
| Enclosure Rating | Open | |
| Short circuit | | |
| Terminal Captive | Mount, | |

| Material Number 0125549 | | |
|---|---------------------------------|-------------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Product brand name | Siemens | |
| Part number | 3UA5000-1J | |
| Relay Type | Overload | |
| Current range | 6.3 -10 A | |
| Voltage rating | 380VAC | |
| Contact Arrangement | 1NO 1NC | |
| Reset Type | Automatic/Manual | |
| Enclosure Rating | Bakelite | |
| Terminal | Screw captive | |
| Mount | Panel | |

| Material Number 0125551 | | |
|---|---------------------------------|-------------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Product brand name | Siemens | |
| Part number | 3UA5000-1D | |
| Relay Type | Overload | |
| Current range | 2 – 3.2 A | |
| Voltage rating | 380VAC | |
| Contact Arrangement | 1NO,1NC | |
| Reset Type | Automatic/Manual | |
| Enclosure Rating | Bakelite | |
| Terminal | Captive Screw | |
| Mount | Panel | |
| Operating and Maintenance Manual | Yes | |

CONTROLLED DISCLOSURE

When downloaded from the EDMS, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

| Material Number 0125552 | | |
|--|--------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Product brand name | Siemens | |
| Part number | 3UA5000-1E | |
| Relay Type | Overload | |
| Current range | 2.5 – 4 A | |
| Voltage rating | 380VAC | |
| Contact Arrangement | 1NO,1NC | |
| Reset Type | Automatic/Manual | |
| Enclosure Rating | Bakelite | |
| Terminal Capacitive | Captive Screw | |
| Mount | Panel | |

| Material Number 0125553 | | |
|--|--------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Product brand name | Siemens | |
| Part number | 3UA5000-1H | |
| Relay Type | Overload | |
| Current range | 5-8 A | |
| Voltage rating | 380VAC | |
| Contact Arrangement | 1NO,1NC | |
| Reset Type | Automatic/Manual | |
| Enclosure Rating | Bakelite | |
| Terminal Capacitive | Captive Screw | |
| Mount | Panel | |

CONTROLLED DISCLOSURE

When downloaded from the EDMS, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

| Material Number 0125560 | | |
|--|--------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Name | RH Relay ABB | |
| Product Reference | HGS86243-0-220 | |
| Model number | RH1713 | |
| Relay Type | Interposing | |
| Coil Voltage | 22.5VDC | |
| Contact Rating | 6A | |
| Contact Arrangement | 3NO,3NC | |
| Action | 3PDT | |
| Enclosure Rating | IP50 | |
| Terminal | Captive Clamp | |
| Mount | Panel | |

| Material Number 0125563 | | |
|--|--------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Product Name | Siemens | |
| Part number | 3UA5000-1A | |
| Relay Type | Overload | |
| Contact Rating | 1-1.6A | |
| Contact Arrangement | 1NO,1NC | |
| Number of Poles | 3 | |
| Reset Type | Automatic/Manual | |
| Enclosure Rating | Bakelite | |
| Terminal | Captive Screw | |
| Mount | Panel | |

CONTROLLED DISCLOSURE

When downloaded from the EDMS, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

| Material Number 0125565 | | |
|--|--------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Supplier Part Number | 3KM5030-1AG01 | |
| Part number | 3RB2066-1MC2 | |
| Relay Type | Overload | |
| Trip Range | 200-320A | |
| Current | 320A | |
| Contact Arrangement | 1NO,1NC | |
| Reset Type | Automatic/Manual | |
| Enclosure Rating | Bakelite | |
| Terminal | Captive Screw | |
| Mount | Panel | |

| Material Number 0125566 | | |
|--|--------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Product Name | Siemens | |
| Part number | 3UA5000-0J | |
| Relay Type | Overload | |
| Trip Range | 0.63-1A | |
| Contact Arrangement | 1NO,1NC | |
| Reset Type | Automatic/Manual | |
| Enclosure Rating | Bakelite | |
| Terminal | Captive Screw | |
| Mount | Panel | |

CONTROLLED DISCLOSURE

When downloaded from the EDMS, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

| Material Number 0125567 | | |
|--|--------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Product Name | Siemens | |
| Part number | 3UA6200-3J | |
| Relay Type | Overload | |
| Trip Range | 110A-135A | |
| Current | 100A– 135A | |
| Contact Arrangement | 1NO,1NC | |
| Poles | 3 | |
| Reset Type | Manual | |
| Enclosure Rating | IP67 | |
| Terminal | Captive Clamp | |
| Mount | Direct | |

| Material Number 0125568 | | |
|--|--------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Product Name | Siemens | |
| Part number | 3UA5800-2D | |
| Relay Type | Overload | |
| Trip Range | 20-32A | |
| Voltage | 380VAC | |
| Contact Arrangement | 1NO,1NC | |
| Number of Poles | 3 | |
| Reset Type | Automatic/Manual | |
| Enclosure Rating | Bakelite | |
| Terminal | Captive Screw | |
| Mount | Panel | |

CONTROLLED DISCLOSURE

When downloaded from the EDMS, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

| Material Number 0125570 | | |
|--|--------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Part number | 3UA6000-2X or 3AU600-2W | |
| Relay Type | Overload | |
| Trip Range | 80-110A | |
| Current | 110A | |
| Contact Arrangement | 1NO,1NC | |
| Reset Type | Automatic/Manual | |
| Enclosure Rating | Bakelite | |
| Terminal | Captive Clamp | |
| Mount | Rear | |

| Material Number 0125571 | | |
|--|--------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Product Name | Siemens | |
| Part number | 3UA5800-2FA7 | |
| Relay Type | Overload | |
| Trip Range | 32-50A | |
| Contact Arrangement | 1NO,1NC | |
| Reset Type | Automatic/Manual | |
| Enclosure Rating | Bakelite | |
| Terminal | Capacitive Screw | |
| Mount | Panel | |

CONTROLLED DISCLOSURE

When downloaded from the EDMS, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

| Material Number 0125789 | | |
|--|--------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Reference Number | CET3-01 or CED3 | |
| Relay Type | Overload | |
| Trip Range | 80-180.8A | |
| Complete For | 36-48VDC | |
| DC Converter | 240/48VDC | |
| Reset Type | Automatic | |
| Mount | Panel | |
| Terminal | Bolt | |

| Material Number 0125794 | | |
|--|---|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Part Number | 36A50000-1KA7 or 3UA5000-1J | |
| Specification | IEC 947 | |
| Relay Type | Overload | |
| Trip Range | 6.3-10A | |
| Current | 10A | |
| Contact Arrangement | 1NO,1NC | |
| Pole | 3 | |
| Reset Type | Manual | |
| Mount | FOR DIRECT MOUNTING ON CONTACTORS 3TB42 AND 3TB43 | |
| Terminal | Captive Clamp | |

CONTROLLED DISCLOSURE

When downloaded from the EDMS, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

| Material Number 0125822 | | |
|--|--------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Part Number | 3UA5200-2A | |
| Relay Type | Overload | |
| Trip Range | 10-16A | |
| Contact Arrangement | 1NO,1NC | |
| Reset Type | Manual | |
| Enclosure Rating | Bakelite | |
| Mount | Panel | |
| Terminal | Capacitive Screw | |

| Material Number 0125847 | | |
|--|--------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Part number | MK2P-1 | |
| Relay Type | Auxiliary Overcurrent | |
| Contact Rating | 250 VAC 7A; 28VDC 10A | |
| Coil Voltage | 24VDC | |
| Contact Arrangement | 2NO, 2NC | |
| Enclosure Rating | Plastic Clear | |
| Terminal | 8 Pin plug in | |
| Mount | Octal Socket | |

| Material Number 0125885 | | |
|--|--------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Part Number | 3UA6000-2H | |
| Relay Type | Overload | |
| Trip Range | 55-80A | |
| Contact Arrangement | 1NO,1NC | |
| Pole | 3 | |
| Reset Type | Automatic/Manual | |
| Enclosure Rating | Bakelite | |
| Mount | Panel | |

CONTROLLED DISCLOSURE

When downloaded from the EDMS, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

| | | |
|----------|---------------|--|
| Terminal | Captive Screw | |
|----------|---------------|--|

| Material Number 0125922 | | |
|--|--------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Brand Name | Schneider | |
| Part Number | CA2-DN240FA65 | |
| Contact Rating | 660 VAC 6 A | |
| Relay Type | Control | |
| Contact Arrangement | 4NO | |
| Coil Voltage | 110 VDC | |
| Terminal | Captive Clamp | |
| Mount | Bracket | |
| Enclosure Rating | Bakelite | |

| Material Number 0125958 | | |
|--|--------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Reference Number | 2-54AFLCRVH22 | |
| Trip Range | 2.5 - 4 A | |
| Relay Type | Overload | |
| Reset | Manual | |
| Contact Arrangement | 1NO 1NC | |
| Current | 4 A | |
| Terminal | Captive Clamp | |
| Mount | Rear | |

CONTROLLED DISCLOSURE

When downloaded from the EDMS, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

| Material Number 0125965 | | |
|--|--------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Reference Number | Siemens | |
| Part Number | 3UA5500-1J | |
| Trip Range | 0.63 -1 A | |
| Relay Type | Overload | |
| Reset | Automatic/Manual | |
| Contact Arrangement | 1NO 1NC | |
| Current | 1 A | |
| Pole | 3 | |
| Terminal | 10 Screw Clamp | |
| Mount | Panel | |
| Enclosure Rating | Open | |

| Material Number 0125997 | | |
|--|--------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Part number | 3RB2056-1FC2 | |
| Relay Type | Overload | |
| Trip Range | 80-110A or 50-200A | |
| Pole | 3 | |
| Contact Arrangement | 1NO,1NC | |
| Reset Type | Manual | |
| Aux at AC-15 | 3A | |
| Mounting Type | Direct mounting | |

CONTROLLED DISCLOSURE

When downloaded from the EDMS, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

| Material Number 0125998 | | |
|--|--------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Part number | 3UA6000-2W | |
| Relay Type | Overload | |
| Trip Range | 63-90A | |
| Current | 90A | |
| Pole | 3 | |
| Contact Arrangement | 1NO,1NC | |
| Reset Type | Automatic/Manual | |
| Enclosure Rating | Bakelite | |
| Terminal | Capacitive Screw | |
| Mount | Panel | |

| Material Number 0126142 | | |
|--|--------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Part number | 3UA6600-3B | |
| Relay Type | Overload | |
| Trip Range | 125-200A | |
| Contact Arrangement | 1NO,1NC | |
| Reset Type | Automatic/Manual | |
| Enclosure Rating | Bakelite | |
| Terminal | Captive Screw | |
| Mount | Panel | |

| Material Number 0126432 | | |
|--|--------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Part number | | |
| Relay Type | Auxiliary Overcurrent | |
| Coil Voltage | 250 VDC | |
| Contact Arrangement | 4NO | |
| Enclosure Rating | Bakelite | |
| Terminal | 12 Captive Screw | |

CONTROLLED DISCLOSURE

When downloaded from the EDMS, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

| | | |
|-------|------------------------|--|
| Mount | Flush Panel Horizontal | |
|-------|------------------------|--|

| Material Number 0126505 | | |
|--|--------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Part number | CAD32MD | |
| Reference | LX4D09 | |
| Relay Type | Control | |
| Contact Rating | 10A | |
| Coil Voltage | 220 VDC | |
| Contact Arrangement | 3NO 2NC | |
| Poles | 5 | |
| Terminal | 10 Captive Screw | |
| Mount | Clip Rail | |

| Material Number 0126563 | | |
|--|--------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Part Number | SM125-220 | |
| Relay Type | Voltage Level | |
| Contact Arrangement | 1NO 1NC | |
| Contact Rating | 250 VAC 10 A; 24 VDC 5 A | |
| Coil Voltage | 220 VAC | |
| Terminal | 11 Pin Plug In | |
| Mount | Panel | |
| Enclosure Rating | Metal | |

CONTROLLED DISCLOSURE

When downloaded from the EDMS, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

| Material Number 0126654 | | |
|--|--------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Part Number | ST-101 | |
| Relay Type | Time Delay | |
| Operation | ON/OFF 0 S - 240 Min | |
| Contact Arrangement | 2NO 2NC | |
| Contact Rating | 5A | |
| Coil Voltage | 10-30 VAC/DC | |
| Terminal | Pin Plug In | |
| Mount | Octal Socket | |

| Material Number 0126660 | | |
|--|--------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Reference | RL100004-02A | |
| Relay Type | Auxiliary Overcurrent | |
| Poles | 2 | |
| Terminal | 6 Pin Solder | |
| Mount | PCB | |

| Material Number 0126661 | | |
|--|--------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Reference | RL100004-03 | |
| Relay Type | Auxiliary Overcurrent | |
| Item Number | 36 | |
| Terminal | 8 Pin Solder | |
| Mount | PCB | |

CONTROLLED DISCLOSURE

When downloaded from the EDMS, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

| Material Number 0126668 | | |
|--|--------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Reference | CACTTET | |
| Relay Type | Time Delay | |
| Operation | ON/OFF 2 – 30S | |
| Contact Arrangements | 4NO 4NC | |
| Coil Voltage | 48VDC | |
| Enclosure Rating | Plastic Clear | |
| Terminal | 14 Pin plug in | |
| Mount | Terminal Socket | |

| Material Number 0126670 | | |
|--|--------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Model | OKSGC CD | |
| Relay Type | Auxiliary Overcurrent | |
| Contact Arrangements | 4NO | |
| Coil Voltage | 48 VDC | |
| Enclosure Rating | Plastic Clear | |
| Terminal | 12 Pin plug in | |
| Mount | Terminal Socket | |

| Material Number 0126671 | | |
|--|--------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Reference | BA | |
| Model | DG | |
| Relay Type | Auxiliary Overcurrent | |
| Contact Arrangements | 4NO 4NC | |
| Coil Voltage | 22 VDC | |
| Enclosure Rating | Plastic Clear | |
| Terminal | 14 Pin plug in | |
| Mount | Terminal Socket | |

CONTROLLED DISCLOSURE

When downloaded from the EDMS, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

| Material Number 0126673 | | |
|--|--------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Model | CG | |
| Part Number | BA | |
| Relay Type | Auxiliary Overcurrent | |
| Contact Arrangements | 4NO 4NC | |
| Coil Voltage | 24 VDC | |
| Enclosure Rating | Plastic Clear | |
| Terminal | 1/4 Pin plug in | |
| Mount | Terminal Socket | |

| Material Number 0126805 | | |
|--|--------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Reference Number | EB4-220VDC | |
| Relay Type | Latch | |
| Contact Arrangements | 4NO 4NC | |
| Coil Voltage | 220 VDC | |
| Enclosure Rating | Plastic Clear | |
| Terminal | 16 Pin plug in | |
| Mount | Terminal Socket | |

| Material Number 0126818 | | |
|--|--------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Reference Number | CT1-150 | |
| Part Number | CT1-150 | |
| Relay Type | Overload | |
| Trip Range | 100 – 150A | |
| Contact Arrangements | 1NO 1NC | |
| Reset | Automatic/Manual | |

CONTROLLED DISCLOSURE

When downloaded from the EDMS, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

| | | |
|-------------------------|---------------|--|
| Coil Voltage | 220 VDC | |
| Enclosure Rating | Bakelite | |
| Terminal | Captive Screw | |
| Mount | Panel | |

| Material Number 0126819 | | |
|--|--------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Part Number | CTA3-42 | |
| Reference Number | CTA3-42-32-42 | |
| Relay Type | Overload | |
| Trip Range | 25 - 43A | |
| Contact Arrangement | 1NO,1NC | |
| Pole | 3 | |
| Reset Type | Manual | |
| Enclosure Rating | Open | |
| Terminal | Captive Clamp | |
| Mount | Panel | |

| Material Number 0126906 | | |
|--|--------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Reference Number | 0864K25 | |
| Part Number | MK2P | |
| Relay Type | Control | |
| Contact Rating | 250 VAC 10A | |
| Contact Arrangements | 2NO 2NC | |
| Coil Voltage | 110 VDC | |
| Enclosure Rating | Plastic Clear | |
| Terminal | 8 Pin Plug In | |
| Mount | Socket | |

CONTROLLED DISCLOSURE

When downloaded from the EDMS, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

| Material Number 0126972 | | |
|--|---------------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Part Number | 3TH80 | |
| Relay Type | Control | |
| Contact Rating | 220/380/530/660VAC 10/6/4/2A | |
| Contact Arrangements | 2NO 2NC | |
| Coil Voltage | 220 VDC | |
| Enclosure Rating | Bakelite | |
| Terminal | Captive Screw | |
| Mount | Panel | |

| Material Number 0126985 | | |
|--|--------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Part Number | ETR5-1 | |
| Relay Type | Time Delay | |
| Operation | ON/OFF 0.5 -1 S | |
| Contact Arrangement | 1NO 1NC | |
| Contact Rating | 240VAC 2A | |
| Coil Voltage | 110 VAC | |
| Terminal | Captive Screw | |
| Mount | Bracket | |
| Enclosure Rating | IP67 | |

CONTROLLED DISCLOSURE

When downloaded from the EDMS, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

| Material Number 0126994 | | |
|--|--|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Part Number | LRD3353 | |
| Relay Type | Overload | |
| Trip Current | 23-32A | |
| Contact Arrangement | 1NO,1NC | |
| Motor Fuse Rating | 40A at 380V 15KW At 500V 18.5KW 600V | |
| Max Fuse Capacity | 110A | |
| Reset Type | Manual | |
| Enclosure Rating | Bakelite | |
| Terminal | Capacitive Screw | |
| Mount | Panel | |
| Dimensions | 60mm LG 90mm HT WD 44mm | |

| Material Number 0127022 | | |
|--|-----------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Product brand name | Schneider | |
| Part number | LRD3359 | |
| Relay Type | Overload | |
| Current range | 48 - 65 A | |
| Voltage rating | 660VAC | |
| Current | 65A | |
| Contact Arrangement | 1NO,1NC | |
| Pole | 3 | |
| Reset Type | Manual | |
| Enclosure Rating | Bakelite | |
| Terminal Capacitive | Screw Captive | |
| Mount | Panel | |
| Dimensions | WD 64 X HT 115 X LG 73MM | |

CONTROLLED DISCLOSURE

When downloaded from the EDMS, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

| Material Number 0127025 | | |
|--|--------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Reference Number | 7PA1143-6EA | |
| Part Number | C72303-A9-B102 | |
| Relay Type | Auxiliary Overcurrent | |
| Contact Rating | 380 VAC; 440VDC 10A | |
| Contact Arrangements | 8NO 2NC | |
| Coil Voltage | 220 VAC | |
| Enclosure Rating | Plastic Clear | |
| Terminal | 20 Pin Plug In | |
| Mount | Terminal Socket | |

| Material Number 0127026 | | |
|--|--------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Part Number | 7PS2111-4 | |
| Relay Type | Time Delay | |
| Operation | ON/OFF 0.1 - 0.6 S | |
| Contact Arrangement | 2NO 2NC | |
| Contact Rating | 220VAC 1A | |
| Coil Voltage | 220VDC | |
| Terminal | 12 Pin Plug In | |
| Mount | Terminal Socket | |
| Enclosure Rating | Plastic Clear | |

CONTROLLED DISCLOSURE

When downloaded from the EDMS, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

| Material Number 0127027 | | |
|--|--------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Part Number | 7PS2161-4 | |
| Relay Type | Time Delay | |
| Operation | ON/OFF 3 - 48 S | |
| Contact Arrangement | 2NO 2NC | |
| Contact Rating | 220VAC 1A | |
| Coil Voltage | 220VDC | |
| Terminal | 12 Pin Plug In | |
| Mount | Terminal Socket | |
| Enclosure Rating | Plastic Clear | |

| Material Number 0127028 | | |
|--|--------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Product brand name | Unknown | |
| Part number | 3UA5000-1C | |
| Relay Type | Overload | |
| Current range | 1.6-2.5 A | |
| Contact Arrangement | 1NO,1NC | |
| Reset Type | Automatic/Manual | |
| Enclosure Rating | Bakelite | |
| Terminal Capacitive | Screw Captive | |
| Mount | Panel | |
| Dimensions | WD 64 X HT 115 X LG 73MM | |

CONTROLLED DISCLOSURE

When downloaded from the EDMS, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

| Material Number 0127029 | | |
|--|--------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Reference Number | 3AU5000-1G | |
| Relay Type | Overload | |
| Trip Current Range | 4 - 6.3 A | |
| Contact Arrangement | 1NO 1NC | |
| Coil Voltage | 220VAC | |
| Motor Driven | Automatic/Manual | |
| Terminal | Screw Captive | |
| Mount | Panel | |
| Enclosure Rating | Bakelite | |

| Material Number 0127030 | | |
|--|--------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Part number | 3UA5900-1C | |
| Relay Type | Overload | |
| Current range | 1.6 - 2.5 A | |
| Contact Arrangement | 1NO,1NC | |
| Pole | 3 | |
| Reset Type | Automatic/Manual | |
| Enclosure Rating | Bakelite | |
| Terminal Capacitive | Screw Captive | |
| Mount | Panel | |

| Material Number 0127033 | | |
|--|--------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Part Number | 7PR1040-7AM00 | |
| Part Number | 3RP1574-1NP30 | |
| Relay Type | Time Delay | |
| Operation | ON 0.5 - 20 S | |

CONTROLLED DISCLOSURE

When downloaded from the EDMS, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

| | | |
|----------------------------|--------------------|--|
| Contact Rating | 220VAC 2A | |
| Contact Arrangement | 1NO 1NC | |
| Coil Voltage | 220VAC | |
| Motor Driven | 50Hz Instantaneous | |
| Terminal | Screw Captive | |
| Mount | Bracket | |

| Material Number 0127034 | | |
|---|---------------------------------|-------------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Part Number | OA0600OANN | |
| Relay Type | Connector | |
| Contact Rating | 6A | |
| Contact Arrangements | 2NC | |
| Coil Voltage | 24 VDC | |
| Enclosure Rating | Plastic Clear | |
| Terminal | 6 Pin plug in | |
| Mount | Terminal Socket | |

| Material Number 0127035 | | |
|---|---------------------------------|-------------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Part Number | 2825403 | |
| Relay Type | Phoenix | |
| Contact Rating | 5A | |
| Contact Arrangements | 2NO 2NC | |
| Coil Voltage | 24 VDC | |
| Enclosure Rating | Plastic Clear | |
| Terminal | 8 Pin plug in | |
| Mount | Terminal Socket | |

CONTROLLED DISCLOSURE

When downloaded from the EDMS, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

| Material Number 0127036 | | |
|--|--------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Part Number | OA0600OCOANN | |
| Relay Type | Phoenix | |
| Contact Rating | 5A | |
| Contact Arrangements | 3NO | |
| Coil Voltage | 24 VDC | |
| Enclosure Rating | Plastic Clear | |
| Terminal | 8 Pin Plug In | |
| Mount | Terminal Socket | |

| Material Number 0127041 | | |
|--|--------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Reference Number | KFA6-SR2-EX1.W | |
| Relay Type | Proximity | |
| Contact Rating | 250/500VAC 4A | |
| Contact Arrangements | 2NO 2NC | |
| Coil Voltage | 220 VDC | |
| Change Over | 500VA | |
| Enclosure Rating | IP20 | |
| Terminal | Captive Screw | |
| Mount | Panel | |

| Material Number 0127045 | | |
|--|--------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Reference Number | LX4-D2UD | |
| Relay Type | Control | |
| Contact Rating | 600VAC 10A | |
| Contact Arrangements | 2NO 2NC | |
| Coil Voltage | 24 VDC | |

CONTROLLED DISCLOSURE

When downloaded from the EDMS, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

| | | |
|-------------------------|---------------|--|
| Enclosure Rating | IP67 | |
| Terminal | Captive Screw | |
| Mount | Bracket | |

| Material Number 0127047 | | |
|---|---------------------------------|-------------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Reference Number | MK3P5-I LIST 1919W | |
| Reference Number | PF113A-E | |
| Relay Type | Auxiliary Overcurrent | |
| Contact Rating | 250VAC 10A | |
| Contact Arrangements | 3NO 3NC | |
| Coil Voltage | 24 VDC | |
| Enclosure Rating | Plastic Clear | |
| Terminal | 11 Pin plug in | |
| Mount | Octal Socket | |

| Material Number 0127048 | | |
|---|---------------------------------|-------------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Reference Number | 60-13 | |
| Relay Type | Control Contact | |
| Contact Rating | 250VAC 10A | |
| Contact Arrangements | 3NO 3NC | |
| Coil Voltage | 110VAC | |
| Enclosure Rating | Plastic Clear | |
| Terminal | 11 Pin plug in | |
| Mount | Octal Socket | |

CONTROLLED DISCLOSURE

When downloaded from the EDMS, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

| Material Number 0127359 | | |
|--|--------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Reference Number | 3UA4200-7AM | |
| Relay Type | Overload | |
| Current range | 30 - 45 A | |
| Contact Arrangement | 1NO 1NC | |
| Reset Type | Manual | |
| Enclosure Rating | Bakelite | |
| Terminal Capacitive | Captive Screw | |
| Mount | Panel | |

| Material Number 0127571 | | |
|--|--------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Reference Number | EMT5 | |
| Part Number | OA0600OCOANN | |
| Relay Type | Control | |
| Contact Rating | 660V 2A | |
| Contact Arrangements | 4NO 4NC | |
| Coil Voltage | 220VAC | |
| Reset | Automatic | |
| Enclosure Rating | Bakelite | |
| Terminal | Captive Screw | |
| Mount | Panel | |

| Material Number 0127572 | | |
|--|--------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Reference Number | DIL08-22 | |
| Relay Type | Auxiliary Overcurrent | |
| Contact Rating | 80VAC 10A | |
| Contact Arrangements | 2NO 2NC | |

CONTROLLED DISCLOSURE

When downloaded from the EDMS, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

| | | |
|-------------------------|---------------|--|
| Coil Voltage | 220VAC | |
| Enclosure Rating | IP67 | |
| Terminal | Captive Screw | |
| Mount | Bracket | |

| Material Number 0127909 | | |
|---|---------------------------------|-------------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Part Number | CA3-30 | |
| Reference Number | CT3-16 | |
| Relay Type | Overload | |
| Current range | 12 -16A | |
| Contact Arrangement | 1NO 1NC | |
| Pole | 3 | |
| Reset Type | Automatic/Manual | |
| Enclosure Rating | Bakelite | |
| Terminal Capacitive | Captive Screw | |
| Mount | Panel | |

| Material Number 0127926 | | |
|---|---------------------------------|-------------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Reference Number | MK3P5-I | |
| Relay Type | Miniature, General Purpose | |
| Contact Rating | 250VAC 10A | |
| Contact Arrangements | 3NO 3NC | |
| Coil Voltage | 24 VDC | |
| Enclosure Rating | Plastic Clear | |
| Terminal | 11 Pin plug in | |
| Mount | Octal Socket | |

CONTROLLED DISCLOSURE

When downloaded from the EDMS, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

| Material Number 0128054 | | |
|--|--------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Part Number | BA | |
| Model | CH | |
| Relay Type | Auxiliary Overcurrent | |
| Contact Rating | 10A | |
| Contact Arrangements | 4NO 4NC | |
| Coil Voltage | 48 VDC | |
| Enclosure Rating | Plastic Clear | |
| Terminal | 14 Pin plug in | |
| Mount | Bracket | |

| Material Number 0128127 | | |
|--|--------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Part Number | C70301-A532-C103 | |
| Relay Type | Auxiliary Overcurrent | |
| Contact Arrangements | 6NO | |
| Enclosure Rating | Plastic Clear | |
| Terminal | 14 Pin plug in | |
| Mount | Terminal Socket | |

| Material Number 0128614 | | |
|--|--------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Reference Number | VE0017 | |
| Relay Type | Variable percentage | |
| Contact Rating | 220/380VAC | |
| Coil Voltage | 380VAC | |
| Contact Arrangements | 1NO 1NC | |
| Enclosure Rating | Plastic blue | |
| Terminal | 11 Pin plug in | |
| Mount | Octal Socket | |

CONTROLLED DISCLOSURE

When downloaded from the EDMS, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

| Material Number 0128619 | | |
|--|--------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Reference Number | SM170-380 | |
| Relay Type | 3 Phase Sequence Voltage | |
| Contact Rating | 220/380VAC | |
| Coil Voltage | 380VAC | |
| Contact Arrangements | 1NO 1NC | |
| Enclosure Rating | Plastic | |
| Terminal | 11 Pin plug in | |
| Mount | Octal Socket | |

| Material Number 0128622 | | |
|--|--------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Reference Number | ST101 | |
| Relay Type | Time Delay | |
| Operation | ON/OFF 1 S – 240 Min | |
| Contact Rating | 220 VAC 3A | |
| Coil Voltage | 250 VAC | |
| Contact Arrangements | 2NO 2NC | |
| Terminal | 11 Pin plug in | |
| Mount | Octal Socket | |

| Material Number 0128624 | | |
|--|--------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Reference Number | | |
| Relay Type | Overload | |
| Trip Range | 0.4 – 0.63 A | |
| Current | 2A | |
| Poles | 3 | |

CONTROLLED DISCLOSURE

When downloaded from the EDMS, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

| | | |
|-----------------------------|---------------|--|
| Contact Arrangements | 1NO 1NC | |
| Reset | Manual | |
| Enclosure Rating | IP67 | |
| Terminal | Captive Clamp | |
| Mount | Panel | |

| Material Number 0128626 | | |
|---|---------------------------------|-------------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Part Number | LR1-D12316A65 LRD16 | |
| Relay Type | Overload | |
| Trip Range | 9 – 13 A | |
| Current | 13A | |
| Poles | 3 | |
| Contact Arrangements | 1NO 1NC | |
| Reset | Manual | |
| Terminal | Captive Clamp | |
| Mount | Rear | |

| Material Number 0128632 | | |
|---|-----------------------------------|-------------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Brand Name | SLIMLIN | |
| Reference Number | ST202 | |
| Series | 07-92 | |
| Relay Type | Time Delay | |
| Operation | ON 0 - 240Min OFF 0 - 12.5 Hrs | |
| Contact Arrangement | 2NO 2NC | |
| Coil Voltage | 90/250VAC | |
| Terminal | 11 Pin Plug In | |
| Mount | Octal Socket | |

CONTROLLED DISCLOSURE

When downloaded from the EDMS, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

| Material Number 0128633 | | |
|--|--------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Part Number | ST100DPDT | |
| Relay Type | Time Delay | |
| Operation | 1.8 -120 S; 1 -4 HR | |
| Coil Voltage | 90 – 250 VAC | |
| Terminal | 11 Pin | |

| Material Number 0128636 | | |
|--|--------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Part Number | RHN411M | |
| Part Number | 20510 | |
| Relay Type | Auxiliary Overcurrent | |
| Contact Rating | 250VAC 5A | |
| Contact Arrangements | 4NO 4NC | |
| Coil Voltage | 220 VAC | |
| Specification | IEC 255 | |
| Enclosure Rating | Plastic | |
| Terminal | 16 Pin Plug in | |
| Mount | Terminal Socket | |

| Material Number 0128639 | | |
|--|--------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Reference Number | CA2-DN1319MA65 | |
| Relay Type | Control | |
| Contact Rating | 500VAC 10A | |
| Coil Voltage | 220VAC | |
| Contact Arrangements | 3NO 3NC | |
| Enclosure Rating | Panel | |
| Terminal | Captive Clamp | |
| Mount | Panel | |

CONTROLLED DISCLOSURE

When downloaded from the EDMS, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

| Material Number 0128648 | | |
|--|--------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Reference Number | DVR/-W | |
| Relay Type | Thermistor | |
| Contact Rating | 110 - 380V 5A | |
| Coil Voltage | 110VAC | |
| Contact Arrangements | 1NO 1NC | |
| Enclosure Rating | Plastic | |
| Terminal | Captive Screw | |
| Mount | Panel | |

| Material Number 0130674 | | |
|--|--------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Reference Number | LR1-D63-361-A65 | |
| Relay Type | Overload | |
| Current range | 57 - 66A | |
| Current | 66A | |
| Contact Arrangement | 1NO 1NC | |
| Pole | 3 | |
| Reset Type | Manual | |
| Enclosure Rating | Open | |
| Terminal Capacitive | Captive Clamp | |
| Mount | Rear | |

| Material Number 0130688 | | |
|--|--------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Part Number | CT3-12 | |
| Relay Type | Overload | |
| Current range | 1.6 - 2.5A | |
| Current | 2.5A | |

CONTROLLED DISCLOSURE

When downloaded from the EDMS, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

| | | |
|----------------------------|---------------|--|
| Contact Arrangement | 1NC | |
| Pole | 3 | |
| Reset Type | Manual | |
| Terminal Capacitive | Captive Clamp | |
| Mount | Panel | |

| Material Number 0138058 | | |
|---|---------------------------------|-------------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Part Number | SSR B229 | |
| Reference Number | C79363A3000B229 | |
| Relay Type | Solid State | |
| Contact Rating | 35 A | |
| Coil Voltage | 3 – 32 VDC | |
| Potential | 220 VAC | |
| Contact Arrangements | 1NO | |
| Enclosure Rating | Plastic | |
| Terminal | Captive Screw | |
| Mount | Flush | |

| Material Number 0139508 | | |
|---|---------------------------------|-------------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Part Number | LR9F5367 | |
| Reference Number | RA1-GA75105 | |
| Relay Type | Overload | |
| Trip Range | 75 - 105A | |
| Contact Arrangement | 1NC | |
| Pole | 3 | |
| Reset Type | Manual | |
| Enclosure Rating | IP67 | |
| Terminal | Bolt | |
| Mount | Bracket | |

CONTROLLED DISCLOSURE

When downloaded from the EDMS, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

| Material Number 0139509 | | |
|--|--------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Part Number | LRD340 | |
| Reference Number | LR1-D40355A65 | |
| Relay Type | Overload | |
| Current range | 30 - 40A | |
| Current | 100A | |
| Contact Arrangement | 1NO 1NC | |
| Pole | 3 | |
| Reset Type | Manual | |
| Enclosure Rating | IP67 | |
| Terminal | Captive Clamp | |
| Mount | Panel | |

| Material Number 0151302 | | |
|--|--------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Part Number | HC3CA8H | |
| Reference Number | C79363A3000B229 | |
| Relay Type | Time Delay | |
| Operation | ON/OFF 99.9 S -9990 HR | |
| Contact Rating | 250 VAC 3 A | |
| Coil Voltage | 100 – 120 VAC | |
| Contact Arrangements | 2NO 2NC | |
| Enclosure Rating | IP67 | |
| Terminal | 8 Pin Plug | |
| Mount | Octal Socket | |

CONTROLLED DISCLOSURE

When downloaded from the EDMS, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

| Material Number 0151303 | | |
|--|--------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Part Number | 0DR-U 110V | |
| Relay Type | Time Delay | |
| Operation | ON/OFF 0 – 10 HR | |
| Contact Rating | 250 VAC 10 A | |
| Coil Voltage | 110 VAC | |
| Contact Arrangements | 1NO 1NC | |
| Enclosure Rating | Plastic | |
| Terminal | 8 Pin Plug | |
| Mount | Octal Socket | |

| Material Number 0151316 | | |
|--|--------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Part Number | AT77866 | |
| Reference Number | MHP-NM-24HR-AC220V | |
| Catalogue Number | 77866-1 | |
| Relay Type | Time Delay | |
| Operation | ON 0 - 24HR | |
| Contact Arrangement | 2NO 2NC | |
| Contact Rating | 250VAC 5A | |
| Coil Voltage | 100 - 240VAC | |
| Terminal | 8 Pin | |
| Mount | Plug In | |

CONTROLLED DISCLOSURE

When downloaded from the EDMS, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

| Material Number 0151317 | | |
|--|--------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Part Number | 3RP1574-1NP30 | |
| Specification | VDE0660 | |
| Reference Number | ETR5-10R | |
| Relay Type | Time Delay | |
| Operation | OFF 2 - 20 S | |
| Contact Arrangement | 1NO 1NC | |
| Contact Rating | 220VAC 3A 220VDC 0.1A | |
| Coil Voltage | 220VAC | |
| Terminal | Captive Screw | |
| Mount | Panel | |
| Range Setting | 1.5 to 15 S | |

| Material Number 0151319 | | |
|--|--------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Part Number | ETR5-10 | |
| Specification | VDE0660 | |
| Reference | ETR5-10R | |
| Relay Type | Time Delay | |
| Operation | 0.5 -10 S | |
| Contact Arrangement | 1NO 1NC | |
| Contact Rating | 240VAC 2A | |
| Coil Voltage | 110VAC | |
| Enclosure Rating | IP67 | |
| Terminal | Captive Screw | |
| Mount | Bracket | |

CONTROLLED DISCLOSURE

When downloaded from the EDMS, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

| Material Number 0151320 | | |
|--|--------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Model Number | SA145 | |
| Relay Type | Time Delay | |
| Operation | 0.8-18 S | |
| Coil Voltage | 24VDC | |
| Supply Voltage | 220VAC | |
| Terminal | 11 Pin | |
| Mount | Direct Beneath Contactor | |

| Material Number 0151321 | | |
|--|--------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Relay Type | Time Delay | |
| Operation | ON/OFF 3 – 60 MIN | |
| Contact Rating | 10 A | |
| Coil Voltage | 120 VAC | |
| Contact Arrangements | 1NO 1NC | |
| Enclosure Rating | Plastic | |
| Terminal | 11 Pin Plug | |
| Mount | Octal Socket | |

| Material Number 0151333 | | |
|--|--------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Part Number | SB175-120 | |
| Relay Type | Time Delay | |
| Operation | ON 0.15 – 3 S | |
| Coil Voltage | 120 VAC | |
| Contact Arrangements | 1NO 1NC | |
| Terminal | 11 Pin Plug | |
| Mount | Octal Socket | |

CONTROLLED DISCLOSURE

When downloaded from the EDMS, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

| Material Number 0151334 | | |
|--|--------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Part Number | SC700-120VAC | |
| Article Number | 22747 | |
| Relay Type | Dividing | |
| Coil Volatge | 110 – 120 VAC | |
| Contact Rating | 300 VAC 10 A; 250 VDC 2A | |
| Contact Arrangement | 1NO 1NC | |
| Terminal | 11 Pin Plug in | |
| Enclosure Rating | IP20 | |
| Mount | Octal Socket | |

| Material Number 0151336 | | |
|--|--------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Part Number | BA7905-82 | |
| Article Number | 22747 | |
| Relay Type | Time Delay | |
| Operation | 0.15 – 3 S | |
| Contact Rating | 220 VAC | |

| Material Number 0151337 | | |
|--|--------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Reference Number | FPTN477016R0007 | |
| Reference Number | TP40D | |
| Relay Type | Time Delay | |
| Operation | OFF 0 – 20 S | |
| Coil Voltage | 220 - 240 VAC | |
| Contact Rating | 220 V 3A | |
| Contact Arrangement | 1NO 1NC | |

CONTROLLED DISCLOSURE

When downloaded from the EDMS, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

| | | |
|-------------------------|---------------|--|
| Terminal | Captive Screw | |
| Enclosure Rating | Bakelite | |
| Mount | Panel | |

| Material Number 0151344 | | |
|---|--|-------------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Reference Number | A642937 | |
| Reference Number | E83400 | |
| Relay Type | Time Delay | |
| Operation | ON 0 – 2 MIN; OFF 0 – 5S | |
| Coil Voltage | 240 VAC | |
| Contact Rating | 120VAC 1/6 HP; 240 VAC ¼ HP; 30 VDC 5A | |
| Contact Arrangement | 2NO 2NC | |
| Terminal | 8 Pin plug in | |
| Mount | Octal Socket | |

| Material Number 0151345 | | |
|---|---------------------------------|-------------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Part Number | BA7901.32 | |
| Article Number | 26641 | |
| Relay Type | Time Delay | |
| Operation | 0.15 – 3 S | |
| Coil Voltage | 24 VDC | |
| Contact Rating | 3A | |
| Contact Arrangement | 2NO 2NC | |
| Terminal | Screw | |
| Mount | Panel | |

CONTROLLED DISCLOSURE

When downloaded from the EDMS, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

| Material Number 0151399 | | |
|--|--------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Part Number | ST111 | |
| Relay Type | Time Delay | |
| Operation | ON/OFF 220 S – 240 MIN | |
| Coil Voltage | 110 VAC | |
| Contact Rating | 5A | |
| Contact Arrangement | 2NO 2NC | |
| Terminal | 11 Pin Plug in | |
| Mount | Octal Socket | |
| Enclosure rating | Plastic | |

| Material Number 0151400 | | |
|--|--------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Part Number | HESG442183R0001 | |
| Part Number | PR1N1AY | |
| Drawing | Eskom O.63/3688 | |
| Relay Type | Time Delay | |
| Operation | 0.1 – 0.5 S | |
| Coil Voltage | 220 VAC | |
| Contact Arrangement | 3NO 1NC | |

| Material Number 0193511 | | |
|--|--|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Reference Number | 3AY1510 | |
| Relay Type | Anti-Pumping | |
| Contact Arrangement | Solenoid | |
| Enclosure | Open for 11 and 3.3 KV Vacuum Breaker | |

CONTROLLED DISCLOSURE

When downloaded from the EDMS, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

| Material Number 0223445 | | |
|--|--------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Reference Number | 3RB1246-1EM00 | |
| Relay Type | Overload | |
| Trip Range | 25 – 100 A | |
| Current | 100A | |
| Control Voltage | 220V | |
| Contact Arrangement | 2NO 2NC | |
| Reset | Manual | |
| Terminal | Screw | |
| Mount | Individual | |

| Material Number 0223827 | | |
|--|--------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Reference Number | 2961105 | |
| Relay Type | Miniature | |
| Trip Range | 20 – 100 A | |
| Contact Rating | 48/240 VAC | |
| Coil Voltage | 24 VDC | |
| Contact Arrangement | 1NO 1NC | |
| Enclosure Rating | IP65 | |
| Terminal | 5 Pin | |
| Mount | Plug in | |

CONTROLLED DISCLOSURE

When downloaded from the EDMS, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

| Material Number 0246125 | | |
|--|--------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Reference Number | 3RU1126-4BBO | |
| Relay Type | Overload | |
| Current range | 14 - 20A | |
| Current | 3A | |
| Contact Arrangement | 1NO 1NC | |
| Reset Type | Automatic/Manual | |
| Enclosure Rating | IP67 | |
| Terminal | Captive Clamp | |
| Mount | Direct | |

| Material Number 0247504 | | |
|--|--------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Part Number | FN-DE, RF4 | |
| Specification | IEC 255-5 | |
| Relay Type | Auxiliary | |
| Contact Rating | 220 VDC | |
| Coil Voltage | 220 VDC | |
| Contact Arrangement | Change Over | |
| Mount | Clip in | |
| Terminal | 16 Captive Screw | |

| Material Number 0248774 | | |
|--|--------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Part Number | LRD-06 | |
| Supplier | Schneider Electric | |
| Manufacturer | Telemecanique | |
| Relay Type | Overload | |

CONTROLLED DISCLOSURE

When downloaded from the EDMS, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

| | | |
|-----------------------------|--------------------------|--|
| Current range | 1 - 1.6A | |
| Operating Temp Range | -20 to 60 Degrees | |
| Contact Arrangement | 1NO 1NC | |
| Pole | 3 | |
| Insulation | 690V | |
| Reset Type | Automatic/Manual | |
| Mount | Direct Beneath Contactor | |

| Material Number 0251521 | | |
|---|---------------------------------|-------------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Part Number | PUA01C B23500V | |
| Relay Type | AC/DC Voltage/Current | |
| Contact Rating | 230 VAC 10 A | |
| Coil Voltage | 230 VAC | |
| Contact Arrangement | 1NO 1NC | |
| Mount | Base | |
| Terminal | 2 Pin | |
| Enclosure | IP20 | |

| Material Number 0151593 | | |
|---|---------------------------------|-------------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Reference Number | DT310-1 | |
| Serial Number | 09364 | |
| Relay Type | Time Delay | |
| Operation | ON/OFF 1.8 – 120 S | |
| Coil Voltage | 90/250 VAC | |
| Contact Arrangement | 2NO 2NC | |
| Terminal | 11 Pin | |
| Mount | Octal Socket | |
| Enclosure | Plastic | |

CONTROLLED DISCLOSURE

When downloaded from the EDMS, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

| Material Number 0151594 | | |
|--|--------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Reference Number | 04-09 | |
| Relay Type | Time Delay | |
| Operation | ON 0.1 – 2 S | |
| Coil Voltage | 220 VAC | |
| Contact Arrangement | 1NO 1NC | |
| Terminal | 11 Pin | |
| Mount | Octal Socket | |
| Enclosure | Plastic | |

| Material Number 0151595 | | |
|--|--------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Reference Number | 09485 | |
| Part Number | DT310-1 | |
| Relay Type | Time Delay | |
| Operation | ON 0.15 – 3 S | |
| Coil Voltage | 220 VDC | |
| Contact Arrangement | 2NO 2NC | |
| Terminal | 11 Pin | |
| Mount | Octal Socket | |
| Enclosure | Plastic | |

| Material Number 0237786 | | |
|--|----------------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Part Number | 1MRK 002 398-BA RK 795 102-AD | |
| Relay Type | Solid State | |
| Contact Rating | 250 VAC/DC | |
| Coil Voltage | DC | |

CONTROLLED DISCLOSURE

When downloaded from the EDMS, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

| | | |
|----------------------------|----------------|--|
| Contact Arrangement | Change Over | |
| Enclosure Rating | Steel/ Perspex | |
| Mount | Flush | |

| Material Number 0600201 | | |
|---|---------------------------------|-------------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Part Number | 373, 374 | |
| Relay Type | Transformer Protection | |
| Contact Rating | 250 V 6 A | |
| Coil Voltage | Magnetic Contact Tube | |
| Contact Arrangement | 1NO 2NO | |
| Mount | Flange | |
| Terminal | Bolted | |
| Enclosure | IP56 | |

| Material Number 0007941 | | |
|---|---------------------------------|-------------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Reference Number | C11-2 | |
| Relay Type | Auxiliary Overcurrent | |
| Contact Arrangement | 7NO 3NC | |
| Reset | Hand Reset | |
| Contact Rating | 250 VDC | |
| Trip Control | Case Size 1D | |
| Terminal | 20 | |
| Mount | Flush vertical | |

CONTROLLED DISCLOSURE

When downloaded from the EDMS, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

| Material Number 0007988 | | |
|--|--------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Reference Number | 4PDT (MY4) | |
| Coil Voltage | 48VDC | |
| Relay Type | Auxiliary Overcurrent | |
| Contact Arrangement | 4NO 4NC | |
| Contact Rating | 220 VDC | |
| Trip Control | Case Size 1D | |
| Terminal | 14 Pin Plug in | |
| Mount | Terminal Socket | |

| Material Number 0115057 | | |
|--|-----------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Reference Number | GDW2-A | |
| Coil Voltage | 220VAC | |
| Relay Type | SolidState(Belt Underspeed) | |
| Contact Arrangement | 1NO 1NC | |
| Contact Rating | 220 VAC ,6A | |
| Minimum Input | 2VA | |
| Terminal | 14 Pin Plug in | |
| Mount | Din Rail | |

| Material Number 0115138 | | |
|--|----------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Reference Number | HR 114-02 ;(05-33-07);6PST | |
| Coil Voltage | 24VDC | |
| Relay Type | Auxiliary Overcurrent | |

CONTROLLED DISCLOSURE

When downloaded from the EDMS, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

| | | |
|----------------------------|-----------------|--|
| Contact Arrangement | 6NO 4NC | |
| Enclosure Rating | Plastic clear | |
| Terminal | 14 Pin Plug in | |
| Mount | Terminal Socket | |

| Material Number 0115522 | | |
|---|---------------------------------|-------------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Reference Number | 7PA1013-2EA;(C72303-A9-B12) | |
| Coil Voltage | 60VDC | |
| Relay Type | Auxiliary Overcurrent | |
| Contact Arrangement | 2NO 2NC | |
| Contact Rating | 380VAC,440VDC,10A | |
| Enclosure Rating | Plastic Clear | |
| Terminal | 8 Pin Plug in | |
| Mount | Terminal Socket | |

| Material Number 0115523 | | |
|---|---------------------------------|-------------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Reference Number | 7PA1023-6EA;C72303-A9-B118 | |
| Coil Voltage | 220VDC | |
| Relay Type | Auxiliary Overcurrent | |
| Contact Arrangement | 4NO 4NC | |
| Contact Rating | 380VAC,440VDC,10A | |
| Enclosure Rating | Plastic Clear | |
| Terminal | 14 Pin Plug in | |
| Mount | Terminal Socket | |

| Material Number 0125716 | | |
|---|---------------------------------|-------------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Reference Number | C004DMS | |

CONTROLLED DISCLOSURE

When downloaded from the EDMS, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

| | | |
|---------------------|-----------------|--|
| Relay Type | Monitor | |
| Contact Arrangement | 4NO 4NC | |
| Enclosure Rating | PLASTIC; 316/24 | |
| Terminal | 8 Lead Splder | |
| Mount | PCB | |

| Material Number 0124690 | | |
|--|---------------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Reference Number | GPD243C10; OA0600OCOANN;3PDT | |
| Coil Voltage | 24VDC | |
| Relay Type | Auxiliary Overcurrent | |
| Contact Arrangement | 3NO 3NC | |
| Enclosure Rating | Plastic Clear | |
| Terminal | 11 Pin Plug in | |
| Mount | Terminal Socket | |

| Material Number 0125492 | | |
|--|---|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Reference Number | 3RN1010-1CM00 | |
| Relay Type | Auxiliary Overcurrent | |
| Coil Voltage | 220-240VAC | |
| Contact Arrangement | 1NO 1NC | |
| Specification | IEC 34-11-1A; THERMISTER, O/A DIMS 100MM LG X 76MM HT X 45MM WIDE, RATED VOLTAGE 4AMP, 250VDC 0.2AMP | |
| Contact Rating | 120/250/400 VAC 6/3/1.5 A | |
| Enclosure Rating | Plastic | |
| Terminal | Screw | |
| Mount | Panel | |

| Material Number 0125546 |
|-------------------------|
|-------------------------|

CONTROLLED DISCLOSURE

When downloaded from the EDMS, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
|--|------------------------------------|------------|
| Criteria | Requirement (Schedule A) | Schedule B |
| Reference Number | 893801; RHC4E115V; R10E1X4-115V | |
| Relay Type | Auxiliary Overcurrent | |
| Coil Voltage | 115VDC | |
| Contact Arrangement | 4NO 4NC | |
| Overall Dimensions | 19MM WD X 29MM LG X 30MM HT | |
| Contact Rating | 250 VAC 2 A; 28 VDC 5 A | |
| Enclosure Rating | Plastic | |
| Terminal | 14 Pin Plug In | |
| Mount | Terminal Socket | |

| Material Number 0125561 | | |
|--|--------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Reference Number | 60-B;(60-13) | |
| Relay Type | Auxiliary Overcurrent | |
| Coil Voltage | 220VAC | |
| Contact Arrangement | 3NO 3NC | |
| Contact Rating | 250 VAC 10 A | |
| Enclosure Rating | Plastic | |
| Terminal | 11 Pin Plug In | |
| Mount | Octal Socket | |

| Material Number 0125583 | | |
|--|--------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Reference Number | MK2P | |
| Part Number | | |
| Relay Type | Control | |

CONTROLLED DISCLOSURE

When downloaded from the EDMS, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

| | | |
|----------------------------|---------------|--|
| Contact Arrangement | 2NO 2NC | |
| Contact Rating | 250 V 10 A | |
| Coil Voltage | 220 VAC | |
| Terminal | 8 PIN PLUG IN | |
| Mount | Socket | |
| Enclosure Rating | Plastic Clear | |

| Material Number 0125588 | | |
|---|---------------------------------|-------------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Part Number | 3UA5900-2E | |
| Trip Range | 25 - 40 A | |
| Relay Type | Overload | |
| Contact Arrangement | 1NO 1NC | |
| Reset | Manual | |
| Current | 40 A | |
| Pole | 3 | |
| Contact Rating | 240 VAC 5/8A | |
| Coil Voltage | 12 - 240 VAC/DC | |
| Terminal | Captive Clamp | |
| Mount | Bracket | |
| Enclosure Rating | Open | |

| Material Number 0125602 | | |
|---|---------------------------------|-------------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Reference Number | XM | |
| Part Number | SPDT-240 | |
| Operation | ON 0.6 - 6 S 6 - 60 MIN | |
| Relay Type | Time Delay | |
| Contact Arrangement | 2NO 2NC | |
| Contact Rating | 240 VAC 5/8A | |
| Coil Voltage | 12-240 VAC/DC | |

CONTROLLED DISCLOSURE

When downloaded from the EDMS, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

| | | |
|-----------------|----------------|--|
| Terminal | 11 Pin Plug In | |
| Mount | Plug In | |

| Material Number 0125632 | | |
|--|--------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Reference Number | MK2PI12VDC8PIN | |
| Relay Type | Auxiliary Overcurrent | |
| Coil Voltage | 12VDC | |
| Contact Arrangement | 2NO 2NC | |
| Contact Rating | 250 VAC 10 A; 28 VDC | |
| Enclosure Rating | Plastic | |
| Terminal | 8 Pin Plug In | |
| Mount | Octal Socket | |

| Material Number 0125788 | | |
|--|--|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Reference Number | R927C 1000 2; PART NO: OA0600OCOANN; UNIVERSAL CONTACT; FOR MODUTROL | |
| Relay Type | Balancing | |
| Coil Voltage | 24VDC | |
| Contact Arrangement | 1NO 1NC | |
| Contact Rating | 1A | |
| Enclosure Rating | Metal Case | |
| Terminal | Captive Screw | |
| Mount | Horizontal Flush | |

| Material Number 0125643 | | |
|--|--------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Reference Number | REFERENCE NO: | |

CONTROLLED DISCLOSURE

When downloaded from the EDMS, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

| | | |
|----------------------------|--|--|
| | LT1SA12F; PART NO: LLT2SE00F; PART NO: NFC 20534 | |
| Relay Type | VARIABLE PERCENTAGE DIFFERENTIAL | |
| Coil Voltage | 110/127 VAC | |
| Contact Arrangement | 1NO 1NC | |
| Contact Rating | 300VAC 5A | |
| Enclosure Rating | Plastic | |
| Terminal | Clamp Captive | |
| Mount | Panel | |
| SPECIFICATION | IEC255-5; THERMISTER PROTECTION, 50/60 HZ, CONTACT UNIVERSAL | |

| Material Number 0125677 | | |
|--|--------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Reference Number | L2-C11B | |
| Relay Type | Auxiliary Overcurrent | |
| Coil Voltage | 24VDC | |
| Contact Arrangement | 4NO 4NC | |
| Contact Rating | | |
| Enclosure Rating | Plastic | |
| Terminal | 14 Pin Plug In | |
| Mount | PCB | |

| Material Number 0125697 | | |
|--|--|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Reference Number | REFERENCE NO: BA220DG28DKC; PART NO: MTI | |
| Relay Type | Auxiliary Overcurrent | |

CONTROLLED DISCLOSURE

When downloaded from the EDMS, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

| | | |
|----------------------------|-----------------|--|
| Coil Voltage | 220VAC | |
| Contact Arrangement | 4NO 4NC | |
| Contact Rating | 250 VAC 12 A | |
| Enclosure Rating | Plastic | |
| Terminal | 14 Pin Plug In | |
| Mount | Terminal Socket | |

| Material Number 0125714 | | |
|--|---|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Reference Number | REFERENCE NO: D2410-1; PART NO: OPL 55282 | |
| Relay Type | SOLID STATE: TYPE: SEMI CONDUCTOR | |
| Coil Voltage | 3 - 32VDC | |
| Contact Arrangement | 1NO | |
| Contact Rating | 240 VAC 10 A | |
| Enclosure Rating | Plastic | |
| Terminal | 14 Pin Plug | |
| Mount | Terminal Socket | |
| Info | FOR TURBINE PROTECTION/CONTROLLERS AND SUPERVISORY SYSTEMS | |

| Material Number 0125715 | | |
|--|--------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Reference Number | MR11-01 | |
| Relay Type | Over Voltage | |
| Contact Arrangement | 1NO 1NC | |
| Contact Rating | 1.7 VAC | |
| Enclosure Rating | Plastic | |
| Terminal | Captive Screw | |
| Mount | Panel | |

CONTROLLED DISCLOSURE

When downloaded from the EDMS, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

| Material Number 0125764 | | |
|--|---|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Reference Number | REFERENCE NO: 023463; PART NO: CAD32M7 | |
| Coil Voltage | 220VAC | |
| Relay Type | Control | |
| Contact Arrangement | 2NO 2NC | |
| Contact Rating | 600 VAC 10 A | |
| Enclosure Rating | BAKELITE | |
| Terminal | Captive Clamp | |
| Mount | Panel | |

| Material Number 0125767 | | |
|--|--------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Reference Number | LRD 22 | |
| Trip Range | 18 - 25 A | |
| Relay Type | Overload | |
| Contact Arrangement | 1NO 1NC | |
| Reset | Automatic/Manual | |
| Contact Rating | 250 VAC 10 A | |
| Coil Voltage | 380 VAC | |
| Terminal | Captive Screw | |
| Mount | Panel | |
| Rating | Bakelite | |

| Material Number 0125787 | | |
|--|--------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |

CONTROLLED DISCLOSURE

When downloaded from the EDMS, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

| | | |
|---------------------|---|--|
| Reference Number | OMRON, LIST NO 19Y4YH; REFERENCE NO: LY-4PDT | |
| Relay Type | Auxiliary Overcurrent | |
| Coil Voltage | 24VDC | |
| Contact Arrangement | 4NO 4NC | |
| Contact Rating | 240 VAC 10 A | |
| Enclosure Rating | Plastic | |
| Terminal | 14 Pin Plug In | |
| Mount | Terminal Socket | |

| Material Number 0125791 | | |
|--|--------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Reference Number | SJ135-220V | |
| Coil Voltage | 230VAC | |
| Relay Type | DC Voltage Level | |
| Contact Arrangement | 1NO 1NC | |
| Contact Rating | 2-10 VDC | |
| Enclosure Rating | IP20 | |
| Terminal | 11 Pin Plug | |
| Mount | Octal Socket | |
| Electromatic System Sensing | Calibration 2/4/6/8/10V | |

| Material Number 0125810 | | |
|--|--------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Reference Number | 3TH2022-OAMO | |
| Coil Voltage | 220VAC | |
| Relay Type | Control | |
| Contact Arrangement | 2NO 2NC | |
| Contact Rating | 220V 4A | |
| Enclosure Rating | Plastic | |
| Terminal | Screw Captive | |
| Mount | Panel | |

CONTROLLED DISCLOSURE

When downloaded from the EDMS, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

| Material Number 0125813 | | |
|--|--------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Reference Number | 3TH8031-0AM0 | |
| Coil Voltage | 220VAC | |
| Relay Type | Control | |
| Contact Arrangement | 3NO 1NC | |
| Contact Rating | 220V 10A | |
| Enclosure Rating | Bakelite | |
| Terminal | Captive Screw | |
| Mount | Panel | |

| Material Number 0006682 | | |
|--|--|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| Relay Specification | CDG16AF8A5 | |
| Relay Type | Inverse Time Overcurrent & Earth Fault relay | |
| Current Setting range | 0.2 to 0.8 A | |
| Preferred or standard Increments | 0.1 | |
| Current Transformer secondary increments | 1A | |
| Characteristics (time setting at 10 times Is) | 0 to 1.3 s | |
| Nominal Burden | 3VA continuously rated | |
| Trip circuit (series seal in, shunt reinforcing or ac) | Voltage operated series seal in auxiliary unit | |
| Trip circuit current (series seal in) | 0.2 to 0.8 | |
| Trip circuit voltage (shunt reinforcing) | 220V dc | |
| Operation Indicator | Hand reset operation indicator | |
| Auxiliary contacts (hand or self reset) | 2 make self-reset | |

CONTROLLED DISCLOSURE

When downloaded from the EDMS, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

| | | |
|---|----------------|--|
| Details of instantaneous unit (CAG if required) | N/A | |
| Case Mounting | Flush mounting | |

| Material Number 0006681 | | |
|--|--------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| RELAY | TIME DELAY | |
| CONTACT ARRANGEMENT | 9NO 1NC | |
| ACTION | 10PST | |
| COIL VOLTAGE | 110 V | |
| TERMINAL | 24 SCREW CAPTIVE | |
| MOUNT | PANEL FLUSH MOUNT | |
| PART NO | TCDS B12 | |
| GENERAL | FOR USE ON MV SWITCHGEAR | |

| Material Number 0007873 | | |
|--|--------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| PART NO | TC 32 | |
| RELAY | SOLID STATE | |
| TYPE | AUTO SYNCHRONIZE CHECK | |
| AUXILIARY VOLTAGE | 220V DC | |
| INPUT VOLTAGE | 110V AC | |

| Material Number 0125538 | | |
|--|--------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| PART NO | RXOTD4 | |
| RELAY | UNDERVOLTAGE RELAY | |
| RATED VOLTAGE | 380/220 V AC | |

CONTROLLED DISCLOSURE

When downloaded from the EDMS, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

| | | |
|--------------------------|------------------------------------|--|
| FREQUENCY | 50Hz | |
| AUXILIARY VOLTAGE | SAME AS LINE VOLTAGE | |
| CONTACT DATA | 2 TRANSFER CONTACTS | |
| ORDERING NUMBER | NUMBER/PART RK 433001-AB | |

| Material Number 0125970 | | |
|---|---------------------------------|-------------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| RELAY TYPE | AUXILIARY | |
| COIL VOLTAGE | 220 VDC | |
| CONTACT ARRANGEMENT | 1NO & 1NC | |
| MOUNTING | HORIZONTAL FLUSH | |
| CASE SIZE | 1D | |
| TERMINALS | BACK CONNECTED, 12 TERMINALS | |
| REFERENCE NUMBER/PART NO | VAWA SPEC27ZG168A | |

| Material Number 0126374 | | |
|---|---------------------------------|-------------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| RELAY | SOLID STATE | |
| TYPE | INTERPOSING | |
| POTENTIAL | 220 VAC | |
| MOUNTING | HORIZONTAL FLUSH | |
| CASE SIZE | 1D | |
| TERMINALS | BACK CONNECTED, 20 TERMINALS | |
| REFERENCE NUMBER/PART NO | VAWA/VAA SPEC278162A | |

| Material Number 0126431 | | |
|---|---------------------------------|-------------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |

CONTROLLED DISCLOSURE

When downloaded from the EDMS, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

| | | |
|--------------------------|---------------------------------|--|
| RELAY | SOLID STATE | |
| TYPE | TRIPPING | |
| POTENTIAL | 220V DC | |
| CONTACT ARRANGEMENT | 2NO 2NC | |
| MOUNTING | HORIZONTAL FLUSH | |
| CASE SIZE | 1/2N | |
| TERMINALS | BACK CONNECTED, 12 TERMINALS | |
| REFERENCE NUMBER/PART NO | VAJSPEC11ZG485A | |

| Material Number 0126433 | | |
|--|---------------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| RELAY | SOLID STATE | |
| TYPE | TRIPPING | |
| POTENTIAL | 220V DC | |
| CONTACT ARRANGEMENT | 3NO 2NC | |
| MOUNTING | VERTICAL FLUSH | |
| CASE SIZE | 1/4IN | |
| TERMINALS | BACK CONNECTED, 10 TERMINALS | |
| REFERENCE NUMBER/PART NO | 11BF5525BA | |

| Material Number 0126434 | | |
|--|--------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| RELAY | SOLID STATE | |
| TYPE | TRIPPING | |
| POTENTIAL | 220V DC | |
| CONTACT ARRANGEMENT | 3NO 2NC | |
| MOUNTING | VERTICAL FLUSH | |
| CASE SIZE | 1/4IN | |
| TERMINALS | BACK CONNECTED | |
| FLAG INDICATION | HAND RESET | |

CONTROLLED DISCLOSURE

When downloaded from the EDMS, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

| | | |
|--------------------------|-----------------|--|
| REFERENCE NUMBER/PART NO | VAJY 11BF5526BA | |
|--------------------------|-----------------|--|

| Material Number 0126448 | | |
|--|---------------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| RELAY | SOLID STATE | |
| TYPE | MASTER TRIP | |
| POTENTIAL | 220V DC | |
| CONTACT ARRANGEMENT | 5NO 4NC | |
| MOUNTING | FLUSH | |
| CASE SIZE | 1D | |
| TERMINALS | BACK CONNECTED, 20 TERMINALS | |
| FLAG INDICATION | HAND RESET | |
| REFERENCE NUMBER/PART NO | VAJY11BF5524BA | |
| | | |

| Material Number 0126449 | | |
|--|--------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| RELAY | AUXILIARY | |
| TYPE | MASTER TRIP | |
| POTENTIAL | 220V DC | |
| CONTACT RATING | 220V | |
| CONTACT ARRANGEMENT | 3NO 2NC | |
| ACTION | 3PST | |
| TERMINAL | CAPTIVE SCREW | |
| MOUNTING | PANEL | |
| ENCLOSURE RATING | BAKELITE | |
| CONTACT MATERIAL | SILVER PLTD | |
| FLAG INDICATION | HAND RESET | |
| REFERENCE NUMBER/PART NO | VAJY 13YF 5522FB | |

CONTROLLED DISCLOSURE

When downloaded from the EDMS, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

| Material Number 0126450 | | |
|--|--------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| RELAY | TIME DELAY | |
| OPERATION | 0.5-5 S | |
| COIL VOLTAGE | 250V DC | |
| TERMINALS CONNECTION | BACK CONNECTION | |
| CONTACT ARRANGEMENT | 2NO + 2NC | |
| ACTION | 3PDT | |
| TERMINAL | 12 CAPTIVE SCREW | |
| MOUNTING | BRACKET | |
| SIZE | 1/2N | |
| CONTACT MATERIAL | AG PLTD | |
| FLAG INDICATION | HAND RESET | |
| REFERENCE NUMBER/PART NO | VTT12ZG2034A; | |

| Material Number 0126451 | | |
|--|-------------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| RELAY | SOLID STATE | |
| TYPE | INSTANTANEOUS UNDER VOLTAGE | |
| TERMINALS CONNECTION | BACK CONNECTION, 10 TERMINALS | |
| SIZE | 1/2N | |
| REFERENCE NUMBER/PART NO | VAG21ZG2006BA | |

| Material Number 0126452 | | |
|--|--------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| RELAY | SOLID STATE | |
| TYPE | AUXILIARY | |

CONTROLLED DISCLOSURE

When downloaded from the EDMS, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

| | | |
|---------------------------------|----------------------------------|--|
| POTENTIAL | 220 VAC | |
| TERMINALS CONNECTION | BACK CONNECTION, 12 TERMINALS | |
| CONTACT ARRANGEMENT | 2NO + 2NC | |
| MOUNTING | HORIZONTAL FLUSH | |
| SIZE | 1D | |
| FLAG INDICATION | HAND RESET | |
| REFERENCE NUMBER/PART NO | VAA2ZG188OA | |

| Material Number 0126453 | | |
|---|---------------------------------|-------------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| RELAY | SOLID STATE | |
| TYPE | AUXILIARY | |
| CONTACT RATING | 220 VAC | |
| TERMINALS CONNECTION | 12 TERMINALS BACK CONNECTED | |
| CONTACT ARRANGEMENT | 2NO + 2NC | |
| MOUNTING | HORIZONTAL FLUSH | |
| CASE SIZE | 1/2N | |
| FLAG INDICATION | HAND RESET | |
| REFERENCE NUMBER/PART NO | VAASPEC21ZG1855A | |

| Material Number 0126454 | | |
|---|---------------------------------|-------------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| RELAY | SOLID STATE | |
| TYPE | UNDERVOLTAGE | |
| CONTACT RATING | 220 VDC | |
| TERMINALS CONNECTION | 12 TERMINALS BACK CONNECTED | |
| CONTACT ARRANGEMENT | 2NO + 2NC | |
| MOUNTING | HORIZONTAL FLUSH | |
| CASE SIZE | 1/2N | |
| FLAG INDICATION | HAND RESET | |

CONTROLLED DISCLOSURE

When downloaded from the EDMS, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

| | | |
|--------------------------|-----------|--|
| REFERENCE NUMBER/PART NO | VAG21ZG9N | |
|--------------------------|-----------|--|

| Material Number 0126455 | | |
|--|----------------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| RELAY | SOLID STATE | |
| TYPE | OVERCURRENT | |
| POTENTIAL | 220 VDC | |
| TIME DELAY | 0.5 - 2s | |
| TERMINALS CONNECTION | BACK CONNECTION, 12 TERMINALS | |
| CASE SIZE | 1-1/2D | |
| FLAG INDICATION | HAND RESET | |
| REFERENCE NUMBER/PART NO | CAG36EF5A5 | |

| Material Number 0126456 | | |
|--|----------------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| RELAY | SOLID STATE | |
| TYPE | OVERVOLTAGE | |
| CONTACT RATING | 220 VDC | |
| RANGE | 121V TO 187V | |
| TERMINALS CONNECTION | BACK CONNECTION, 10 TERMINALS | |
| CASE SIZE | 1D | |
| FLAG INDICATION | HAND RESET | |
| REFERENCE NUMBER/PART NO | VDG11AF2151B5 | |

| Material Number 0126457 | | |
|--|--------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |

CONTROLLED DISCLOSURE

When downloaded from the EDMS, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

| | | |
|--------------------------|----------------------------------|--|
| RELAY | SOLID STATE | |
| TYPE | POWER REVERSING | |
| POTENTIAL | 220 VDC | |
| CURRENT | 1A | |
| INPUT | 3 X 1A INPUT | |
| TERMINALS CONNECTION | BACK CONNECTION, 20 TERMINALS | |
| CASE SIZE | 1D | |
| FLAG INDICATION | HAND RESET | |
| REFERENCE NUMBER/PART NO | WCD11BF2081A5 | |

| Material Number 0126458 | | |
|--|----------------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| RELAY | SOLID STATE | |
| TYPE | UNDER FREQUENCY | |
| POTENTIAL | 220 VDC | |
| RANGE | 45 – 48.5 Hz | |
| TERMINALS CONNECTION | BACK CONNECTION, 10 TERMINALS | |
| CASE SIZE | 1 – 1/2D | |
| FLAG INDICATION | HAND RESET | |
| REFERENCE NUMBER/PART NO | FMG12AF2003A | |

| Material Number 0126459 | | |
|--|----------------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| RELAY | SOLID STATE | |
| TYPE | PROTECTION | |
| POTENTIAL | 220 VDC | |
| CURRENT | 1A | |
| TIME DISCREPANCY | | |
| TERMINALS CONNECTION | BACK CONNECTION, 10 TERMINALS | |
| CASE SIZE | 1D | |

CONTROLLED DISCLOSURE

When downloaded from the EDMS, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

| | | |
|--------------------------|------------|--|
| FLAG INDICATION | HAND RESET | |
| REFERENCE NUMBER/PART NO | SOLKOR RF | |

| Material Number 0126462 | | |
|--|----------------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| RELAY | SOLID STATE | |
| TYPE | AUXILIARY | |
| CONTACT RATING | 220 VDC | |
| TERMINALS CONNECTION | BACK CONNECTION, 20 TERMINALS | |
| CASE SIZE | 1D | |
| FLAG INDICATION | HAND RESET | |
| REFERENCE NUMBER/PART NO | VAA61 SPEC2BF10SA | |

| Material Number 0126463 | | |
|--|--------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| RELAY | SOLID STATE | |
| TYPE | OVER-CURRENT | |
| COIL VOLTAGE | 220 V | |
| CONTACT ARRANGEMENT | 6 NO | |
| CONTACT RATING | 1A | |
| CONTACT MATERIAL | SILVER PLATED | |
| ACTION | 6PST | |
| TERMINALS | 10 CAPTIVE SCREW | |
| MOUNT | FLUSH PANEL | |
| FLAG INDICATION | HAND RESET | |
| REFERENCE NUMBER/PART NO | CAG39AF11A | |

| Material Number 0126750 |
|-------------------------|
|-------------------------|

CONTROLLED DISCLOSURE

When downloaded from the EDMS, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
|--|--------------------------|------------|
| Criteria | Requirement (Schedule A) | Schedule B |
| RELAY | NUMERIC | |
| TYPE | MOTOR PROTECTION | |
| COIL VOLTAGE | 80V - 265V DC | |
| CONTACT ARRANGEMENT | 1NO | |
| CONTACT RATING | 1 - 5A | |
| REFERENCE NUMBER/PART NO | SPAM 150C | |

| Material Number 0126466 | | |
|--|-------------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| RELAY | SOLID STATE | |
| TYPE | TRIPPING | |
| POTENTIAL | 220 VDC | |
| CONTACT ARRANGEMENT | 7NO 1NC | |
| TERMINALS | 20 TERMINALS, BACK CONNECTION | |
| CASE SIZE | 1D | |
| MOUNT | FLUSH PANEL | |
| FLAG INDICATION | HAND RESET | |
| REFERENCE NUMBER/PART NO | VAJ V11BF2402BA | |

| Material Number 0126827 | | |
|--|--------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| RELAY | SOLID STATE | |
| TYPE | DC FAIL | |
| COIL VOLTAGE | 220 VDC | |
| CONTACT ARRANGEMENT | 2NC | |
| CONTACT RATING | 10A | |
| ACTION | DPST | |
| TERMINAL | CAPTIVE SCREW | |
| CONTACT MATERIAL | SILVER PLTD | |

CONTROLLED DISCLOSURE

When downloaded from the EDMS, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

| | | |
|-------------------------|---------------|--|
| MOUNT | FLUSH PANEL | |
| FLAG INDICATION | HAND RESET | |
| REFERENCE NUMBER | C821655 | |
| PART NO | VAA11YF4609AC | |

| Material Number 0126829 | | |
|---|----------------------------------|-------------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| RELAY | SOLID STATE | |
| TYPE | TIME DELAY | |
| OPERATION | OFF, 0.05 – 0.5s | |
| CONTACT ARRANGEMENT | 2NO | |
| COIL VOLTAGE | 250V DC | |
| ACTION | 3PST | |
| TERMINAL | 12 CAPTIVE SCREW, BACK CONNECTED | |
| CONTACT MATERIAL | AG PLTD | |
| MOUNT | HORIZONTAL FLUSH | |
| CASE SIZE | 1/2N | |
| FLAG INDICATION | HAND RESET | |
| REFERENCE NUMBER | VTT11ZG2035S | |

| Material Number 0126830 | | |
|---|---------------------------------|-------------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| RELAY | SOLID STATE | |
| TYPE | TRIP | |
| POTENTIAL | 220V DC | |
| CONTACT ARRANGEMENT | 2NO 7NC | |
| TERMINAL | 20 TERMINALS BACK CONNECTED | |
| MOUNT | VERTICAL, FLUSH | |
| CASE SIZE | 1D | |
| FLAG INDICATION | HAND RESET | |

CONTROLLED DISCLOSURE

When downloaded from the EDMS, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

| | | |
|------------------|----------------|--|
| REFERENCE NUMBER | VAJY11BF5522BA | |
|------------------|----------------|--|

| Material Number 0126862 | | |
|--|-----------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| RELAY | SOLID STATE | |
| TYPE | BIASED DIFFERENTIAL | |
| CURRENT RATING | 1A | |
| CONTACT ARRANGEMENT | 2NO | |
| TERMINAL | 24 TERMINALS BACK CONNECTED | |
| MOUNT | VERTICAL, FLUSH | |
| CASE SIZE | 1V | |
| FLAG INDICATION | HAND RESET | |
| REFERENCE NUMBER | 4C21 409A6344 | |

| Material Number 0128193 | | |
|--|--------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| RELAY | SOLID STATE | |
| TYPE | SYNCHRONIZE CHECK | |
| CONTACT RATING | 63.5V AC | |
| POTENTIAL | 220V DC | |
| CASE SIZE | 1D | |
| FLAG INDICATION | HAND RESET | |
| REFERENCE NUMBER | TC3-406A-8064 | |

| Material Number 0128547 | | |
|--|--------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| RELAY | SOLID STATE | |

CONTROLLED DISCLOSURE

When downloaded from the EDMS, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

| | | |
|---------------------|---------------------------------|--|
| TYPE | PTC THERMISTOR TRIPPING UNIT | |
| COIL VOLTAGE | 110V AC | |
| CONTACT RATING | 110-220/380 VAC 5/3/1.5 A | |
| CONTACT ARRANGEMENT | 1NO 1NC | |
| CONTACT MATERIAL | AG PLTD | |
| ACTION | DPST | |
| TERMINAL | CAPTIVE SCREW | |
| MOUNT | BRACKET | |
| PART NO | 3UN2110-OAF7 | |

| Material Number 0151335 | | |
|--|---|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| RELAY TYPE | TIME DELAY | |
| OPERATION | ON/OFF 0.001 – 1s | |
| CONTACT ARRANGEMENT | 2NO 2NC | |
| ACTION | DPDT | |
| COIL VOLTAGE | 220-250V DC | |
| TERMINAL | 8 PIN PLUG IN | |
| MOUNT | TERMINAL SOCKET | |
| REFERENCE NUMBER | REFERNCE NUMBER RK732104-BA, REFERENCE NO: RXKE1- 220-250V, REFERENCE NO: RK3330001AS PART NO: 8810 PART NO: 8324 PART NO: RXTUG2H | |

CONTROLLED DISCLOSURE

When downloaded from the EDMS, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

| Material Number 0237185 | | |
|--|--------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| RELAY | SOLID STATE | |
| TYPE | MOTOR PROTECTION | |
| CONTACT RATING | 250V DC | |
| CONTACT ARRANGEMENT | 4NO 1NC | |
| CONTACT MATERIAL | AGCDO2 | |
| ACTION | SPDT | |
| MOUNT | SLIDE IN | |
| REFERENCE NUMBER | SPCJ 4D34 | |

| Material Number 0247505 | | |
|--|--------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| RELAY TYPE | PROTECTION | |
| COIL VOLTAGE | 115V AC | |
| CONTACT RATING | 250V 5A | |
| CONTACT ARRANGEMENT | 2NO 1NC | |
| TERMINAL | 31 CAPTIVE SCREW | |
| MOUNT | FLUSH | |
| ENCLOSURE RATING | IP21 | |
| PART NO | 7 SJ 600 | |

| Material Number 0249292 | | |
|--|--------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |

CONTROLLED DISCLOSURE

When downloaded from the EDMS, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

| | | |
|---------------------|-------------------|--|
| RELAY TYPE | MONITORING | |
| COIL VOLTAGE | 160 – 500V AC | |
| CONTACT RATING | 250V | |
| CONTACT ARRANGEMENT | 2NO 2NC | |
| CONTACT MATERIAL | AGNI | |
| ACTION | 3P | |
| ENCLOSURE RATING | IP 50/20 | |
| MOUNT | DIN RAIL | |
| MODEL NO | CM-PVS | |
| PART NO: | 1SVR730794R3300CM | |

| Material Number 0559293 | | |
|--|--------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| RELAY TYPE | MOTOR PROTECTION | |
| COIL VOLTAGE | 220V DC | |
| ENCLOSURE RATING | IP54 | |
| MOUNT | FLUSH | |
| PART NO/REFERENCE NUMBER | REM 610 B11HCNN | |

| Material Number 0559414 | | |
|--|--------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| RELAY TYPE | MV FEEDER PROTECTION | |
| COIL VOLTAGE | 220V DC | |
| ENCLOSURE RATING | IP54 | |
| MOUNT | FLUSH | |
| PART NO: | REJ525B412BAA | |

| Material Number 0559415 | | |
|--|--------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| RELAY | MV FEEDER PROTECTION | |
| COIL VOLTAGE | 220V DC | |

CONTROLLED DISCLOSURE

When downloaded from the EDMS, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

| | | |
|------------------|-----------------|--|
| ENCLOSURE RATING | IP 54 | |
| MOUNT | FLUSH | |
| PART NO: | REF543KM127AAAA | |

| Material Number 0577950 | | |
|--|--------------------------|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| RELAY TYPE | ENERGY METER | |
| COIL VOLTAGE | 125 -220V AC | |
| CONTACT RATING | 24V, 25-75mA | |
| CONTACT ARRANGEMENT | 4NO 4NC | |
| ACTION | 4P4T | |
| TERMINAL | 40 PIN CLIP IN | |
| MOUNT | FLUSH | |
| CONTACT MATERIAL | SILVER PLTD | |
| PART NO: | ZMQ202C.6R4F6 | |

| Material Number 0620926 | | |
|--|--|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| RELAY TYPE | VOLTAGE OPERATED AUXILIARY TRIPPING | |
| COIL VOLTAGE | 220 – 250V DC | |
| CONTACT RATING | 220 - 250V DC | |
| CONTACT ARRANGEMENT | 4NO 2NC | |
| ACTION | INSTANTANEOUS SWITCHING | |
| MOUNT | VERTICAL, FLUSH | |
| TERMINAL | 12 | |
| ENCLOSURE RATING | IP 66 | |
| CONTACT MATERIAL | AG/CU ALLOY | |
| CONTACTS | 4M/2B | |
| CASE SIZE | 2 | |

CONTROLLED DISCLOSURE

When downloaded from the EDMS, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

| | | |
|----------------------------|------------|--|
| OPERATION INDICATOR | HAND RESET | |
| PART NO: | MVAA13 | |

| Material Number 0632771 | | |
|--|---|------------|
| TENDERER TO PLEASE COMPLETE SCHEDULE B | | |
| Criteria | Requirement (Schedule A) | Schedule B |
| RELAY TYPE | GENERATOR PROTECTION | |
| COIL VOLTAGE | 125-250V AC/DC | |
| CONTACT RATING | 30A | |
| CONTACT ARRANGEMENT | PRE - CONFIGURED | |
| ACTION | INSTANTANEOUS SWITCHING | |
| MOUNT | 3U PANEL BLOCK | |
| ENCLOSURE RATING | IP 30, IP54 | |
| CONTACTS | 6 OPTO ISOLATED CONTACT INPUT AND 8 OUTPUT CONTACTS | |
| PART NO: | SEL 300G01H4212X52 | |

CONTROLLED DISCLOSURE

When downloaded from the EDMS, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

CONTROLLED DISCLOSURE

When downloaded from the EDMS, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.