

Annexure C3.2 – Scope of Work

Executive Summary – Scope of Work:

The Amanzimtoti Station supplies Langerand reservoir, which distributes water to Sebokeng, Evaton, Helenusrust, Midvaal and Tshepong. A new 20ML reinforced concrete reservoir was constructed at Amanzimtoti as a balancing reservoir to the Langerand reservoir. The reservoir is currently full of water which was fed via bypass line connected to A13 and A20 pipeline respectively, these was done in order to commissioned the reservoir as well as checking the leaks and if the reservoir can hold pressure at full capacity.

The scope of work includes but not limited to the following:

Service provider to empty the reservoir by providing relevant pump set on trailer of 4" and 6" pumps with suction hose. Should damage be experienced service provider to reinstate around the reservoir?