






This drawing was based on the Architects Drawing No:  
07015-RWR-23-103 Rev 3


- Notes:**
1. All photoluminescent fire and directional signage must comply with SABS 1186 - 1 & 5 photoluminescent and to be installed in accordance with SABS 0400 - 1990.
  2. All photoluminescent fire and directional signs are to have a matt finish to the face of the signs and are to be framed with mitred corners and concealed elbow joints. Frame to be manufactured from Aluminium
  3. All wall-mounted fire and directional signage to be concealed screwed to brickwork. No double-sided tape
  4. All suspended fire and directional signage to be hung on stainless steel wire
  5. Signage external to building to be ABS in non - photoluminescent
  6. All signs to be 290x290 single pictogram size combinations.

**Legend:**

  
E3 = 40ff




  
F13 = 50ff

  
F24 = 30ff



  
NOODUITGANG  
HOU SKOON  
F45 = 40ff

FOR FIRE NOTES REFER TO LEVEL 902.000 FIRE  
PLAN DRAWING NUMBER 0.84/31102 SHEET 3

**Legend:**

-  - Escape Route
-  - 2 Hour Fire Wall
-  - 9.0 kg DCP Fire Extinguisher (40ff)

002	01	05/03/14	LATEST ARCHITECTURE OVERLAIN	JL	PS	DvdM	-	-	-
D01	00	05/04/12	ISSUED FOR CONSTRUCTION	JL	JJ	JJ	-	-	-
D.O.	REV	DATE	"** REVISION **"	REV	BY	CHKD	BY	AUTH	BY
DRG	REGISTR	DATE	INDEX REFERENCE	REV	BY	CHKD	BY	AUTH	BY
DESIGN	APPROVED	DATE	INDEX REFERENCE	REV	BY	CHKD	BY	AUTH	BY
KKS	APP	DATE	INDEX REFERENCE	REV	BY	CHKD	BY	AUTH	BY
DO	AUTH	DATE	INDEX REFERENCE	REV	BY	CHKD	BY	AUTH	BY
CHKD	BY	DATE	INDEX REFERENCE	REV	BY	CHKD	BY	AUTH	BY
DRAWN	BY	DATE	INDEX REFERENCE	REV	BY	CHKD	BY	AUTH	BY
SCALE	1:100								



**MEDUPI POWER STATION**  
RAW WATER RESERVOIR PUMP STATION  
PLAN LEVEL 916.000  
FIRE PROTECTION LAYOUT  
08038-FP-RWRPSS-916  
**0.84/31102**

SHEET	REV
4	1