

RFP 20/2025A
MAINTENANCE OF DIESEL GENERATORS AND RELATED INFRASTRUCTURE AT
SARS DATA CENTERS
ERRATUM

SOUTH AFRICAN REVENUE SERVICE – REQUIREMENTS AND SPECIFICATIONS

The following details have been included in paragraph 9.1 of the Business Requirements Specification:

9. Generator & HT Infrastructure & Related Infrastructure

9.1 Generator Infrastructure

“...Additional details on the SARS generator:”

Location	Generator	Size (kVA)	Generator Hours	Generator Enclosure	Commission Date	Engine Type	Serial Number
Le Hae la SARS	Gen A	Mitsubishi 1 850	1 065.03	None	2012	S16R -PTA	S1302
	Gen B	Mitsubishi 1 850	2 578.90	Container	2012	S16R -PTA2	S0815
	Gen C	Mitsubishi 1 850	3 523.06	Container	2010	S16R -PTA	S0907
Alberton Campus	Gen 1	MTU 1 600	2 239.26	Container	2013	12V4000G23	526106149
	Gen 2	MTU 1 600	2 775.56	Container	2013	12V4000G23	526106147