

Technical Evaluation **Doble AC Curent Clamp On Probe and Cap Bank Test Cable M4000**. Data sheet to be provided **(If no data sheet is supplied or scoring below 85 points will be regarded as technically non-compliant)**

Nr	Criteria	Weighting (%)	Returnable with the RFQ/Tender Yes / No / Partial compliance	Returnable Datasheet to be provided (Yes/No)	Score
1	Capacitor bank testing using the M4110, and the M4140	40	Yes – 40 Partial – 20 No - 0		
2	Test Current: 300mA	20	Yes – 20 Partial –10 No - 0		
3	Test Voltage:10kV Maximum	20	Yes – 20 Partial –10 No - 0		
4	Frequency: 45-70Hz	20	Yes – 20 Partial –10 No - 0		
	Total Score	100			
	Threshold	85			