

**BID No.: 10409721**

**Bid Description: Replace wooden pole at Transformer Pond 7 at Rand Water Zuikerbosch**

### **Annexure C3.2 Scope of Work**

Remove/disconnect transformer from overhead lines. Remove broken poles, plant 4 (four) new treated poles mount brackets and cross arms to poles. Install transformer on brackets and cross arms reconnect transformer back to overhead lines replace 11kv fuses and close fuse dropouts to switch on transformer. Also secure the four poles with wood cross arms. Ground around poles need to be compacted to secure poles.

Note that the successful supplier must submit safety file and attend induction before work commences.



**BID No.: 10409721**

**Bid Description: Replace wooden pole at Transformer Pond 7 at Rand Water Zuikerbosch**





**BID No.: 10409721**

**Bid Description: Replace wooden pole at Transformer Pond 7 at Rand Water Zuikerbosch**

## **Annexure C4 – Site Information**

**Rand Water Panfontein is situated about 2-3km up the road from Rand Water Zuikerbosch**

### **RAND WATER ZUIKERBOSCH**

Vischagat Road, Three Rivers East

Vereeniging, 1939

GPS Coordinates: S 26° 41.520 and E 28° 00.061

### **THE IMPORTANCE OF WEARING PPE**

Everyone accessing the plant will be expected to wear safety shoes, failure to which no access will be granted.

### **THE IMPORTANCE OF CARRYING YOUR DRIVER'S LICENSE**

Everyone accessing the site using personal or company vehicles is requested to always carry their valid driver's license.

### **DATA SECURITY**

The site complies with the principle of Personal Access to Information Act (PAIA) and as such all data collected will be treated with the utmost confidentiality and used solely for security and access control purposes.