

<b>Additional Staff Resources</b> <b>Roles and responsibilities of contractor staff in line of duty of typical Work Projects</b> <b>Curriculum Vitae required for each staff resource</b> <b>Details shall be completed in Returnable Schedule F15.4</b>		
<b>Number</b>	<b>Position</b>	<b>Job Description for this tender</b>
1.2	Electrical cable jointer	<p>This person shall have the necessary training, skills and experience to make electrical cable joints and terminations ranging 400 Volts – MV cables up to 11 000 Volt AC cables. Medium Voltage (MV) work will require cable joints, terminations and lead cable wipe terminations on joint boxes, transformers and RMU's. Work will take place at contractors or sub-contractors workshops and all Water and Sanitation facilities in the ENGINEERING AND ASSET MANAGEMENT (EAM) areas.</p> <p><b>Must have the following:</b></p> <ul style="list-style-type: none"> <li>▪ 2 years' experience in MV cable jointing and termination experience.</li> </ul> <p>Certified competent by a recognized major cable joint manufacturer or certified competent in terms of <b>South African Qualification Authority (SAQA)</b> Further Education and Training Certificate: Cable Jointing and Termination , <b>SAQA QUAL ID: 58204</b> or certified competent in terms of a similar MV cable jointing and termination certification or certified competent by the City of Cape Town Technical Training Centre.</p> <p><b>Previous Experience (This will be amplified in the CV of such a person)</b></p> <p>Tenderers shall have experience in <b>each</b> of the following aspects:</p> <ul style="list-style-type: none"> <li>▪ Medium Voltage Cable Jointing</li> <li>▪ Medium Voltage Cable Termination</li> <li>▪ MV Aerial Bundle Conductor Jointing</li> <li>▪ MV Aerial Bundle Conductor Termination</li> <li>▪ A jointer shall be certified competent by a recognized major cable joint manufacturer or certified competent in terms of <b>South African Qualification Authority (SAQA)</b> Further Education and Training Certificate: Cable Jointing and Termination , <b>SAQA QUAL ID: 58204</b> or equivalent MV cable jointing and termination certification or by the City of Cape Town Training Centre.</li> <li>▪ The cable jointer must have at least two years relevant work experience in cable jointing and termination; experience must be shown on the CV.</li> <li>▪ The start and end date (Month &amp; Year) of experience, the job title and specific duties performed for each period indicated must be reflected on the CV. <b>CV and copies of certificates of each Cable Jointer shall be submitted at time of contract implementation. Details shall be entered into Returnable Schedule F.15 at time of contract implementation.</b></li> <li>▪ The purpose of a cable jointer is to perform jointing and terminations on Low and Medium Voltage Cables during the Construction Works as specified by City of Cape Town representative.</li> <li>▪ Must have working knowledge of relevant Safety Legislation and Practices.</li> <li>▪ Broad knowledge of electrical equipment.</li> <li>▪ Good communication skills (Oral and written).</li> </ul>