Site: Saldanha
Date: 06-06-2025

Tender Clarification Query Sheet – Saldanha

No	Reference	Description	Response: Transnet
1	Electrical	What are the electrical battery limits?	From the point of control, including the mains breaker/isolator.
2	Security	Will transnet provide site security for the duration of construction and installation?	We have security on site , but as Per NEC , sceuring of site camp , materials on site , etc remains the responsibility of the bidder.
3	Tender	Does the two Effluent plants include the Fuel Depot?	There's only one effluent plant in the scope for Saldanha and does not include the fuel depot. The Diesel locomotive workshop effluent plant is covered in this project.
4	Environmental	Conduct EIA - We assume that this is outside of the scope of this tender?	Yes
5	Civil	Cleaning and commisioning - Does it inlcude waste disposal?	Yes
6	Mechanical	Can the old Effluent tanks, eqiupment be repurposed	If the question is reffering to the two tanks currently being used, then yes. If its reffering to de-commisioned tanks then no. With this being a capital project, we expect the lifespan of the asset to be renewed.