

SPECIFICATION FOR QUARANTINE PALISADE FENCE AND ROOF FOR THE QUARANTINE GENERATOR SHELTER

The palisade fence and roof will be 5m x 10m.

The Roof needs to cover the entire palisade fence

The roof will be IBR sheeting and will slope towards the ground.

Palisade fence to be bolted to poles for removal if needed.

Square tube pole 75 x75 height 4.5m

Palisade height 3.5m

Palisade double gate 3.5m

Apply primer on the palisade and IBR sheets before painting with hunter green paint.

All to be painted hunter green and galvanized IBR sheets.

Requirements

- Grade 2 CIDB registration
- Three traceable reference letters of the similar projects

Conditions

- Material used shall be of high standard (SABS approved)
- Works with poor workmanship will not be signed off
- The project should be completed within 2 weeks.
- Penalties for exceeding the allocated time will be incurred.
- All rubble to be removed by the contractor and no dumping on the property will be allowed.