

	MINUTES OF Q&A E3098GXMPGRO	Template Identifier	240-43921804	Rev	6
		Document Identifier	240-53463042	Rev	2
		Effective Date	01 January 2018		
		Review Date	March 2027		

The provision of cleaning the AWR dams, all Pollution Control Dams, Ash Dam Decanting systems, Oil skimmer operation & oil skimmer cleaning, Terminal Reservoirs cleaning at Grootvlei Power Station and cleaning of Clarifiers and sludge Dams at Vaal dam “as in when required”

Questions and Responses

No	Question	Response
1.	Drawings and Site Information Will drawings be provided for dams and drains?	Drawings exist but contain confidential information. They will be made available to the successful contractor when required
2.	Sludge Disposal and Pumping Can sludge be pumped between dams, and what alternatives exist?	• The preferred option is pumping sludge to the Ash Dam. • Where pumping is impractical, contractors may propose alternative disposal or hauling methods. • Site investigations are encouraged to determine the most practical solution
3.	Equipment Availability May equipment be hired through another company?	Yes. A Letter of Intent from the equipment provider will be accepted as proof of equipment availability.
4.	Experience References Can a combination of completion certificates and reference letters be submitted?	Yes. Both are considered acceptable proof of relevant experience.

Minutes Prepared By: [Nsukuzonke Buthelezi](#)

Meeting Type: Tender Clarification Meeting