
Meeting Title:

Supply and Delivery of Phase Conductors – Tender Clarification Meeting

Date:

08 April 2026

Time:

11:00 AM

Platform:

Microsoft Teams

Chairperson:

Ezile Pupane

Purpose of the Meeting

To provide clarification on the tender for the **Supply and Delivery of Phase Conductors** and address supplier queries prior to submission.

Tender Overview

- **Tender advertised:** 26 March 2026
 - **Closing date:** 16 April 2026 at 10:00 AM
 - **Validity period:** 120 days from closing date
 - **Submission platform:** Eskom E-Tendering website
 - **Tender type:** Open tender
 - **Scope:** Supply and delivery of phase conductors (single item in large quantities)
-

Key Tender Requirements**Submission Requirements**

- All submissions must be uploaded electronically under:
 - Technical
 - Commercial

- Financial
 - Quality
 - Documents must be submitted in **PDF format**
 - Pricing may be submitted within the NEC (Excel optional)
 - Late submissions will **not be accepted**
-

Mandatory Commercial Returnables

- Completed NEC3 Contract Data Part 2: provided by the contractor
- Completed NEC3 Offer and acceptance and priced BOQ
- All documents need to be submitted in a PDF format (The upload size per document is 500 megabytes and total submission is restricted to 4 gigabytes).

Tenderers who do not submit mandatory tender returnables as at stipulated deadlines will be disqualified.

Mandatory Technical Requirements:

The technical evaluation will be done in accordance with the requirements of the following:

- The technical evaluation will be conducted in accordance with the requirements, criteria and process as listed in **240-130900871 Technical evaluation standard for Overhead Phase Conductors and 240-152844641 Phase Conductor Standard for Eskom Overhead Lines.**

⚠ Failure to submit mandatory documents will result in **disqualification**

Evaluation Criteria

- **Price:** 80 points
 - **Specific Goals (BBBEE):** 20 points
 - Evaluation based on **PPPFA 80/20 principle**
 - Functionality criteria applicable
 - No reverse auction
-

Contractual Information

- Contract type: **NEC3 Supply Contract**
- Fixed pricing applies

- Delivery expected **as soon as possible** due to urgency
-

Questions and Responses

Insurance (COID)

- Business insurance covering liability is acceptable if COID is unavailable.

Correction: In the case where COIDA is not available, the requirement is an insurance cover, covering accidental death and disability of the value of R500 000 and above. (Sole Proprietor)

Delivery Responsibility

- Delivery may be:
 - Supplier-provided, or
 - Deliver By Rotran
- Must be clearly indicated in pricing

Pricing Structure

- Fixed pricing applies (no CPI adjustments)

Financial Requirements for New Companies

- Suppliers may still submit bids
- Financial compliance will be assessed at a later stage

Start Date

- Expected **as soon as possible** after award due to urgency

Product Specification Query

- Confirmed: ACSR Hare conductor specification is correct
 - Conductor, Electric: Material: Acsr Hare 14.16d Ungrs; Dimensions: Od 14.16 Mm; Type: Acsr; Structure: Stranded; Special Features: Steel Core; Ugr; Specification: Eskom 240-75521463; Potential: 132 Kv; Current: 360 A; Commercial Size: Hare; Strand Size: 4.72 Mm; Strand Quantity: (6) Al/(1) Stl; Strand Material: Al/Stl; Drawing No: D3136 Rev 1; Material: Al/Stl
-

General Notes

- No alternative tenders allowed
- No public tender opening

- All queries must be submitted **5 working days before closing date**
 - Questions & Responses will be published with the tender advert
-

Conclusion

- No further questions raised
 - Meeting adjourned
-

Prepared by:

Ezile Pupane

Date:

08 April 2026
