

	Tender Questions and Answers	Document Identifier	559-222407715	Rev	1
		Effective Date	July 2024		
		Review Date	July 2027		

To:ALL SUPPLIERS	Date	17 June 2025
	Enquiries	Candice Ratlhagane
	E-mail address	ratlhatc@ntcsa.co.za

Request for Enquiry Number	E1301NTCSAGP
Description / Project Title	The supply and delivery of DC Workshop Production Equipment
Tender Questions Closing Date	5 working days before the closing date of the tender

Item	Questions	Answers	Clarity Published Dates
1.	How many thermal cameras are you requesting	It is only one from DC workshop.	17/06/2025
2.	The LV, MV and HV corresponds to the VDC at 50VDC, 110VDC and 220VDC respectively for Battery Load Unit (Battery capacity test equipment). Which means that:		
3.	Item 9: UNIT: BATTERY LOAD BANK LV	50VDC Low Voltage	
4.	Item 10: UNIT: BATTERY LOAD BANK MV	110VDC Medium Voltage	
5.	Item 11: UNIT: BATTERY LOAD BANK HV	220VDC High Voltage	

Controlled Disclosure

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the system. No part of this document may be reproduced in any manner or form by third parties without the written consent of NTCSA SOC Ltd, © copyright NTCSA SOC Ltd, Reg No 2021/539129/30