



Invitation to Tender
Enquiry no : E1336GXMPMAT-R

ESKOM HOLDINGS SOC LTD

ADDENDUM 2: INVITATION TO TENDER

FOR

**PROVISION OF BOILER AND TURBINE AUXILIARY VALVES REFURBISHMENT FOR
THE PERIOD OF 5 YEARS ON AN AS AND WHEN REQUIRED BASIS AT MATLA
POWER STATION**

| No. | Query | Revised |
|------------|---|--|
| 1. | With respect to the accommodation please advise if this the accommodation for the team expected to carry out the work and if this is for the duration of the IR, MO and GO respectively. There is uncertainty as the UOM is No. and the QTY is 1. Is this for the 5 year period in total or per annum | <ul style="list-style-type: none">➤ Accommodation for IR – Spanner work is 7 days plus 3 days for commissioning.➤ Accommodation for MO – Spanner work is 30 days plus 3 days for commissioning.➤ Accommodation for GO – Spanner work is 45 days plus 3 days for commissioning. |
| 2. | With respect to the transport please advise if this is for the team travelling daily to site or only for the duration of the IR, MO and GO respectively. There is uncertainty as the UOM is No. and the QTY is 1. Is this for the 5 year period in total or per annum | <ul style="list-style-type: none">➤ Transport rate for travelling daily to work and return for the IR duration, MO duration and GO duration as per spanners days plus commissioning. |
| 3. | With respect to the rubber gates (NB250, NB300, NB150) please advise if this is the cost of rubberising the gate valves or if this refers to a component on a specific valve and which valves they are | <ul style="list-style-type: none">➤ It refers to rubberising the gate valves and coating them internally and externally. |
| 4. | With respect to the expansion pins/ shylock pins please advise if you are referring to sellock spring pins. Alternatively may you give a more detailed spec. | <ul style="list-style-type: none">➤ Correct, Sellock spring pins are the correct components we are looking for. |
| 5 | Please may you assist with a spec for the rubber seals on the butterfly valves. Alternatively may you assist with the valve make, model number and/or type of butterfly valves. | <ul style="list-style-type: none">➤ These are Ainsworth butterfly valves (NB400 and NB600) |



Invitation to Tender
Enquiry no : E1336GXMPMAT-R

| | | |
|-----------|--|---|
| 6. | With respect to the bill of materials. For items not in the NEC are we supposed to incorporate the price of the soft spares in the cost of the valve refurbishment for the valve, e.g. the rubber seals for the butterfly valves | ➤ Yes, the soft spares not on the bill of material should be included on the cost of valve refurbishment for the valve. |
|-----------|--|---|

Yours faithfully

Signature
Stanley Ngwenya
Manager Procurement

Date: 08/08/2025