



CONDUCTOR AND HARDWARE SCHEDULE		BAY DESIGNATION	
		SIZE	QUANTITY
CONDUCTOR	BUSBAR	φ 250 AL TUBE	-
	STRINGER AND DROPPER	3x800mm <sup>2</sup>	-360- m
	EQUIPMENT EARTHING	50x3 Cu	- m

  

CLAMPS AND HARDWARE TO DRG No 0.54/412	DESCRIPTION	MK	ITEM	QUANTITY
	φ 250 TUBE TO 3 x 800mm <sup>2</sup> TWISTED	1	TBTC-250/C3-38 TWISTED	6
	SPACER	2	-S5	60
	CLAMPS	3	-3Y4	12
		4		
		5		
6				

FOUNDATION		A
FOUNDATION DRG No 0.54/		4358
EQUIPMENT		POST INS
EQUIPMENT RATING	AMPS	--
	kA	--
EQUIPMENT STEM/PAD SIZE		127 PCD
MAKER		PPC
OUTLINE DRG No 0.54/		8314
ORDER NUMBER		13289
CONTRACT NUMBER		4501243396
STEELWORK DRG No 0.54/	SUPPORT	303
	CAP	703

**FINAL DESIGN FOR CONSTRUCTION**

ORIGINAL DRG #: N/A  
 CONCEPT DRG #: N/A  
 DETAIL DRG #: MOO21P05-SE-D16-18 REV 0

0	FIRST ISSUE. DECOMMISSIONED.				28/08/2025
REV	REVISION DESCRIPTION	BY	CHKD	AUTH	DATE
		<b>ESKOM HOLDINGS LIMITED</b> REG No 2002/015527/30			
<b>MOOKODI</b> 400kV TRFR 12 BUSBAR INTERTIE					
© Moo21P05-SE-E13		SHEET NUMBER	REVISION		
		18	0		