

Responses to the queries Questioned

1. I have an enquiry about the Trade Test qualification for the Site Supervisor and Artisan; would an Electrician Trade Test be acceptable for the two personnels? Please do advise on the matter.

Ans: The requirement for a site supervisor and the artisan is as per the tender document. Alternative qualifications for these resources will not be considered and will lead to points being lost for the incorrect qualification provided.

2. Please can you share a copy of Annex K as revert to in the NEC for the above-mentioned tender.

Item no.	Activity Description	Frequency	Quantity (per Year)	Amount (per single item)	Total (per Year)
Preliminary and General					
1	Airport permits and parking fees – provisional sum	Once off	1	R 5000.00	R 5000.00
2	Contract Management and administration	Monthly	12		
3	Insurance (ACSA required for this contract)	Monthly	12		
4	Store supervision and Monthly reports	Monthly	12		
5	PPE and Cell Phone	Monthly	12		
Total Preliminary & General					R
Maintenance & Inspections					
6	Fire Water Pump Station Preventative Maintenance as Per Annex K	Monthly	12		
7	Fire Sprinkler System Preventative Maintenance as Per Annex I by a ASIB approved service provider	Monthly	12		
8	Fire Hose Reels Preventative Maintenance as per Annex I by a ASIB approved service provider	Monthly	12		
9	Fire Hydrants Preventative Maintenance as per Annex I by a ASIB approved service provider	Monthly	12		
10	6h Diesel Full load Engine test run by a ASIB approved service provider	Quarterly	4		
Total Maintenance & Inspections					R
Total	Sub-total A (Total Preliminary & General + Total Maintenance & Inspections)				R

**The above activity schedule is minimum work required and the contractor as the subject expect matter on these services they are bidding for shall fill in any other activity with prices for "other" activities which they deem necessary to achieve the set out comes on availability ,reliability, maintainability, MTTR, MTBF, legislative and all other targets set in this contract. Should an alternative not be presented, the offer will be deemed as the contractor's optimal proposal for which they will be liable for.*

****All rates for all activities including diagnostic and repair shall include all required tools, software, hardware and consumables (including all applicable specialized tools and software, hardware and consumables) Onus is on the contractor to price correctly).**

*****It is noted that the required labour resources and skills for this contract is not prescribed in detail. The contractor is fully responsible to ensure that labour resources remain adequate and competent in order to maintain required service levels, system performance levels and according to all applicable laws and regulations. The Tenderer shall also ensure that all required maintenance is catered for as per the Original Equipment Manufacturer in the pricing above.**

******Low service damages will be applicable as per the Low service damages table in this contract**

Price list

C2.2 page 1

Ans: There is a mistake in the current BOQ or contract. The correct annex is Annex I of the updated attached contract which is also uploaded as addendum 1 on eTenders.