

ENGINEERING SERVICES DEPARTMENT



PLATE HEAT EXCHANGER H1603 SPECIFICATION SHEET

Project	NW PlasGas and WOPG	Unit Tag Number	H1603
Datasheet Document No.	ENS-NWPVR-SPE-24023	Revision	3
Description	Heat exchanger H1603 cools primary cooling water returning from users in the NW PlasGas Facility and the WOPG Facility. This is a plate exchanger, in which primary cooling water is contacted with secondary cooling water from cooling tower T1604, before it is returned to the primary cooling water tank, T1601.		
Plant Location	Merged NW PlasGas Demonstration Facility and WOPG Facility ^{Note 1}		
Equipment Location	At the cooling tower T1604 (outside Building V-H2, Laboratory 150)		
Safety Classification	Non-classified(N) and SC-3 (C)		
Quality Classification	Non-classified(N) and QC-3 (C)		
Duty	207,85 kW ^{[1], Note 2}		

FLOW MEDIA

	UNITS	HOT MEDIUM		COLD MEDIUM	
		NW PlasGas	WOPG	NW PlasGas	WOPG
Media		Demineralised water		Process water	
Inlet temperature	°C	40 ^[1]		25 ^[1]	
Outlet temperature	°C	30 ^[1]		35 ^[1]	
Design temperature	°C	100		100	
Flow rate	kg/s	4,97	4,67 ^[3]	4,97	4,67 ^[3]
Maximum operating pressure	kPa(g)	600		600	
Permissible pressure drop	kPa	70		70	
Calculated pressure drop	kPa	Supplier to advise		Supplier to advise	
Design pressure	kPa	2000		2000	

FLUID PROPERTIES (at average temperature)

Density	kg/m ³	994 ^[2]	997 ^[2]
Specific heat capacity	kJ/kg.K	4,18 ^[2]	4,18 ^[2]
Thermal conductivity	W/m.K	0,622 ^[2]	0,614 ^[2]
Viscosity	kg/m.s	7,2E-04 ^[2]	7,64E-04 ^[2]
Corrosive		No	No
Erosive		No	No
Abrasive		No	No
Toxic		No	No
Presence of solids		No	No
Presence of uranic material		No	No

DESIGN DATA

Plate heat exchanger type		Supplier to advise
Design duty (calculated)	kW	Supplier to advise
Frame type		Supplier to advise
Frame size (height, width, thickness)	mm	Supplier to advise
Number of plates		Supplier to advise
Maximum number of plates allowed		Supplier to advise
Total active heat transfer area	m ²	Supplier to advise
Nominal plate gap	mm	Supplier to advise
Flow arrangement		Supplier to advise
Packed size	mm	Supplier to advise
Mass of empty unit	kg	Supplier to advise
Volume of fluid in exchanger	m ³	Supplier to advise

MECHANICAL PROPERTIES

Process connections	Pipe size	50NB, Sch 40	Pipe size	50NB, Sch 40
	Type	Raised Flanged (RF); 150 lb	Type	Raised Flanged (RF); 150 lb
	Material	304L Stainless Steel	Material	304L Stainless Steel
Material of construction	Casing	Carbon Steel	Plates	304L Stainless Steel
Surface finish	Casing	Supplier to advise	Plates	Supplier to advise
Surface protection	Casing	Supplier to advise	Plates	Supplier to advise
Corrosion allowance	Casing	0.00"	Plates	0.00"
Pressure rating	Casing	150 lb	Plates	150 lb

RESTRICTED

ENGINEERING SERVICES DEPARTMENT



PLATE HEAT EXCHANGER H1603 SPECIFICATION SHEET

Project	NW PlasGas and WOPG	Unit Tag Number	H1603
Datasheet Document No.	ENS-NWPVR-SPE-24023	Revision	3

SITE CONDITIONS

Altitude	m	1300
Site location		Pelindaba East, H-Building
Atmospheric pressure	kPa(a)	Min: 87,4 kPa: Max: 88,3 kPa
Ambient Temperature (min./max)	°C	Min: 2°C: Max: 32°C

REFERENCE DRAWINGS AND DOCUMENTS

- [1] ENS-NWPVR-CLC-24012: Energy Balance Calculations for NW PlasGas Demonstration Facility
- [2] www.engineeringtoolbox.com
- [3] ENS-OWPVR-CLC-24002: Mass & Energy Balance Calculations for the Basic Engineering Design of the Uranium Contaminated Waste Oil Plasma Gasification Project

NOTES

- Note 1: The NW PlasGas and WOPG facilities will not be operated simultaneously. Therefore this heat exchanger will only be servicing one of the facilities at a time.
- Note 2: The duty for the NW PlasGas facility is the enveloping duty. The duty for WOPG is lower (195,09 kW [3]).
- Note 3: The heat exchanger shall be fully drainable in situ, with the drainage mechanism normally closed.

	Name	Signature	Date
Compiled by	M Correia (Senior Process Engineer)		
Checked by	B Khumalo (Senior Process Engineer)		
Checked by	W Ludwick (Senior Process Engineer)		
Checked by	SM Mngoma (Chief Mechanical Engineer)		
Checked by	G Manuel (Chief C&I Engineer)		
Checked by	W van den Berg (Chief Electrical Engineer)		
Approved by	K Moodley (Chief Process Engineer)		