

Annexure C3.2

SCOPE OF WORK

Important to note – the successful supplier must submit a safety file and attend induction before the work commences

DESCRIPTION OF THE WORKS

Supply, deliver and installation submersible pumps at Rand Water Zuikerbosch

4 Inch submersible pumps for filter house No. 1

Discharge diameter = 102mm (4 inches)

The pumps should also be able to drain excavation water as well as slurry solutions

Maximum pump weight restricted to 80kg stainless steel material

Suction head = minimum 40 meters

Capacity = 2 -2.5 kilo litres per second

Cable = 100 meters

The pumps should also include starter boxes per pump, voltage = 3 phase (380V to 400V) Frequency = 50Hz

3 x 100 meter of 102mm diameter layflat pipe rolls

3 x 30 meter of 102mm diameter heliflex pipe rolls



SITE INFORMATION

Non Compulsory Site Briefing 21.06.2023 @ 09:00

We will meet at Rand Water Zuikerbosch, Risk Control Parking Area –

Vischgat Road, Three Rivers East, Vereeniging

S26 41 520 E28 00 061

Please bring along your ID for access purposes and wear safety shoes. You will not be allowed to enter the plant without safety shoes