

Specifications - M - Drainage			
Key Value		Keynote Text	
M1: General drainage		Sewage uPVC waste water pipes and fittings to SABS 791. uPVC soil waste and vent pipes to SABS 697. Lay pipes to SABS 1200i,d, and SABS 112. Minimum invert level must be no less than 450mm below the finished ground level. All sewage pipes under structures must be encased in concrete. All soil and waste fittings to be accessible along their entire length. Ovp's to be carried up to 1800mm above and opening within 6m thereof. All sanitary fixtures to have self-cleaning traps. Vent valves to all waste fittings.	
DRAWING TITLE		CLIENT NAME	
SPECIFICATIONS - DRAINAGE		CITY OF MBOMBELA	
PROJECT TITLE		Sheet Issue Date	Current Rev. Date
THEKWANE SPORT FIELD - GATE HOUSE		2023/09/15	2023/09/15
		Drawn by	
		FB DDK	
		Project No.	Current Rev. No
		N23-23	0
		Status	
		T	
		Drawing No.	
		AR-9012	