

VAT REG NO: 4740101508

RFQ Collective number

E1959DXWC

Contact person

XOLISWA JEANETTE MNINZI

Your person responsible/Your reference

Your vendor number with us

Quotation deadl.: 27.10.2025

Delivery date: Day 07.04.2026

Invitation to Tender

Eskom Holdings SOC Ltd (hereinafter #Eskom”) invites you to submit a tender for:
THE SUPPLY AND DELIVERY OF VARIOUS STOCK ITEMS FOR CAPE COASTAL
CLUSTER-WESTERN CAPE

The tender documents are supplied to you on the following basis:

1. Free of charge

Eskom has delegated the management of this Invitation to Tender to the Eskom Representative whose name and contact details are set out in the Tender Data. The submission of a tender/proposal by you in response to this Invitation to Tender will be deemed as your acceptance of the Eskom Standard Conditions of Tender which may be accessed at www.eskom.co.za.

All queries and clarifications relating to the Invitation to Tender documents must be addressed in writing to the Eskom Representative. No query or clarification may be addressed to any Eskom official other than the Eskom Representative.

ERROR: No office address maintained

SA

Tel 0219415862 Fax

Item	Material	Description	Unit	Deliv. date
RFQ quantity				
00010	0186926	CABLE,ELECT:JXA1WAQ 66KV 1C;AL;500 MM2	m	
6,000		CABLE, ELECTRICAL: VOLTAGE: 66 KVAC; CORE QUANTITY: 1; CONDUCTOR MATERIAL: ALUMINIUM; CONDUCTOR SIZE: 500 MM2; DESIGN TYPE: STRANDED; SHEATH MATERIAL: POLYETHELENE; TYPE: JXA1WAQ; CONDUCTOR: 1 AL STRANDED; COVERING: SHEATH AL CORRUGATED SEAMLESS; RATING: 66 KV AC; SPECIFICATION: ESKOM DSP 34-1625; TEST/CERTIFICATION SANS 60840; CONDUCTOR INSULATION: XLPE; DRAWING NO: D8070 REV 1; REFERENCE NO: JXA1WAQ; POLYETHELENE OUTER SHEATH WITH GRAPHITE COATING; IDENTIFICATION: INDELIBLE MNFRS TRADEMARK AND PART NO.ON ALL ITEMS AND CABLE DRUM STAMPED/MARKED		

Brackenfell Maintenance
Eskom Road,
Brackenfell.
7560

00020	0582355	SWITCH DSCNNCT:REMOVE, CSTL;22 KV;630 A	each	
500		SWITCH, DISCONNECT: TYPE: REMOVE, CSTL; POTENTIAL: 22 KV; CURRENT: 630 A; ACTION: PULL TO OPEN; PUSH TO CLOSE; APPLICATION: SINGLE PHASE LINE OFFLOAD; SPECIFICATION: CORROSION SANS 121; BS 2816; DPC 34-216; ESKOM 240-68973356; STD IEC/SANS 60815/61230/62271-1/62271-102; DRAWING NO: D3087 REV 0; DISCONNECTOR; REMOVABLE SWITCHBLADE; LINK STICK OPERATED; RATED VOLTAGE: 24KV; RATED SHORT-TIME (3S) CURRENT: 12.5KA; BIL - TERMINAL TO EARTHED FIXING STEM: 150KV; MINIMUM CREEPAGE: 31MM/KV; COMPLETE WITH: PULL-TO OPEN AND PUSH-TO-CLOSE LEVER AND EARTHING PIN; FOR APPLICATION ON 11KV AND 22KV NETWORKS IN CORROSIVE ENVIRONMENTS; IDENTIFICATION: INDELIBLE MNFRS TRADEMARK AND PART NUMBER ON ALL ITEMS		

Brackenfell Maintenance
Eskom Road,
Brackenfell.
7560

00030	0582355	SWITCH DSCNNCT:REMOVE, CSTL;22 KV;630 A	each	
500		SWITCH, DISCONNECT: TYPE: REMOVE, CSTL; POTENTIAL: 22 KV; CURRENT: 630 A; ACTION: PULL TO OPEN; PUSH TO CLOSE; APPLICATION: SINGLE PHASE LINE OFFLOAD; SPECIFICATION: CORROSION SANS 121; BS 2816; DPC 34-216; ESKOM 240-68973356; STD IEC/SANS 60815/61230/62271-1/62271-102; DRAWING NO: D3087 REV 0; DISCONNECTOR; REMOVABLE SWITCHBLADE; LINK STICK OPERATED; RATED VOLTAGE: 24KV; RATED		

Item	Material	Description	Deliv. date
RFQ quantity	Unit		

SHORT-TIME (3S) CURRENT: 12.5KA; BIL - TERMINAL TO EARTHED FIXING STEM: 150KV; MINIMUM CREEPAGE: 31MM/KV; COMPLETE WITH: PULL-TO OPEN AND PUSH-TO-CLOSE LEVER AND EARTHING PIN; FOR APPLICATION ON 11KV AND 22KV NETWORKS IN CORROSIVE ENVIRONMENTS; IDENTIFICATION: INDELIBLE MNFRS TRADEMARK AND PART NUMBER ON ALL ITEMS

Brackenfell Maintenance
Eskom Road,
Brackenfell.
7560

00040 0714247 BUSHING:RIP PAPERLESS;1000 A;450 KVAC;96

27 each

BUSHING: TYPE: RIP PAPERLESS; CURRENT: 1000 A; BASIC INSULATION LEVEL: 450 KVAC; CURRENT TRANSFORMER EXTENSION DIAMETER: 96 MM; CURRENT TRANSFORMER EXTENSION: 300 MM; OIL EXTENSION: 540 MM; FLANGE DIAMETER: 225 MM; MOUNTING HOLES: (6) DIA 16 MM; PITCH CIRCLE DIAMETER: 185 MM; STEM DIAMETER: 26 MM; OUTSIDE DIAMETER: 96 MM; SPECIFICATION: 240-56062799; VOLTAGE: 72.5 VOLT ALTERNATING CURRENT

Brackenfell Maintenance
Eskom Road,
Brackenfell.
7560

00050 0400641 CABLE ELECT:1 KV;4C;CU;70 MM2;STL WIRE

1,200 m

CABLE, ELECTRICAL: VOLTAGE: 1 KV; CORE QUANTITY: 4C; CONDUCTOR MATERIAL: CU; CONDUCTOR SIZE: 70 MM2; ARMOR: STL WIRE; DESIGN TYPE: BVX4NCV; COVERING: PVC OUTER SHEATH; RATING: 0.6/1 KV AC; SPECIFICATION: ESKOM: 240-56063805; STD SANS 1507; TEST/CERTIFICATION SANS 1507; CONDUCTOR INSULATION: PVC; DRAWING NO: D3128 REV 1; 4 CORE STRANDED COPPER CONDUCTOR; 300M DRUM; IDENTIFICATION: INDELIBLE MNFRS. TRADEMARK & PART NO. ON ALL ITEMS AND DRUM TO BE STAMPED/MARKED

Item	Material	Description	Deliv. date
	RFQ quantity	Unit	
Brackenfell Majors Capital Eskom Road, Brackenfell. 7560			
00060	0578950	CABLE,ELECT:EUX3UAQ 11KV 3C;AL;300 MM2	
	9,000	m	
CABLE, ELECTRICAL: VOLTAGE: 11 KV; CORE QUANTITY: 3C; CONDUCTOR MATERIAL: ALUMINIUM; CONDUCTOR SIZE: 300 MM2; ARMOR: GALVANISED STEEL WIRE; DESIGN TYPE: EUX3UAQ; TYPE: A; COVERING: PE OUTER SHEATH; RATING: 6.35/11 KV AC; SPECIFICATION: ESKOM 240-56063792; STD SANS 1339; TEST/CERTIFICATION SANS 1339; CONDUCTOR INSULATION: XLPE; DRAWING NO: D-DT-8001 REV 0; 3 CORE STRANDED ALUMINIUM CONDUCTOR; PVC BEDDING; PE SERVING; DRUM = 300 M			

Brackenfell Majors Capital
Eskom Road,
Brackenfell.
7560