REQUEST FOR INFORMATION FOR GOODS AND SERVICES





ONDERSTEPOORT BIOLOGICAL PRODUCTS LTD PRIVATE BAG X7, ONDERSTEPOORT 0110

From: Supply Chain Department

Date: 04 December 2025 - 15 January 2026

Tel: 012 522 1500

Fax: N/A

Email: purchasing@obpvaccines.co.za

To: Supplier: Tel: Fax: Email:

REQUEST FOR INFORMATION - FOR SALES AGENTS FOR OBP

Kindly provide Information for the following: RFI /OBP 003/2025/26

COMPULSORY/MANDATORY	
Company/ Individual Profile	 That highlights years' relevant experience and capabilities in the animal pharmaceutical environment, A list of geographical location where your business focus is, and a list of customers / clients. Indicate agent/s relevant experience and their languages proficient
Proposal	Detailed proposal to include pricing, methodology and approach etc.
Additional Notes	All Bidders must be registered on CSD (Central Supplier Database)
Compulsory Site briefing 11 December 2025 @10:00	Compulsory site briefing to be attend, at OBP Offices (100 Old Soutpan Road, Onderstepoort, 0110). Must be there before or on time as stipulated on the document and wear PPE clothing before entering the premises. 11 December 2025 @10:00

DOC NO.: PM-ME-002-F001 (EDITION 05) Page 1 of 1

TERMS OF REFERENCE

To request information for Fire Protection Systems Upgrade at Onderstepoort Biological Products (OBP)

Business Background

OBP is a manufacturer of animal vaccines. These products are sold within domestic market mainly to coops, feedlots, wholesalers, veterinarians, and pharmacies. The company has further segmented its market according to provinces, with each province having various distribution points. Most of these distribution points are mainly in rural areas dominated by cattle, sheep, and goat farmers.

Objective

OBP intends to request information for Fire Protection Systems Upgrade.

Mandatory Requirements to take into consideration

- Testing of the existing fire water supply for flow and pressure in accordance with NFPA 25, SANS 10400-T, and SANS 10252, recording static and residual pressures and flow rates, and submit a formal report.
- Safely decommission the old sprinkler system, remove non-compliant components, and restore affected areas.
- A competent ECSA-registered fire engineer shall design new sprinkler, hydrant, water storage, and pumping systems per NFPA, SANS, and FM Global/ASIB standards, with approval prior to installation.
- Installation includes wet-pipe sprinklers (Ordinary Hazard), hydrant reticulation, a 434,160 L water tank, two diesel fire pumps, valves, alarms, and controls, integrated with the site fire alarm/BMS.
 Electrical works, hydrostatic and performance testing, commissioning, and certification are required.

Additional Requirements or Considerations

All proposed designs and services must comply with, but not be limited to, the following standards:

- NFPA 13
- NFPA 20
- NFPA 25
- SANS 10400-T
- SANS 10252
- Applicable local municipal by-laws

DOC NO.: PM-ME-002-F001 (EDITION 05) Page 2 of 1