

	Scope of Work – Marathon Transformer No 1 and No 2 bucholz supply North-East Grid Transmission	Template Identifier	240-43921804	Rev	5
		Document Identifier	SOW-PGSS	Rev	0
		Effective Date	20 February 2014		
		Review Date	February 2023		

1. Introduction

Transformer No 1 tripped on numerous occasions and according to the Specialist Sidwell Mtetwa the problematic bucholts relays needs replacement.

2. Scope of work/supply

Supply and deliver 4 bucholz relays to Marathon Substation North East Grid.

Bucholz relays Procurement

- Source as per “240-56063908 OIL AND GAS ACTUATED (BUCHHOLZ) RELAYS FITTED TO TRANSFORMERS AND REACTORS SPECIFICATION”

Compiled by 
Quinten Nepgen
Senior Advisor: North East Grid
Eskom

Approved by: 
Mbali Mapaila
HV Plant Manager: North-East Grid
Eskom