




James Pahl
1341421

4. TECHNICAL EVALUATION CRITERIA

Functionality Threshold Evaluation (Technical = 80%)


- Evaluate submission against functionality criteria
- Rate submission against each criteria
- Apply the penalty system and calculate total functionality score
- Eliminate if supplier is below minimum qualifying threshold of 80%

Item	Description	Weight	Score
1	Confirmation that conductor Eskom approved ACSR conductor (19 steel wires and 54 Aluminum wires)	20	
2	Conductor to have a Amp rating of 1110 amps (test result supplied)	20	
3	Conductor to have a minimum UTS (ultimate tensile test)rating of 203 kN (test result supplied)	30	
4	Confirmation that conductors on drum lengths of 2000m	20	
5	Confirmation that delivery is done on site (Trucks including crane) for own off load on site	10	
	TOTAL	100	



Acting Portfolio Manager

Name John Tshabalala



Quantity Surveyor

Name Kevin Muirhead