

## ADDENDUM No. 3

**Date:** 28.02.2024

**Ref:** Addendum 3

**Enquiries:** Thabile Sibiya

**Email:** sibiyaTh@eskom.co.za

To whom it may concern

**RE: KZN113**

**The Manufacture, Test and Supply of various Medium and Low Voltage Cable Accessories on an “as and when” required basis for various Regional Distribution Centres located in the Central East Cluster (KwaZulu Natal and Free State Operating Units) over a period of thirty-six (36) months. Rotek will be responsible for transportation of the goods.**

The following changes have been made to the tender enquiry KZN113:

| Description             | Current Description   | Revised Description   |
|-------------------------|---|---|
| <b>Correction 1</b>     | Eskom standard 240-56030619 clause 3.1.2.4 states:” Unscreened separable connectors (USCs)<br>a) Unscreened separable connectors (USCs) for indoor terminations shall be supplied with a stainless steel or brass M16 x 2 pitch x 35 mm long set screw, spring washer and washer (3 off per set). See Figure 1. | The set screw standard details shall be M16 x 2 pitch x 40 mm long. Not 35mm long.  |
| <b>Correction 2</b>     | The requirement of stating the method of waterblocking used for main primary earth braids in terminations and joints was omitted in the technical schedules.  | Please can tenderers submit a letter stating the method of waterblocking used on main primary earth braids. This is excluding the 2500mm trifurcating primary earth braid that has its own specific requirements. |
| <b>Clarification</b>    | Screened separable connector kits shall come supplied with stainless steel fixing stems that will fit into type C bushings with M16x2 thread as per SANS 1332. The fixing stem should accommodate a M16 mechanical torques shear lug with a suitable palm hole for fixing stem.                                 |   |
| <b>Technical folder</b> | It must be noted that the original Technical Folder uploaded on 13.12.2023 did not contain all the necessary documentation, the Technical Folder was uploaded again on 26 February 2024 which should contain a total of 36 documents (TEC, SCHEDULES, STANDARDS, SPECS ETC).                                    |   |



The closing date remains 12 April 2024, 10h00 and the closing date for queries is 05 April 2024. (5 days before closing date).

No late tenders will be accepted.

Yours faithfully,

A handwritten signature in black ink, appearing to read "Thandi Xaba", positioned above a horizontal line.

---

**Name: Thandi Xaba**

**Designation: Acting Procurement Manager – KZN OU (CEC KZN5438)**