



SCHEDULE OF EQUIPMENT BASES 88kV REV.0 (2020)			
TYPE	No OFF	DRG No 0.54/	REMARKS
CIRCUIT BREAKER	2	0.54/4358	FOR LAYOUT OF THESE BASES REFER TO EQUIP SCHEDULE WAT16P02-SE-D16
CIRCUIT BREAKER	3	33558	
ISOLATOR	4	0.54/4358	
ISOLATOR	29	0.54/10116	
MED. EQUIP. SUPPORT (CT)	24	33556	
MED. EQUIP. SUPPORT (CT)	6	0.54/4358	
MED. EQUIP. SUPPORT (PI)	3	0.54/308	
JUNCTION BOX	13	0.54/4713 SHT.1	

SCHEDULE OF EQUIPMENT BASES 275kV REV.0 (2020)			
TYPE	No OFF	DRG No 0.54/	REMARKS
CIRCUIT BREAKER	3	0.54/4358	FOR LAYOUT OF THESE BASES REFER TO EQUIP SCHEDULE WAT16P02-SE-D16
ISOLATOR	27	33559	
ISOLATOR	18	0.54/4358	
MED. EQUIP. SUPPORT (CT)	6	33556	
ISOLATOR PG	6	0.54/5829	
MED. EQUIP. SUPPORT (SA)	3	33556	
JUNCTION BOX	6	0.54/4713 SHT.1	
MED. EQUIP. SUPPORT (PI)	17	0.54/4358	
MED. EQUIP. SUPPORT (CT)	3	0.54/4358	
MED. EQUIP. SUPPORT (SA)	3	0.54/4358	
MED. EQUIP. SUPPORT (CVT)	3	0.54/4358	
LABEL SUPPORT	1	0.54/401	
FIRE BARRIER	3	0.54/4169	

SCHEDULE OF EQUIPMENT BASES FOR 275kV FEEDER 1			
#	TYPE	No OFF	DRG No 0.54/
ISOLATOR		3	771
CIRCUIT BREAKER		1	4399
MED. EQUIP. SUPPORT		12	4358
JUNCTION BOX		1	4713
LABEL SUPPORT		1	401

SCHEDULE OF MAIN BASES 275kV YARD REV.16 (2014)					
ITEM	MARK	TYPE	No OFF	DRG No 0.54/	REMARKS
COLUMN	C236 & C237	OC3	2	4473	TO BE AT SAME LVL AS EXIST C211
	C238 - C243	OC1	5	4473	
	C239 #	SPECIAL	1	0.18/	

SCHEDULE OF EQUIPMENT BASES 275kV REV.16 (2014)					
TYPE	No OFF	DRG No 0.54/	REMARKS		
CIRCUIT BREAKER (3x3Φ)	9	8280	FOR LAYOUT OF THESE BASES REFER TO EQUIP SCHEDULE 0.18/14126 SHT. 4, 6 & 9		
ISOLATOR (5x3Φ) *	15	7514			
PG ISOLATOR (3x1Φ)	3	5829			
MED. EQUIP. SUPPORT (PI)	6	5829			
EARTH SWITCH (1x3Φ) *	3	6432	* FONS GROUPED SEE NOTE 11		
MED. EQUIP. SUPPORT	24	4358			
JUNCTION BOX	3	4713 SHT.1			
LABEL SUPPORT	4	401			

SCHEDULE OF MAIN BASES 88kV YARD REV.16 (2014)					
ITEM	MARK	TYPE	No OFF	DRG No 0.54/	REMARKS
COLUMN	C147	88/H	1	5612	

SCHEDULE OF EQUIPMENT BASES 88kV REV.16 (2014)					
TYPE	No OFF	DRG No 0.54/	REMARKS		
CIRCUIT BREAKER	1	7511	FOR LAYOUT OF THESE BASES REFER TO EQUIP SCHEDULE 0.18/14126 SHT. 37		
ISOLATOR	2	7512			
EARTH SWITCH	1	8293			
MED. EQUIP. SUPPORT	3	4358			
JUNCTION BOX	1	4713 SHT.1			
LABEL SUPPORT	1	401			

SCHEDULE OF MAIN BASES 275kV YARD (STAGE 1985)					
ITEM	MARK	TYPE	No. OFF	DRG No 0.54/	REMARKS
COLUMN	C201, C202		2		5.79m
	C203, C206		2		5.68m
	C208, C224		2		5.81m
	C211, C227	LIGHT	2	352	5.62m
	C229, C231		2		5.63m
	C232, C233		2		5.52m
	C234, C235		2		5.34m
	C207, C209		9		5.81m
	C213-C217		5		5.62m
	C210, C212	HEAVY	9	351	5.62m
TRFR. PLINTH	T11		1	0.18/15094	5.24m
	T12		1	0.18/14096	5.41m
TRFR. OFF LOADING PLATFORM	T13		1		5.48m

SCHEDULE OF BUSBAR SUPPORT 275kV BYPASS				
ITEM	MARK	No OFF	DRG No 0.54/	REMARKS
BUSBAR SUPPORT	BS1 - BS21	21	4169	FOR LAYOUT REFER TO DRG WAT16P02-SE-D12

**DETAIL DESIGN**  
**NOT FOR CONSTRUCTION**  
ORIGINAL DWG # 0.18/14129 REV 16  
CONCEPT DWG R N/A

SCHEDULE 'A' OF EQUIPMENT BASES FOR 132kV FEEDER 5 (2009)			
#	TYPE	No OFF	DRG No 0.54/
ISOLATOR		2	483
CIRCUIT BREAKER		1	6493
MED. EQUIP. SUPPORT (CT, VT & SA)		2	4358
JUNCTION BOX		1	4713

SCHEDULE OF EQUIPMENT BASES FOR 132kV FEEDER 6 (2000)			
#	TYPE	No OFF	DRG No 0.54/
ISOLATOR		2	465
CIRCUIT BREAKER		1	3898
MED. EQUIP. SUPPORT (CT, VT & SA)		9	4358
JUNCTION BOX		1	4713
CABLE TRENCH RAMP		1	390 DTL.37 & 37A

SCHEDULE OF MAIN BASES FOR 132kV YARD.				
MARK	#	TYPE	No OFF	DRG No 0.54/
C76, C78, C79, C81, C82 & C83	RC4	6		4316
C77	RC2	1		
C80	RC1	1		

NOTE :  
# THESE FOUNDATIONS WILL BE REMOVED DURING THE CONSTRUCTION OF THE NEW 132kV YARD.

SCHEDULE OF EQUIPMENT BASES 132kV REV.0 (2020)			
TYPE	No OFF	DRG No 0.54/	REMARKS
CIRCUIT BREAKER	2	4358	FOR LAYOUT OF THESE BASES REFER TO EQUIP SCHEDULE WAT16P02-SE-D16
PG ISOLATOR	6	4358	
MED. EQUIP. SUPPORT (PI)	6	4358	
MED. EQUIP. SUPPORT (CT)	3	4358	
JUNCTION BOX	1	4713 SHT.1	