













		W2739.999LEEDING	
		W2733.33261200KRONA SUPERWEED CEILING TILES	
		CEILING HEIGHT = 2400MM	
		W2733.3326CONCRETE COFFER SLAB CEILING	
		SOPFH HEIGHT (TOP TO TOP) = 2150MM	
		HVAC	
		WATER SUPPLY/SPRINKLER SYSTEM	
		SEWER	
		W2733.3326ELECTICAL	
		W2733.3326STORMWATER	

LIST OF LUMINAIRS

TYPE (AND GENERAL ELECTRICAL SYMBOLS)

~~_____~~ Distribution Board

CD		25W Round Surface Light Head on Drowox in Ceiling Collar Structure
F5		50W 1200x600mm LED CEILING RECESS
A		MOUNT FLAT PANEL
A7		25W Round Surface Ceiling mounted Utility IP65 Blurred light fitting
SH		1P65 UVAL Blurred light fitting
D		25W Shurtie up and Down Surface light mounted light fitting
D2		13W ECLSD Surface light fitting wall mounted light fitting
P1		5W Dimmable Surface Downlighter in Flush mounted enclosure
OS		2 x 50W LED 6 Metre High Pole Light fittings on 75mm diameter pole
OS		Daylight Switch
OS		15A Light Switch Single Lever on/off, 2way
CD		200mm Circuit Identification Essential Light Circuit Number LL and from DBPL

NOTE: Light connected direct to live

CHANGES ON DRAWINGS HAVE TAKEN INTO ACCOUNT ALL THE RECORDED CHANGES AS INDICATED ABOVE.

F1 Fire Detector Device

HEALTH DEPARTMENT SIGNATURES	
FACILITY STAMP	
FACILITY MANAGER	
INFRASTRUCTURE MANAGER	
GENERAL MANAGER	
CHECKED BY PROFESSIONAL CONSULTANT	
Name	Tithani NMI
Signature	TJNMI
Date	30 September 2023

CONSULTING ENGINEERS

T J NEL

CONSULTING ELECTRICAL ENGINEERS

P O BOX 169
PORT EDWARD
4295

CELL: 083 - 2659623

TJ

public works

Department:
Public Works

PROVINCE OF KWAZULU-NATAL

SOUTHERN REGION

Project: WIMS, PORT
 ID: 044044: SOUTHERN REGION
 SHEPSTONE DEPARTMENT OF HEALTH
 PORT SHEPSTONE HOSPITAL
 NEW PSYCHIATRIC WARD

Drawing Description	
PARKING LEVEL LIGHTING LAYOUT DRAWING	
Drawn: T.M.	Date: 16 AUG 2004
Scale: 1" = 500'	Revised: 12-2-04
Consultants Drawing number	
SL 231 - EL3	
DDPP Drawing number	
Stamped by: Pines Approval Committee	