



INQUIRIES AND RESPONSES - E2960DXGOU

INQUIRIES FROM BIDDERS	RESPONSES FROM ESKOM
the information for the generators as stated below: • Make • Model • Serial Number • KVA Size • Physical address where based	- Germiston Simmerpan Complex, Cnr Power and Refinery Rd. Size 250kVA, 100KVA; Newage Stamford AC generator C534B. - 18 President Building, cnr Kruger Avenue & Lesley Street, Vereeniging – Size 100KVA; Cummins standby diesel. - Benoni Eskom Benoni Office Park, No 8 Lakeview Crescent, Kleinfontein Benoni, Size 100KVA, LOVOL. The serial info will be provided at Contract award.
Where is the air conditioning and electrical portion of the scope, and why was it excluded?	Find information in the scope of work doc and NEC section C3:1.
Can we submit a quotation for the generator set and diesel refueling only, or should the UPS also be included in the quotation?	Refer to provided price list and price for generator and UPS.
Why is an engineer required for this scope of work?	To perform electrical conditional assessment, electrical critical issues in the server rooms, building electrical reticulation, develop electrical design, etc as and when required basis.
Looking at C2.2 the price list, we did determine the total price for the duration of the contract as we could only offer prices for single items or resources. Now my question comes to populating the NEC3 Term Service Contract (TSC3). On the C1.1 Form of Offer & Acceptance (Page 1), is it then acceptable for instance inserting “ NOT APPLICABLE – RATES BASED” for offered total of the Prices?	Refer to updated NEC