



Type. L

Crealco Swift 38 or eq. approved top hung aluminium casement window, per layout. Casement sash 1500 x 1200mm max capacity
 Fixing lugs suitable for fixing to plastered brickwork reveals. Mullions in 100mm depth section, code W54454 with Lx 71.5
 AAAMSA exposure category: A3. SANS613 - 2000Pa wind load capacity
 Class 2 powder coated to SANS 10322:2014; Coatings in accordance with SANS 1796 using powders in accordance with SANS 1578.
 TBC. Provisionally Mat Black
 500mm Stays, 13mm stack, capacity 28Kg. Crealco code STF-TH600S-304 or equal app
 Handles - Per manufacturers specification to suite operation indicated.
 Glazing throughout to be 12mm thick toughened safety glass, per PFG Armourplate.
 SHGC Req. 0.7
 U-Value Req. 5.8 W/m².K (system)
Mesh security screen: Per Trellidor Clearguard casement window, consisting of: 89x23 box section outer frame .
 s/steel woven mesh screen in 42x33 casement framing . Finish- Powder coated of colour to match window frame.
 Locking with cylinder deadlatch and escutcheon, at max 600mm cc. 100mm sinkless S/steel hinges.
Blinds / Curtains: Nil

QUANTITY:	Incl Security Mesh
2	WG37 WG39

NOTES: 1. ALL DIMENSIONS TO BE CHECKED ON SITE PRIOR TO MANUFACTURE. 2. WINDOWS DRAWN AS VIEW FROM EXTERIOR.			REVISIONS	
	Rev.	Date	Description	By
	A	2024.08.06	Window & description updated.	PD

PROJECT: PORT SHEPSTONE HOSPITAL NEW PSYCHIATRIC WARD	Architect: ARTEK 4 ARCHITECTS (KZN) CC Durban: 46 Lena Ahrens Road, Glenwood, Durban 4000 tel: 031 201 0445 fax: 031 201 6609 email: admin@artek4.co.za Port Shepstone: 19 Tradewinds, Marine Drive, Shelly Beach tel: 039 682 2447 fax: 039 682 2446 email: admin@artek4.co.za	
DRAWING DESCRIPTION: WINDOW SCHEDULE WINDOW TYPE L		

Scale	Date	Drawn	Project No.	Drawing No.	Rev.
1:25	14.11.2022	WP	1518	401-12A	A