



- NOTES**
1. ALL POSTS TO BE SET IN CONCRETE (GRADE 25/19).
 2. ALL POSTS, STRUTS, ANGLES, BOLTS, NUTS, STRAIN BOLTS, HOOKS, ETC AND ALL GATES AND PANELS ARE TO BE HOT DIP GALVANISED AFTER FABRICATION IN ACCORDANCE WITH SANS 150 1461.
 3. REPAIRS TO DAMAGED GALVANISING AND UNTREATED STEELWORK TO BE IN ACCORDANCE WITH SANS 150 1460.
 4. GATE MOTOR TO BE CENTURION D5 SMART IN COMBINATION WITH A GALVANISED STEEL TRACK.

FINAL DESIGN FOR CONSTRUCTION

REV	REVISION DESCRIPTION	DRN	CHKD	AUTH	DATE	REFERENCE DRAWINGS
1	GATE WIDTH CHANGED				20-4-2021	
APPROVED BY	Eskom		Eskom Holdings SOC Ltd Reg No 2002/015527/30			
DATE	25-3-2021					
CHECKED BY						
DATE	25-3-2021					
DRAWN BY						
DATE	25-3-2021					
SCALE	AS SHOWN	SHEET NUMBER	16	REVISION	0	

SECURITY FENCE
SUBSTATION ACCESS GATES
SINGLE 7m GATE WITH NO MIDDLE POST
LAYOUT, SECTIONS AND DETAILS

0.54/7470