



Invitation to Tender
Enquiry No: E3070GXMPMAT

ESKOM HOLDINGS SOC LTD
ADDENDUM: INVITATION TO TENDER
FOR

PROVISION OF WELDING SERVICES AT MATLA POWER STATION FOR A PERIOD OF 3 YEARS

ADDENDUM FOR THE FOLLOWING:

TENDER NUMBER: E3070GXMPMAT

- Revised Tender Closing Date

Closing Date	Revised Closing date
24 July 2026 at 10H00	19 September 2026 at 10H00

- Queries and responses for clarity

No.	Queries	Responses
1.	Following our recent clarification meeting regarding the Matla Welding Shop Additional Resources tender, it was noted that certain missing sections and adjustments need to be made to the scope of work and tender documentation. During the clarification meeting, it was mentioned that an addendum containing these updated scope requirements and documentation would be formally issued to tenderers. Would you kindly provide an update on when we can expect this addendum to be published or uploaded to the Eskom Tender	Addendum Published on the 12 of August 2026

	Portal? We want to ensure our submission fully incorporates all revised requirements prior to the closing date.	
2.	1. Material grades according to ISO/TR 15608 grouping. 2. Plate thickness ranges. 3. Pipe diameters and wall thicknesses. 4. Required welding processes (111, 141, 135, 136, etc.). 5. Any dissimilar metal welding requirements. 6. Applicable welding standards and specifications. 7. Typical welding applications expected under the contract.	Plate thickness-1.6mm to 32mm Pipe diameter-35mm to 400mm and wall thickness is from 3mm to 16mm Welding processes are TIG,MIG,STICK ,OXY-ACCETELYN ETC
3.	Can you please clarify on the below queries regarding the above-mentioned tender: 1. Welders Do we need to submit a ISO 9606 Welder's Qualification only or should we also submit a Red Seal as well??? 2. Boilermakers Requirement state that we should submit N3 Qualification.... Can we submit a Matric qualification which is equivalent to a N3???	For the welders, Please submit both the iso 9606 and the red seal certificate For boilermakers N3 is required even if you have matric
4.	1. Will Eskom be supplying the equipment and the consumables? 2. On the Technical Evaluation it requests qualifications for a diesel Mechanic on page 12 but on the price list there is no Diesel Mechanic listed. Must it be included or excluded?	1.eskom will supply diesel welding machines, welding inverters, plate rolling machine,Guilotine machine, Bending press machine, radial drilling machine pedestal grinder etc. 2 exclude the diesel mech

Kind Regards,

 PP

Signature

Lebogang Letsholo

Acting Manager Procurement – Matla Power Station

Date: 12/08/2026