Туре		Description	Installation	Lamp Type	S Colour	Qty	Location	Comments
				Турс	Coloui	l		
А		600x600 LED panel with white alumimium trim. Back lit with a 4mm opal diffuser and PMMA light guide CRI 80+, UGR =19, 110-120 lumens per watt complete with 6amp plug top and 3m cordset. 1 hour battery back up where indicated with 'e' at 20% output. Complete with 5 year warranty and lumen maintenance of >50 000 hours 600x600 LED panel with white alumimium	Recessed	33W LED	4000K		Offices / Passages / General Area's	Beka LED Panel or equal and approved
A1		trim. Back lit with a 4mm opal diffuser and PMMA light guide CRI 80+, UGR =19, 110-120 lumens per watt complete with 6amp plug top and 3m cordset. 1 hour battery back up where indicated with 'e' at 20% output. Complete with 5 year warranty and lumen maintenance of >50 000 hours	Surface - Surface mount kit to be included	33W LED	4000K		Archives / Stores / Safes, Records Room	Beka LED Panel or equal and approved
A2		trim. Back lit with a 4mm opal diffuser and PMMA light guide CRI 80+, UGR =19, 110-120 lumens per watt complete with 6amp plug top, 3m cordset and Dali dimmable driver. Complete with 5 year warranty and lumen maintenance of >50 000 hours L80B10	Recessed	33W LED	4000K		Lecture Room	Beka LED Panel or equal and approved
В	W	50% output. Complete with 5 year warranty and lumen maintenance of >50 000 hours L70B10	Recessed in ceiling	9W LED	4000K		Bathroom /Ablutions/ Kitchen	Beka RondoLED Maxi or equal and approved
С			Surface (wall mounted)	14W LED	4000K		Building Exterior	Beka Series 50 or equal and approved

Samples of all luminaires are to be presented for approval before orders are placed.
Quantities are to be confirmed by contractor
Lamps to be Osram, Phillips or equal and approved. Control gear to be Osram, Phillips, Tridonic, V&S or equal and approved. Full details to be submitted with sample.

						ENGINEER:	DRAWN:	DATE:	CHKD	P SIZE	TITLE:	Mr.
H	-					MK	MK	Aug 2024	JK	A4	Samora Machel Police Station	
F						PROJ No.:		DWG No	REV	SCALE	( Dad K Approved in Principle	
(	0	Original Issue	MK	22/01/234	MK	32308_601		0	nts	Luminaire Schedule  Justin Mckelvie-King Pr Eng: 20120548	The state of the s	
RI	V D	DESCRIPTION	BY	DATE	CHKD	FILE NAME:	32302_6	01_0 SHEET:	1 of	3	11 Elig : 20120040	Mhares

	1			Lamp	S	-		Comments		
Туре		Description	Installation	Туре	Colour	Qty	Location	Comments		
C1			Surface (wall mounted)	7W LED	4000K		Covered Walkways	Beka Series 50 or equal and approved		
D		LED Linear vapour proof fitting (1200mm) (IP65) (IK10) constructed from marine grade high pressure die cast aluminium with poly carbonate UV protected diffuser, (160 - 180 lumens per watt and CRI 80+). Complete with 5 year warranty and lumen maintenance of >50 000 hours L70B10	Surface	27W LED	4000K		Flammable Stores	Beka Vapourline or equal and approved		
E	R L	Ceiling mounted emergnecy exit signage. Complete with 2 hour self contained, maintained emergency with separate red/green indicator lights and test button. Complete with 5 year warranty.	Surface	5W LED	4000K		Emergency Exits	Supplied by Rubicon / Regent / ETAP or equal and approved		
F		LED Post top mounted fitting constructed from marine high grade pressure die cast aluminium base and high impact polycarbonate diffuser, with built in photocell and 5m firbreglass pole. 120 -130 lumens per watt . Complete with 5 year warranty and lumen maintenance of >100 000 hours L70B10 LED Post top mounted fitting constructed	Post top mounted	28W LED (a- symmetric light distribution)	4000K		External	Beka Zela or equal and approved		
G	B	from marine high grade pressure die cast aluminium base and high impact polycarbonate diffuser, with built in photocell and 5m firbreglass pole. 120 -130 lumens per watt. Complete with 5 year warranty and lumen maintenance of >100 000 hours L70B10	Post top mounted	22W LED (symmetric light distribution)	4000K		External	Beka Zela or equal and approved		

Samples of all luminaires are to be presented for approval before orders are placed.

Quantities are to be confirmed by contractor

Lamos to be Osram .Phillips or equal and approved. Control gear to be Osram. Phillips. Tridonic. V&S or equal and approved . Full details to be submitted with sample.

ſ						ENGINEER:	DRAWN:	DATE:	CHKD	P SIZE	TITLE:	<b>M</b>
ŀ						MK	MK	Aug 2024	JK	A4	Samora Machel Police Station	
						PROJ No.:		DWG No	REV	SCALE	Approved in Principle	
						32308 601					Justin Mckelvie-King	
	0	Original Issue	MK	22/01/234	MK	32306_601			U	nts	Luminaire Schedule Pr Eng : 20120548	
	EV [	DESCRIPTION	BY	DATE	CHKD	FILE NAME:	32302_6	01_0 SHEET:	2 of	3	7 11 Elig : 20120040	Mark

т	Description	la stallation	Lamp	S	04.	Looption	Comments		
Туре	Description	Installation	Туре	Colour	Qty	Location	Comments		
J	80+). Complete with 5 year warranty and lumen maintenance of >50 000 hours	Surface Mounted	26W LED	4000K		Cells / Cell Blocks Secure Lobby / Cell Block Kitchen / Cell Admittance Area / Temporary Holding Cell	Beka RoughGuard LED or equal and approved		
J1	LED Linear vandal proof fitting (300mm) (IP66) (IK10) constructed from marine grade high pressure die cast aluminium with poly carbonate UV protected opaque diffuser, (100 -110 lumens per watt and CRI 80+). Complete with 5 year warranty and lumen maintenance of >50 000 hours L70B10	Surface Mounted	7W LED (with night light)	4000K		Cells Shower and Toilet Cubicles / Temporary Holding Cell Toilet	Beka RoughGuard LED or equal and approved		
J2	LED Linear vandal proof fitting (600mm) (IP66) (IK10) constructed from marine grade high pressure die cast aluminium with poly carbonate UV protected opaque diffuser, (140 -150 lumens per watt and CRI 80+). Complete with 5 year warranty and lumen maintenance of >50 000 hours L70B10	Surface Mounted	52W LED	4000K		Cells Exercise Yard / Cell Block Offloading Area	Beka RoughGuard LED or equal and approved		
J3	LED Linear vandal proof fitting (300mm) (IP66) (IK10) constructed from marine grade high pressure die cast aluminium with poly carbonate UV protected opaque diffuser, (100 -110 lumens per watt and CRI 80+). Complete with 5 year warranty and lumen maintenance of >50 000 hours I 70B10	Surface Mounted	7W LED	4000K		Cell Block Service Ducts	Beka RoughGuard LED or equal and approved		
J4	LED Linear vandal proof fitting (300mm) (IP66) (IK10) constructed from marine grade high pressure die cast aluminium with poly carbonate UV protected opaque diffuser, (100 -110 lumens per watt and CRI 80+). Complete with 5 year warranty and lumen maintenance of >50 000 hours L70B10	Surface Mounted	15W LED	4000K		Cell Block - Passages / Stores / Visitors Area / Visitors Waiting / Pantry / Staff Toilets	Beka RoughGuard LED or equal and approved		

Samples of all luminaires are to be presented for approval before orders are placed.

Quantities are to be confirmed by contractor

Lamos to be Osram .Phillips or equal and approved. Control gear to be Osram. Phillips. Tridonic. V&S or equal and approved . Full details to be submitted with sample.

ſ						ENGINEER:	DRAWN:	DATE:	CHKD	P SIZE	TITLE:	
ŀ						MK	MK	Aug 2024	JK	A4	Samora Machel Police Station	
I						PROJ No.:		DWG No	REV	SCALE	Approved in Prin	inle
						32308 601			١ ,	nto	Justin Mckelvie-	
	0	Original Issue	MK	22/01/234	MK	32300_001			U	nts	Luminaire Schedule Pr Eng : 201205	CF CF N
	EV [	DESCRIPTION	BY	DATE	CHKD	FILE NAME:	32302_6	01_0 SHEET:	3 of	3	V 11 Elig : 201200	, Munici