











AS PER PART 'DB' DEPT. SPECIFICATION FOR EARTHWORKS FOR PIPE TRENCHES. (CLASS 'C')



THRUST BLOCK SIZES (in mm)
in normal earth for heads of 120 m

PIPE SIZE	CAP	TEE (BRANCH)	90° 1/4 BEND	45° 1/8 BEND	22.5° 1/16 BEND
75mm	200 x 200	200 x 650	250 x 300	200 x 250	200 x 200
110mm	200 x 400	200 x 650	300 x 500	250 x 300	200 x 200
160mm	300 x 600	300 x 650	500 x 600	350 x 500	300 x 300
200mm	400 x 800	400 x 800	600 x 900	400 x 800	300 x 500
250mm	600 x 800	600 x 800	900 x 900	600 x 800	400 x 600
315mm	700 x 1000	700 x 1000	1000 x 1300	700 x 1000	600 x 600
	X Y	X Y	X Y	X Y	X Y



DRAWING No. 38584

METRO WATER & WASTE WATER DESIGN BRANCH

THRUST BLOCK DETAILS FOR M.P.V.C. PIPES

Drawn by: K.M.H.

Checked by:

Date: MAR 2005

Manager(WD):

Exec. Dir. (Water & Waste)

39

Plan No: