A0_REF_1

PROJECT/ADDRESS

Nyweiczanz Hospital
Proposed New Orthotic &
Prosthetics Centre
Electrical Services

TITLE

Small Power Roof
Layout and Details

Option 4

ENGINEER	DRAWN BY	DATE	CHECKED	SCALE
RSN	BM	May'22	RSN	1:200
			PAPER SIZE	A0

PROJECT No.	DRAWING No.	SHEET	REV.
20013	201		0

FILE: LAYER:

REVISIONS			
REV	DATE	BY	DESCRIPTION
0	19/04/22	BM	Original Issue

BLOCK D
ESSEX PARK
MENTMORE
PO BOX 1662
WAKEFIELD
WA09 0BEOK 3631
TEL: +27 (0)11 2987631
FAX: +27 (0)11 2987631
E-mail: thejeff@ibuia.co.za

IBUIA Chartered Building Log/08813

YOUNEEDNO DETAILDRAWN?

GENERAL NOTES

This drawing is issued for Electrical purposes only, and should be read in conjunction with the Electrical Specification. Setting out of Electrical and Electronic accessories are to be as indicated on Architects details.

Refer to Architects and Structural Drawings for all building dimensions, latest building revisions and services.

Do not scale this drawing.

All work to comply with relevant Standards, Codes of Practice, Specification and Regulations.

Notwithstanding anything to the contrary, all rights reserved. No part of this drawing may be reproduced in any material form (including photo-copying or storage in any medium or by electronic means and whether or not transiently or incidently to some other use of this drawing). In addition, this drawing may not be used for any purpose or reason other than for which it was originally issued, without written permission of the author.

DRAWING NOTES

(29) 60A Three Phase Isolator on the Roof for AHU No. 2 (Weatherproof)

(29) 30A Three Phase Isolator for Fresh Air Fan(Weatherproof)

(30) 60A Three Phase Isolator for Fresh Air Fan(Weatherproof)

(31) 30A Three Phase Isolator for Fresh Air Fan(Weatherproof)