

TECHNICAL SCHEDULES A & B FOR MV XLPE CABLES

SAP: 175763 CABLE 22kV 3C 185SQ. CU FUX3SCQ

Schedule A: Purchasers specific requirements
 Schedule B: Guarantees and technical particulars of equipment offered

1	2	3	4	5
Item	240-56063792	Description	Schedule A	Schedule B
1		Item and system description		
		CABLE 22KV 3C 185SQ. CU FUX3SCQ		
1.1		SAP No	0175763	xxxxxxxxxx
1.2		Buyers Guide Drawing	D-DT-8001	xxxxxxxxxx
1.3		Symmetrical fault level rating	kA	xxxxxxxxxx
1.4		Nominal system voltage	kV	22
1.5		Earth fault level rating	kA	xxxxxxxxxx
2		Ratings		
2.1	3.1.1	Rated voltage (U _i)	kV	22
	3.1.2	Conductor Size	mmsq	185
2.3	3.1.2	Number of cores (1- Core or 3- Cores)		3
	3.1.4.8	Screening of cables		Individually screened
	3.1.4.2	Semiconducting core screen		Strippable
	3.1.4.3	Core identification		Yes
	3.1.4.4	Bedding under armouring		PVC Type B1
	3.1.4.8	Armouring		SWA
2.5	3.2.6f)	Rated frequency (f _i)	Hz	50
2.7	3.1.4.8	Type of outer sheath		Black PE type S2
	3.1.4.8	Does outer sheath comply with the requirements specified in 3.1.4.8		Yes
2.8	3.1.4.5	Is the PE PS2 outer sheath fire retardant?		Yes
2.9	3.1.4.7	Does the cable meet the longitudinal water blocking requirements for conductor and cable?		Longitudinally water blocking
	3.1.4.7	Method used to achieve water blocking requirements		xxxxxxxxxx
		Instruction provided for water blocking removal in conductor when jointing or termination (if applicable) ?		Yes / NA
	3.2.1b)	Hole for wooden drums for a spindle if not 80mm (minimum).	mm	80mm (min)
2.10	3.2.1c)	Drum length required as per 3.2.1	m	300
2.11	3.2.2	Is the conductor marking system details supplied with tender?		Yes
2.12	3.2.2	Does the conductor marking comply with the requirements of 3.2.2?		Yes
2.14	3.2.2	What magnification factor is required to read font size for conductor marking characters?	Factor	xxxxxxxxxx
2.15	3.2.3	Is marking of cable identification system details submitted with tender?		Yes
2.17		Does the cable marking system comply with the requirements of 3.2.3?		Yes
2.19	3.2.3a)	Where is the cable identification system located (in which layer of the cable)?		xxxxxxxxxx
2.20	3.2.3c)	Does the cable identification system comply with the requirements as stated in 3.2.3c)	mm	Yes
	3.2.4	Does the marking of cable outer sheath comply to 3.2.4?		xxxxxxxxxx
2.21	3.2.6	Is the catalogue with required information submitted?		Yes
2.22	3.2.6	Does the catalogue have all the required information?		Yes
2.23	3.3.1	Are copies of type tests reports submitted with tender documentation?		Yes
		Are all applicable documents submitted i.e type test reports, test schedules, deviation schedule (if any), cable construction drawings, list of all type tested material used in the construction of the cable?		Yes
3.24	3.3.1.2	Cable dimensional data drawing submitted?		Yes
3.25	3.3.1.2	Maximum sustained current rating at 90deg Celcius conductor temperature installed in:	A	
		a) Ground?		xxxxxxxxxx
		b) Air?		xxxxxxxxxx
		c) Ducts?		xxxxxxxxxx
3.26	3.3.1.2	Maximum sustained current rating 70deg Celcius conductor temperature installed in:	A	
		a) Ground?		xxxxxxxxxx
		b) Air?		xxxxxxxxxx
		c) Ducts?		xxxxxxxxxx
3.27	3.3.1.3	Short circuit rating?	kA	xxxxxxxxxx
	3.2.6g)	Cable mass?	kg/m	xxxxxxxxxx
	3.2.6h)	Gross mass per standard drum length?	kg	xxxxxxxxxx
	3.2.6i)	Resistance at max conductor temperature?	°C	xxxxxxxxxx
	3.2.6j)	Reactance per phase?	Ω/m	xxxxxxxxxx
	3.2.6k)	Capacitance per phase?	nF/m	xxxxxxxxxx
	3.2.6l)	Zero sequence impedance and capacitance per phase?	Ω/m	xxxxxxxxxx
	3.2.6m)	Cable thermal time constant?	Seconds	xxxxxxxxxx
	3.2.6 n)	A copy of the relevant SABS mark scheme permit submitted?		xxxxxxxxxx
3.28	3.3	Testing of cable is done in accordance with SANS 1339?		Yes

SIGNATURES

Factory	Name (Print)	Sign	Date
Eskom	Name (Print)	Sign	Date