

ANNEXURE A – SPECIFICATION

Generic 42U Server Rack -Black in colour.

Must support the following switch, width and depth specifications should be as follows.

Switch Dimensions

Switch Component	Width	Depth ¹	Height
Cisco Nexus 9504 chassis	17.3 inches (43.9 cm)	32.4 inches (82.3 cm) ²	12.2 inches (31.0 cm) (7 RU)

¹ Depth measurements for the chassis include fan tray handles.² With fan tray handles, the depth from the front of the chassis to the handles is 33.5 inches (85.1 cm)

- Depth must be at least 1000mm.
- PDU should be a 2 x horizontal/vertical Power strip with 16/32 AMP or similar with 32 Amp 3 pin caravan/welding connector.
 - Support IEC C19 power connectors x 4
 - Support IEC C14 power connectors x 8

Example



- Server Rack must be delivered in the Northern Cape Region

Address Details:

9 Southey Street,
Van de Wall Gebou 1st Floor
Kimberley,
8301

1. Proposal

The proposal must be a fixed price including VAT.

2. PERIOD OF ASSIGNMENT

All work is to be carried out in accordance with the time schedule as agreed with ICASA.

3. PERFORMANCE MEASURES

The performance measures for the delivery of the project will be closely monitored by ICASA IT Department.