

	Tender Questions and Answers	Document Identifier	559-222407715	Rev	1
		Effective Date	July 2024		
		Review Date	July 2027		

To whom it may concern	Date	
	Enquiries	Rumani Tshivhandekano
	E-mail address	tshivhr@ntcsa.co.za

Dear Sir/Madam

Request for Enquiry Number	E2970NTCSAMWP
Description / Project Title	SUPPLY AND DELIVERY OF NITROGEN GAS AS AND WHEN REQUIRED, RENTAL OF 10 X 11 KG NITROGEN GAS CYLINDERS FOR A PERIOD OF 60 MONTHS
Tender questions and response	22 June 2026

Item	Questions	Responses
1.	NTCSA requires adherence to Specifications for Nitrogen Gas: Suppliers provide specifications of the Gas to be supplied (Nitrogen > 99.99%, are suppliers allowed to quote you on a higher purity?	Yes, suppliers are allowed to quote NTCSA on higher purity. The minimum must be >99% and, within acceptable price range.
2.	The maximum consumption of cylinder per annum?	NTCSA uses maximum of 10 bottles per annum.
3.	Is there any possibility of this 10 per annum going up higher than 10?	No, NTCSA uses maximum of 10 bottles per annum. It can be less than 10, depending on how our system is responding at the time.
4.	How will NTCSA calculate CPA base date?	NTCSA will use latest information which will be from SIEFSA or Statistics South Africa, and NTCSA reserves the right to negotiate CPA terms and conditions during negotiations held with tenderers.
5.	Does NTCSA require SANAS accreditation only for the supply of Nitrogen Gas?	NTCSA will require proof of SANAS accreditation or traceability according to NIST and ISO 9001 certification can be provided

Controlled Disclosure

from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the document may be reproduced in any manner or form by third parties without the written consent of NTCSA SOC Ltd, © copyright NTCSA SOC Ltd, Reg No 2021/539129