



HARDWIRED INTERLOCK TABLE		
INT No.	DESCRIPTION	CONTROL ACTION
361301	X01 E-STOP	ES 011
368601	FUTURE (X02 E-STOP)	ES 021
368602	FUTURE (X03 E-STOP)	ES 031
368603	FUTURE (X04 E-STOP)	ES 041
361901	X05 E-STOP	ES 051
361902	X06 E-STOP	ES 061
367101	X07 E-STOP	ES 071
367102	FOIC 711	ES 711

FOR ALL SOFTWARE INTERLOCK REFER TO EDS

- NOTE:
- 80mm FLANGES TO BE INSTALLED FOR EXTERNAL CALIBRATION OF PROVER
 - SPOOL PIECE FOR FUTURE DENSITOMETER – FACE TO FACE 600mm
 - MONOLITHIC JOINT
 - TRANSFER PUMP TO BE SIZED FOR CORRECT FILLING AND DRAIN TIMES
 - SELF PRIMING PUMP
 - OPTICAL INTERFACE DETECTOR TO BE CLOSE TO PETROLINE PUMPS TO DETECT PRODUCT CHANGE. STD ANALOG SIGNAL. RUN CABLE WITH PIPELINE
 - DH1 CONTROLS LOT, L02 & R01
 - BLEED LINE TO BE CONNECTED TO TOP OF MAIN PROCESS LINE
 - PENDING NEW WATER DRAIN ARRANGEMENT
 -
 - PETROLINE SCOPE ON HOLD (INTAKE MANIFOLDS)