	<b>Tender Questions and Answers</b>	<b>Document Identifier</b> 240-7124948	<b>Rev</b> 1
		<b>Effective Date</b> 01 April 2023	
		<b>Review Date</b> April 2026	

<b>To whom it may concern</b>	<b>Date</b>	<u><b>29/04/2026</b></u>
	<b>Enquiries</b>	<u><b>Thandi Mavasa</b></u>
	<b>E-mail address</b>	<u><b>MavasaPT@eskom.co.za</b></u>


Dear Sir/Madam

<b>Request for Enquiry Number</b>	<b>E2812GXMPGRO</b>
<b>Description / Project Title</b>	<b>Supply, Delivery, installation and commissioning of Dust hopper level measurement for a period of 3 years at Grootvlei Power Station</b>
<b>Tender Questions Closing Date</b>	<u><b>13/04/2026</b></u>

Item	Questions	Answers	Clarity Published Dates
1.	<b>Contract Duration</b>	<b>Please take note the duration of this contract will be for a period of three (03) years</b>	<b>29.04.2026</b>
2.	<b>What ACS can supply towards this tender:</b> 1. <b>Supply of 2535 Vibrating rod level switch or 5300 guided wave radar with 4-20mA loop powered for analog measurements</b> 2. <b>Commission instruments after installation completion</b> <b>Looking forward to your assistance</b>	<b>We are looking for an analogue level measurement, supply, install, and commissioning.</b>  <b>We have 3 units and each unit has 16 hoppers, which means we need 48 instruments to be supplied, installed, and commissioned.</b>	<b>30.04.2026</b>

**Controlled Disclosure**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the system. No part of this document may be reproduced in any manner or form by third parties without the written consent of Eskom Holdings SOC Ltd, © copyright Eskom Holdings SOC Ltd, Reg No 2002/015527/30

 Eskom	<b>Tender Questions and Answers</b>	<b>Document Identifier</b> 240-7124948	<b>Rev</b> 1
		<b>Effective Date</b> 01 April 2023	
		<b>Review Date</b> April 2026	

4.	<b>Please confirm that the technology you are looking for is 4-20mA and loop power.</b>	<b>Yes continuous level measurement</b>	
3.	<b>Please confirm the accuracy of the instrument</b>	<b>0.1% Accuracy</b>	
4.	<b>Please send the specification for the instrument cable</b>	<b>UVG (instrument) Type of cable</b>	
5.	<b>Please confirm we are reusing the existing cable racks.</b>	<b>Yes, correct</b>	
6.	<b>Please confirm the cable lengths that need to be replaced.</b>	<b>About 10 meters each instrument and a total of 48 instruments.</b>	
7.	<b>Please send the specifications for the junction boxes and the quantity that we need to replace. 2 boxes per unit, in total of 6 boxes</b>	<b>I will send the specifications</b>	

### Controlled Disclosure

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the system. No part of this document may be reproduced in any manner or form by third parties without the written consent of Eskom Holdings SOC Ltd, © copyright Eskom Holdings SOC Ltd, Reg No 2002/015527/30