

Questions and Answers:

Q: We have only become aware of your requirement yesterday and through our Italian based manufacturing principle, Servizi Industriali Srl who manufacture the Macfuge (www.macfuge.com) range of Oil separators, we are able to bid competitively on this requirements. We are also aware that a very limited number of manufacturers manufacture this specific equipment and thus our ability to submit a bid would be most helpful to expand the present options available to Eskom.

A: Unfortunately, the answer remains the same. We will not consider alternatives.

Q: I would like to request an extension for our quotation submission to the 6th of April 2022.

A: Tender is closing 29 April 2022

Q: I would like to know if it is possible to participate in the tender, providing only centrifugal purification units and not decommissioning/commissioning.

A: It is not possible. All submissions must cover the complete scope of work.

Q: Can the following documents to be made available to us

6. CODES AND STANDARDS

The Contractor shall adhere to the following codes and standards:

6.1. C&I

- 240-56227443 Requirements for Control and Power Cables for Power Stations Standard.
- 240-56355815 Control & Instrumentation Field Enclosure and Cable Termination Standard.
- 240-56355466 Alarm Management System Guideline
- 240-56355888 Temperature Measurement Systems Installation Standard
- 240-56355843 Pressure Measurement Systems Installation Standard
- 240-56355789 Flow Measurement Systems Installation Standard

6.2. Electrical

- 240-56356396 Earthing and Lightning Protection.
- 240-56355754 Field Equipment Installation Standard.
- 240-57617975 New Low Voltage Motors Procurement Standard.

6.3. Mechanical

- 240-56063935 Turbine Oil Standard
- 240-89147446 Impulse Piping for Coal Fired Power Plants Standard
- 240-106628253 Welding Requirements on Eskom Plant Standard
- 240-83539994 Non-Destructive Testing (NDT) on Eskom Plant Standard

6.4. Civil

- 240-56364545 Structural Design and Engineering Standard

6.5. Drawings and Procedures

- 240-86973501 Engineering Drawing Standard – Common Requirements.
- 240-56030537 Review of Piping and Instrumentation Diagrams.
- 240-109607332 Eskom Plant Labelling Abbreviation Standard.
- 240-61227631 Piping and Instrumentation Diagram (P&ID) Standard.

A: Documents are attached.

1. An extension of the bid submission date to the 6th May 2022
2. Will alternative solutions to the current design be acceptable i.e different purification technology as opposed to a centrifuge?
3. Will the station be willing to have a clarification meeting to discuss question 2

A:

1. We will extend the closing date to the end of April 2022
2. We will not consider any alternatives as stated in our clarification meeting.
3. We will not have another clarification meeting to discuss alternatives