



TITLE	SPECIFICATION FOR PROTECTION	REFERENCE	REV
		CP_TSSPEC_214	5
			DECEMBER 2024

TABLE OF CONTENTS

FOREWORD	4
INTRODUCTION	5
1 SCOPE.....	5
2 NORMATIVE REFERENCES	5
3 DEFINITIONS.....	7
4 NOTE	7
5 SERVICE CONDITIONS	7
6 MAJOR PROTECTION EQUIPMENT: General hardware and software requirements	7
7 MAJOR PROTECTION EQUIPMENT: logic and setting Configurations	8
8 MAJOR PROTECTION EQUIPMENT: IED Communication ports	8
9 MAJOR PROTECTION EQUIPMENT: DigSilent StationWare compatibility	9
10 BYCH - HV BAY CONTROLLER.....	9

11	DOCUMENTATION	14
12	MARKING AND LABELLING	15
13	TRAINING	15
14	QUALITY MANAGEMENT	15
15	HEALTH AND SAFETY	15
16	ENVIRONMENTAL MANAGEMENT	15
	ANNEXURE A - Bibliography	16
	ANNEXURE B - Revision information.....	17
	ANNEXURE C - BYCH – TECHNICAL SCHEDULES	19
	ANNEXURE C - BYCM – TECHNICAL SCHEDULES.....	21
	ANNEXURE C - MAINI – TECHNICAL SCHEDULES	23
	ANNEXURE C - PFCR – TECHNICAL SCHEDULES.....	27
	ANNEXURE C DIFFO– TECHNICAL SCHEDULES.....	29
	ANNEXURE C - DIFFPV – TECHNICAL SCHEDULES.....	31
	ANNEXURE C - PWSRV – TECHNICAL SCHEDULES	32
	ANNEXURE C - DIFFPI – TECHNICAL SCHEDULES	33
	ANNEXURE C - PWSRI – TECHNICAL SCHEDULES.....	34
	ANNEXURE C - DIFFT – TECHNICAL SCHEDULES	35
	ANNEXURE C - DIFFZ – TECHNICAL SCHEDULES	37
	ANNEXURE C - DIFFB – TECHNICAL SCHEDULES.....	39
	ANNEXURE C - ARCP – TECHNICAL SCHEDULES	41
	ANNEXURE C - STBYEF – TECHNICAL SCHEDULES	44
	ANNEXURE C – LO1 & LO2 & MTR – TECHNICAL SCHEDULES.....	46
	ANNEXURE C – TAUX – TECHNICAL SCHEDULES.....	47
	ANNEXURE C – ALA – TECHNICAL SCHEDULES	48
	ANNEXURE C – INTSP and INTRP – TECHNICAL SCHEDULES	49
	ANNEXURE C – INTSF and INTRF – TECHNICAL SCHEDULES	50
	ANNEXURE C – MFST – TECHNICAL SCHEDULES.....	51
	ANNEXURE C – DIFFC – TECHNICAL SCHEDULES	53
	ANNEXURE C – TAUX – TECHNICAL SCHEDULES.....	55

FOREWORD

This standard was reviewed by the following work group members:

H. S. Somo

Innovation Hub

C. Talane

Grid expansion

The work group appointed by the Interim Study Committee, which, at the time of approval, comprised of the following members:

Study Committee	Name	Department and Section
	Charlotte Talane	Grid expansion.
	Marc Paravano	Grid expansion.
	Ntsako Mdaka	IOT
	James Khoza	IOT
	Sixolele Tok	IOT
	Siyabulela Mkhondweni	IOT

Recommendations for corrections, additions or deletions should be addressed to the:

Innovation Hub Senior Manager

City Power Johannesburg (SOC) Ltd

P O Box 38766

Booyens

2016

INTRODUCTION

The City Power Johannesburg electrical network is an amalgamation of five separate electrical utility networks. These five networks are Johannesburg, Roodepoort, Midrand, Randburg, and the South. Each network was historically developed in a unique manner respective to one another due to the different local municipal authorities responsible at the time. As a result, there are many different protection scheme types as well as associated relays installed on these networks as detailed in this document. To control the burgeoning relay manufacturer types and models on the system, the number of relay models and manufacturers thereof need to be controlled and limited for a period of time.

1 SCOPE

City Power will utilize this specification to evaluate major protection equipment that is required on the network. Only the major protection equipment evaluated and passed under this specification shall be deemed as fit for use by City Power.

2 NORMATIVE REFERENCES

The following documents contain provisions that through reference in the text constitute requirements of this standard. At the time of publication, the editions indicated were valid. All standards and specifications are subject to revision and parties to agreements based on this specification are encouraged to investigate the possibility of applying the most recent editions of the documents listed below.

IEC 61850-1: *Introduction and overview Part 1.*

IEC 61850-2: *Glossary: Part 2*

IEC 61850-3: *General Requirements Part 3*

IEC 61850-4: *Systems and Project Management Part 4*

IEC 61850-5: *Communication requirements for functions and device models Part 5*

IEC 61850-6: *Configuration description language for communication in electrical substations related to IEDs Part 6*

IEC 61850-7-1: *Basic communication structure for substation and feeder equipment. Principles and models Part 7-1*

IEC 61850-7-2: *Basic communication structure for substation and feeder equipment. Compatible logical node classes and data classes Part 7-2*

IEC 61850-8-1: *Specific Communication Service Mapping (SCSM). Mappings to MMS (ISO 9506-1 and ISO 9506-2) and to ISO/IEC 8802-3 Part 8-1*

IEC 61850-9-1: *Specific Communication Service Mapping (SCSM). Sampled values over serial unidirectional multi-drop point to point link Part 9-1*

IEC 61850-9-2: *Specific Communication Service Mapping (SCSM) Sampled values over ISO/IEC 8802-3 Part 9-2*

IEC 61850-10: *Conformance testing Part 10*

EN 50263 1999: *Electromagnetic Compatibility (EMC) : Electromagnetic Emissions*

EN 60255-26-:2009 *Measuring relays and protection equipment - Part 26: Electromagnetic compatibility requirements*

IEC 61000-4-3 2010: *Electromagnetic compatibility (EMC) - Part 4-3: Testing and measurement techniques - Radiated, radiofrequency, electromagnetic field immunity test* IEC 61000-4-11 2017 *Electromagnetic compatibility (EMC) - Part 4-11: Testing and measurement techniques - Voltage dips, short interruptions and voltage variations immunity tests*

IEC 60255-11 1979: *Electromagnetic Compatibility Immunity: Power Supply Immunity*

IEC 61000-4-8 2009: *Electromagnetic compatibility (EMC) – Part 4-8: Testing and measurement techniques – Power frequency magnetic field immunity test*

IEC 61000-4-9 2016: *Electromagnetic compatibility (EMC) - Part 4-9: Testing and measurement techniques - Impulse magnetic field immunity test*

IEC 61000-4-2: 2008: *Electromagnetic compatibility (EMC) - Part 4-2: Testing and measurement techniques - Electrostatic discharge immunity test.*

IEC 60255-26:2013: *Measuring relays and protection equipment - Part 26: Electromagnetic compatibility requirements.*

IEC 60068-2-1: 2007: : *Environmental testing - Test A: Cold*

IEC 60068-2-2 2007: *Environmental testing - Test B: Dry- TestC* 60255-21-1 1998: *Class 1*

IEC 60255-21-2: 1998: *Class 1*

IEC 60255-21-3 1993: : *Electrical relays: Vibration, shock, bump and seismic tests on measuring relays and protection equipment: Seismic tests*

IEC 60529: 2015: *Degrees of protection provided by enclosures (IP Code)*

IEC 60255-1 2009: *Measuring relays and protection equipment - Part 1: Common requirements.*

ENA TS 50-19: 2004: *Standard Numbering for Small Wiring: for Switchgear And Transformers Together With Their Associated Relay Panels)*

SANS ISO 9001: *Quality Management*

OHSAS 18001: *Occupational health and safety management systems*

3 DEFINITIONS

The definitions and abbreviations in the above documents (Normative Reference) shall apply to this specification.

OEM	Original Equipment Manufacturer. The manufacturer and source of the protection relay and not any intermediary, re-seller, modifier, or agent thereof.
IED	An intelligent electronic device. A protection relay that has an embedded microprocessor for protection and control functionality and is able to serially communicate to another device using a standard protocol.
SCADA	Supervisory control and data acquisition. The ability to receive and send information to and from a remote-control Centre and a intelligent electronic device.
I/O	Relay inputs and outputs. The MAJOR PROTECTION EQUIPMENT's opto-isolated digital inputs and contact output relays used for protection, control and SCADA functionality.
BYCH	Bay Controller. Any MAJOR PROTECTION EQUIPMENT that has SCADA, automation and control functionality using integral I/O's and Boolean type programmable logic to execute such functionality.
Major Protection Equipment	Protection equipment that has significant strategic, functional and cost value e.g. protection relays, auxiliary tripping relays.
Supplier	An OEM or their official representatives based in South Africa

4 NOTE

Nothing in this specification shall lessen the obligations of the supplier. The supplier shall be fully responsible for the design and supply of electronic intelligent devices, and its satisfactory performance in service. Approval by City Power shall not relieve the supplier of the responsibility for the adequacy of the design.

5 SERVICE CONDITIONS

The requirements in this specification apply to equipment for use under the following conditions:

- 5.1 indoors.
- 5.2 at an altitude above sea level up to 1 800 m.
- 5.3 at maximum ambient air temperatures for design purposes:
 - a. minimum -10 °C and maximum 45 °C
 - b. daily average 30 °C
 - c. yearly average 25 °C
- 5.4 relative humidity: 30 % to 90 %.
- 5.5 maximum wind speed: 40m/s.
- 5.6 mean annual rain fall: 1065mm and
- 5.7 Maximum solar radiation: 21200 W/m

6 MAJOR PROTECTION EQUIPMENT: General hardware and software requirements

All IED digital inputs shall be of the opto-coupler type and must be rated to the station DC battery supply. The use of resistors to drop the voltage into the digital inputs shall not be accepted. All relays shall be of the flush mounting type.

The numeric relays shall utilise programmable scheme logic to configure the output relays, binary inputs, internal relay elements, timers and logic variables. Every digital input and output contact shall be able to be freely incorporated into the user configurable programmable logic.

The operation of an IED element shall be clearly and positively indicated on the relay by an indicating LCD display. Primary protection functions and important alarms shall at all times be indicated by a red LED. The adjustable settings on all relays shall be easily accessible, from the relay LCD and a remote terminal. At no time shall the downloading of new settings to the relay compromise the relay protection functions.

All major protection equipment output contacts shall be rated to the station DC battery supply.

The nominal voltage transformer input is 110 Vac.

The burden of each voltage input shall not exceed 1VA at nominal input voltage.

The nominal current transformer input is 1 Amp and/or 5 Amp as specified.

The current inputs shall be continuously rated for 300% of nominal current inputs.

The burden of each current input shall not exceed 1VA at nominal input current.

All major protection equipment shall perform extensive and continuous self-checking of hardware and software. A subsequent fault shall be indicated clearly on the face of the major protection equipment and the condition signaled immediately via an output contact. A watchdog contact shall be provided for alarming any failure of the equipment.

7 MAJOR PROTECTION EQUIPMENT: logic and setting Configurations.

The major protection equipment shall have user programmable logic functionality as specified to execute the specified control and protection schemes. Every digital input and output contact shall be able to be freely incorporated into the user configurable programmable logic.

The MAJOR PROTECTION EQUIPMENT programmable logic configurations shall have a minimum number of timers, Boolean functions, latch's, local and remote bit elements as specified.

8 MAJOR PROTECTION EQUIPMENT: IED Communication ports

The IED's shall be supplied with communications ports. For a bay control type IED (See Section - Overview descriptions of the Major Protection Equipment: - BYCH), three communication ports are required; one port is required on the front face of the IED, and two ports are required on the rear. The front port will be used for local engineering access and the rear ports for SCADA and remote engineering.

All other IED's require two communication ports; one port is required on the front face of the IED, and one port is required on the rear. The front port will be used for local engineering access and the rear port for remote engineering.

It shall be possible change the settings, configure the logics and download fault records of any IED via the front face communication port using City Power's laptops, notebooks or computers and the OEM's software.

The ports and the software shall be upgradeable to accommodate City Power's expansion and needs.

For the BYCH, the first rear communication port shall communicate directly with the substation RTU using IEC61850. No intermediate protocol converter shall be allowed whether attached to the IED or remote to the IED.

The second rear communication port shall be utilised for an engineering channel from the substation to City Power - Protection offices (Reuven). It shall be possible to view and alter all relay settings and logic configurations remotely via the engineering channel. It shall also be possible to receive fault records remotely via the engineering channel. It shall be possible to link to the BYC engineering channel directly via a WAN connection and also via telephone modem.

9 MAJOR PROTECTION EQUIPMENT: Dig Silent Station Ware compatibility

All the IED type relays shall each be supplied with a settings file that can be used by Dig Silent Station Ware software for the import and export of the IED settings. The supplier shall be responsible to work with Dig Silent in creating and providing the settings file. Only IED's supplied with a Dig Silent Station Ware settings file shall be considered for evaluation.

The contents of the Dig Silent StationWare settings file must contain all(!) settings parameters with the following information: Name, Function/Chapter, Settings group, Range (also for enumeration types), Unit (e.g. 'A'), Description text, Type of parameter (integer, double, string, Enum), Default value, Actual value.

10 DESCRIPTION OF THE MAJOR PROTECTION EQUIPMENT

10.1 BYCH - HV BAY CONTROLLER

The BYCH shall perform all high voltage level bay related functions such as local and remote control, command sequences, bay and station interlocking, data acquisition, data storage, event and alarm storage, outputs of commands and signal processing required for the different switchgear units of the bay.

The BYCH shall have an integral mimic, capable of controlling and displaying the status of plant devices per bay and have a user-definable layout to suit the substation physical layout. The mimic shall only allow operation if the bay has been selected to local control.

The interlocking software RAM or on-board memory shall be backed-up via non-volatile memory and in the case of a supply failure, on return of supply, automatically resume their function. The software shall be re-programmable via the front port or the rear engineering access port in a straightforward manner. Disturbance records and events shall be stored in non-volatile memory to ensure that data cannot be erased by the removal of the supply to the device.

The BYCH's shall communicate directly on a "peer-to-peer" or one-on-one basis using a direct fiber-optic connection; fibre-optic switches shall be allowed between the BYCH's for the fiber-optic connection. The BYCH's shall be able to send discrete binary signals to one another over the fiber-optic communication channel. All inter bay interlocking and automation, i.e. between BYCH's, shall be done using IEC61850 GOOSE messaging over the fiber-optic channels.

10.2 BYCM - MV BAY CONTROLLER

The BYCM shall perform all medium voltage level bay related automation and interlocking functions such as automatic "chop-over" control, pairing station "flip-flop" control, and local transformer parallel interlocking.

The interlocking software RAM or on-board memory shall be backed-up via non-volatile memory and in the case of a supply failure, on return of supply, automatically resume their function. The software shall be re-programmable via the front port or the rear engineering access port in a straightforward manner.

The BYCM's shall communicate directly on a "peer-to-peer" or one-on-one basis using a direct fiber-optic connection; fiber-optic switches shall be allowed between the BYCM's for the fiber-optic connection. The BYCM's shall be able to send discrete binary signals to one another over the fiber-optic communication channel. All inter bay interlocking and automation, i.e. between BYCH's, shall be done using IEC61850 GOOSE messaging over the fiber-optic channels.

10.3 MAINI – MULTI PURPOSE INCOMER OVERCURRENT PROTECTION RELAY

An incomer is classified as a source of energy. A source may be a remote feeding station, a local transformer, a local generator etc. The MAINI IED shall protect the source from over loading and fault currents as well as the downstream equipment such as bus-bars and feeders. The IED shall monitor the tripping (opening) time of the CB to ensure that they do not exceed adjustable thresholds. The trip time shall be displayed on the IED LCD screen, and an external alarm generated should an adjustable time threshold be exceeded. Each IED shall have a minimum number of protection elements shown below.

Element	Qty	Type	Curve	Range (xIn)	Time Delay/Time Multiplier
O/C	2	Directional	Definite Time	5-2000%	0-10000 ms
E/F	2	Directional	Definite Time	5-80%	0-10000 ms
O/C	1	Directional	IDMT (SI, VI, EI)	10-200%	0.05 – 1.0
E/F	1	Directional	IDMT (SI, VI, EI)	5-80%	0.05 – 1.0
O/C	2	Non Directional	Definite Time	5-2000%	0-10000 ms
E/F	2	Non Directional	Definite Time	5-80%	0.05 – 1.0
SE/F	1	Non Directional	Definite Time	0.5-30%	0-10000 ms
O/C	2	Non Directional	IDMT (SI, VI, EI)	10-200%	0.05 – 1.0
E/F	2	Non Directional	IDMT (SI, VI, EI)	5-80%	0.05 – 1.0
SE/F	1	Non Directional	IDMT (SI, VI, EI)	0.5-10%	0.05 – 1.0

Table 1: Summary of minimum protection element requirements per MAINI IED:

10.4 MAINF – MULTI PURPOSE BACKUP OVERCURRENT PROTECTION RELAY

The MAINF IED will protect the outgoing feeders of a substation from over loading and fault currents as well as any downstream equipment. Only non-directional protection is required and therefore the MAINF IED shall have the same non-directional protection elements as specified for the MAINI IED. The IED shall monitor the tripping (opening) time of the CB to ensure that they do not exceed adjustable thresholds. The trip time shall be displayed on the IED LCD screen, and an external alarm generated should an adjustable time threshold be exceeded.

10.5 PFCR - CAPACITOR BANK PROTECTION RELAY

The PFCR IED shall protect, and control grounded and ungrounded single and double wye capacitor banks using both phase and neutral voltage differential protection. Phase current unbalance protection and neutral current unbalance shall also be provided to protect the capacitor banks. Compensation adjustment shall be provided to zero out small unbalances that are inherent in the bank as well as CT and VT errors. Control logic shall be provided for maintaining system V, VAR or PF (Power Factor) as well as the alarm and blocking of control operations. Over-current and voltage protection elements shall provide additional protection of the banks.

10.6 DIFFO - FIBRE OPTIC LINE DIFFERENTIAL RELAY

The DIFFO IED shall provide high speed, two-ended, phase segregated current differential protection of overhead lines and underground cables. The differential protection shall be current biased with two adjustable slopes. The IED shall also provide CT ratio correction, CT vector correction and inrush restraint to allow for CT mismatch and in-zone transformers. The IED's shall be connected using direct fibre (1310nm Single-Mode, 850nm Multi-Mode fibre) and multiplexed digital links (G.703, V.35, and X.21 interfaces). It shall be possible to send multiple discreet inter-trip signals over the protection communication channel. The IED shall have 1A and 5A CT inputs on one device to allow for CT mismatching.

10.7 DIFFPV – PILOT WIRE LINE BALANCED VOLTAGE DIFFERENTIAL RELAY

The DIFFPV relay shall provide two-ended current differential protection of overhead lines and underground cables. The relay's shall operate on a balanced voltage principle and be directly compatible with remote-end relay. The relay shall provide phase and earth fault protection on circuits and be very stable for through faults while providing suitable sensitivity for internal faults. The relays

shall be of similar type and be linked to one another using a pair of copper pilot wires. The relays shall be suitable for pilot wires insulated to 4kV. The pilot wires shall be supervised, and an alarm contact energized when an open or short circuit is detected.

10.8 DIFFPI – PILOT WIRE LINE CURRENT BALANCED DIFFERENTIAL RELAY

The DIFFPI relay shall provide two-ended current differential protection of overhead lines and underground cables. The relay's shall operate on a current balance principle and be directly compatible with remote end relays. The relay shall provide phase and earth fault protection on circuits and be very stable for through faults while providing suitable sensitivity for internal faults. The relays shall be of similar I type and be linked to one another using a pair of copper pilot wires. The relays shall be suitable for pilot wires insulated to 5kV. The pilot wires shall be supervised, and an alarm contact energized when an open or short circuit is detected.

10.9 DIFFT - TRANSFORMER DIFFERENTIAL AND RESTRICTED EARTH FAULT RELAY

A DIFFT IED is required to protect two winding and auto power transformers. The IED shall include low impedance REF protection for the transformer MV and HV windings. The differential current protection shall be phase segregated, biased and with two adjustable slopes. The IED shall also provide CT ratio correction, CT vector correction, and 2nd and 5th inrush restraint and blocking. A separate unrestrained differential element will provide fast clearance of high magnitude internal faults. The IED shall also cater for dc offset currents during transformer energisation. The REF elements shall function without the use of external stabilizing resistors or equipment of any kind. It shall be possible to apply REF to an auto transformer using internal programming logic only. The neutral phases shall have IDMT and definite time over-current protection elements. The IED shall provide a visual display on an integral LCD screen all the operating parameters (input current phasors, differential currents, bias currents, harmonics, and sequence currents).

10.10 DIFFZ - LINE DIFFERENTIAL AND DISTANCE RELAY

The DIFFZ IED shall provide high speed, two or three terminals, phase segregated current differential protection of overhead lines and underground cables. The IED's shall be connected using direct fibre (1310nm Single-Mode) and multiplexed digital links (G.703, V.35, IEEE C37.94 EIA-422 and X.21 interfaces). It shall be possible to send multiple discrete inter-trip signals over the protection communication channel. The relay shall compare local and remote phase and sequence currents to provide fast operation and shall operate for unbalanced faults with currents below line charging current. Mismatched CTs shall be accommodated by relay settings. Distortion caused by CT saturation of one or both ends shall not cause a mal operation. The IED shall also incorporate four zones of phase and ground mho distance and quadrilateral ground distance protection. Communications assisted distance schemes (e.g. Permissive Over-reach Transfer Trip) shall be provided. Two distance zones shall be settable for either forward or reverse direction. Both positive-sequence memory polarized, and compensator-distance phase distance elements shall be available and the IED shall detect stable and unstable power swings. The IED shall have phase, residual ground, and negative sequence over-current elements with directional and non-directional control.

10.11 DIFFB – BUSBAR DIFFERENTIAL RELAY

A DIFFB IED is required to protect HV and EHV busbars. The protection shall be of the numerical low impedance type in a localised (central) or distributed configuration. Bus-zone protection IED's shall detect bus-bar faults quickly and selectively and thereby isolate the faulty zone only. The bus zone protection shall be capable of detecting three-phase, phase-to-phase and phase-to-earth faults, under all system conditions. The protection shall retain full stability in the event of a through fault. Each zone measuring unit shall use at least two independent criterions for its operation, e.g. current summation and phase angle comparison. A bus-zone protection IED shall be configurable with both main and check zone elements with automatic internal selection of current elements to the correct zones. Each of the bay measuring elements shall not be affected by line / transformer switching, heavy load transfer, power swings, unbalanced primary currents and voltage, voltage dependant current functions, external switching, sudden power reversal etc. The differential current protection function shall have adjustable bias and operating / restraint curves.

The bus-bar protection shall accept inputs from external breaker fail protection relays. Breaker failure protection shall be provided which shall monitor the feeder's phase currents by detectors in each phase. Each bay unit shall have integral CT circuit supervision, which shall detect CT circuit faults, flag these faults and prevent mal operation during normal system operation. It shall not be necessary for

the CT circuit supervision to await an over-current situation to detect a problem. The sensitivity of the IED shall be such that it shall not operate on load in the event of a bus zone protection CT or CT connection being faulty, i.e. open or short-circuited. Operation of current transformer supervision equipment must take the defective protection zone out of service. A low current transformer burden is required to allow the protection to be installed in series with other equipment on a common current transformer secondary circuit.

The bus zone IED shall not be affected by harmonic currents that as may be experienced in a multiple earthed power system or by a CT saturation. CT saturation shall not affect the performance of the bus-zone IED. CT saturation shall be detected within 2 ms of occurring and protection algorithms adjusted to compensate for the saturation. In the case of a distributed type of bus-zone scheme, peripheral units shall be connected to the Central Unit via ruggedized Optic fibre Cable. Optical Fibre Connection interface for multimode glass fibre shall be of the type as per IEC 874-10, 850nm short-haul fibres, Min Length: 1000m. Central and Peripheral units shall be equipped with at least 12 LEDS of which at least 8 shall be user configurable. Graphical programmable user interface allowing user defined protection and control logic to be tailored to the specific application, shall be provided. Internal configurable CT ratio mismatching shall be provided.

10.12 ARCP - ARC PROTECTION RELAY

The main protection for metal-clad switchgear shall be arc protection utilizing both light and current to trip (i.e. a 2 out of 2 operation). This protection scheme shall be provided with individual light sensors in the busbar, cable box and circuit breaker compartments. A fault in a cable box shall only trip the single circuit breaker associated with that cable box. A fault in a circuit breaker compartment or bus-bar chamber shall only clear that section of the switchboard (zone) associated with the fault, i.e. all circuit breakers on the faulted zone shall trip. Therefore, the bus-bars and associated circuit breakers that are separated by bus section circuit breakers shall form separate zones that are cleared on a fault. Healthy bus-bar zones shall not be isolated. The protection system shall have continuous self-monitoring for both internal and external hardware including software failure and a watchdog contact shall be provided. The arc protection system shall have a master central unit with light and current sensing capability. The system shall be modular allowing for the addition of up to 4 zones.

10.13 AVR - TRANSFORMER AUTOMATIC VOLTAGE REGULATOR

A transformer automatic voltage regulator IED is required to control the MV output voltage i.e. secondary side voltage of a step-down power transformer. The regulator shall constantly compare the actual voltage value and a fixed or load-dependent set-point value and, depending on the deviation, determine the correcting action for the tap changer of the transformer. The regulator parameters shall be optimally adjusted to the dynamic time behaviour of the network voltage to allow for a high control quality at a low number of tap changer switching operations.

All regulators shall be able to control up to six transformers connected in parallel to one busbar without any additional devices. Parallel operation of transformers on one or several bus-bars shall be performed using Master-slave for identical transformers with equal tap change, $\Delta I \sin \phi$ for identical transformers with equal or different tap-changes, $\Delta I \sin \phi (S)$ for transformers with different powers and different or equal tap-changes, or freely switched in parallel using $\Delta \cos \phi$. The regulator shall monitor and record the transformer oil temperature directly via a PT 100 a mA transducer input.

The regulator shall trend, display and record the voltage that is to be regulated over time and the transformer oil temperature. The regulator shall have freely user programmable inputs and outputs. Every regulator shall constantly indicate which reactive current $I \sin \phi$ is being used. The regulator shall have integral user operated controls for placing the device on Auto or Manual mode, and Local or Remote control. All important information (tap-change position, voltage, etc.) shall be displayed on a large backlit LCD screen.

A statistics function shall be provided on the regulator to record the total number of tap-changer switching operations and switching operations per tap. Inputs for tap-changer position shall include potentiometer, mA transducer, and BCD (binary coded decimal). Outputs for tap changer position shall include hard wired mA and BCD.

10.14 STBYEF - STANDBY EARTH FAULT RELAY

A STBYEF IED is required to provide backup earth fault protection for all source downstream equipment as well as provide earth fault backup protection to MV faults of a step-down transformer. The IED shall reject harmonics caused by CT saturation. The STBYEF IED shall also be used for high impedance transformer REF applications by using external series stabilizing resistors and non-linear resistors (Metrosils).

Element	Qty	Type	Curve	Range (xIn)	Time Delay/Time Multiplier
E/F	2	Non Directional	Definite Time	5-80%	0.05 – 1.0
SE/F	1	Non Directional	Definite Time	0.5-30%	0-10000 ms
E/F	2	Non Directional	IDMT (SI, VI, EI)	5-80%	0.05 – 1.0
SE/F	1	Non Directional	IDMT (SI, VI, EI)	0.5-10%	0.05 – 1.0

Table 2: The IED with single element device with functionality.

10.15 LO1 & LO2 & MTR - LOCKOUT RELAY

A LO1 and LO2 lockout relay is required to reinforce the main tripping contact of protection IED's, to prevent the closure of primary devices as well as provide an operational flag indication. A MTR is used for inter-tripping in a local substation environment when dc source isolation is required. The lockout relay output contacts shall be mechanically latched and manually hand reset with a user signed operating flag. The relays shall have a high operating speed and be of the high burden type providing immunity to capacitance discharge in the wiring. The relays shall have an instantaneous cut off contact to break the operating coil circuit once the relay mechanism has completely operated. The relays shall be of the electro-mechanical type.

10.16 TAUX - TRIP AUXILIARY RELAY

A TAUX relay is required to supplement or multiply the main tripping contact of protection IED's, as well as provide an operational flag indication. The relay is also used for inter-tripping in a local substation environment with dc source isolation. The relay output contacts shall be self-resetting and with the user signed operating flag manually hand reset. The relays shall have a high operating speed and be of the high burden type providing immunity to capacitance discharge in the wiring. The relays shall have an economizing element to reduce the operating coil burden once the relay mechanism has completely operated. The relays shall be of the electro-mechanical type.

10.17 ALA - ALARM ANNUNCIATOR

An alarm annunciator is required to supplement the visual alarms provided by the protection IED's via their respective LED's. The alarm annunciator shall be specifically designed for use in high voltage protection panels which normally operate with a battery supplied control voltage. The annunciator shall operate on a normally open contact which closes on fault. On receipt of a closing contact, an appropriate LED shall flash. The LED colour shall be user configurable between red and amber. On acceptance of the alarm, the LED shall go steady. The LED shall stay on until a reset button is pressed. Subsequent alarms shall be recognized, i.e. If there are existing alarms on the system, a new alarm will initiate a flashing LED without affecting existing alarms. The acceptance and reset pushbuttons shall be integral to the annunciator unit. Each alarm LED shall have an integral user configurable label.

10.18 INTSP & INTRP - INTERTRIP SEND AND RECEIVE PILOT WIRE RELAY

An INTSP and INTRP relay is required to send signals between remote stations for protection purposes. Inter-tripping over copper pilot wire using a DC signal is used. Induced AC voltages that could cause false tripping shall be filtered out to enhance this immunity while maintaining high sensitivity to DC voltages. A manually resettable mechanical flag indicator shall be provided on both the send & receive elements of the relay.

10.19 INTSF & INTRF - INTERTRIP SEND AND RECEIVE FIBRE OPTIC RELAY

An INTSF and INTRF relay is required to send signals between remote stations for protection purposes. Inter-tripping over fibre optic cables is used. The relays shall be connected using direct fibre (1310nm Single-Mode, 850nm Multi-Mode fibre) and multiplexed digital links (G.703, V.35, and X.21 interfaces).

It shall be possible to send multiple discreet inter-trip signals over the protection communication channel. Each discreet inter-trip signal shall be clearly indicated on the relay via LED's. The Fibre optic channel shall be continuously monitored with an alarm output contact to increase scheme security.

10.20 MFST – MUTLI FUNCTION SCADA TRANSDUCER

A MFST is required to provide a local substation Remote Terminal Unit (RTU) with signals representing the operating parameters of the electrical network e.g. current, voltage, power, frequency, phase angle etc. The transducer is required to be multi-functional in order to save space within the protection panels. The transducer shall measure three phase unbalanced quantities. The transducer shall have DNP3 and IEC61870 communication protocol outputs to signal each analogue type and range. The physical communication connection terminal shall be of the RS485 type. The transducers shall be pre-configured in the factory as per scheme requirements and further by a user programmable interface.

10.21 DIFFC – CIRCULATING CURRENT RELAY

A DIFFC shall be used to protect short lengths of cables/lines usually situated with a substation boundary where any remote current transformer cabling to the relay does not exceed 50m in length. The DIFFC relay shall actually be a MAINF IED used in a high impedance circulating current differential application with external series stabilizing resistors and non-linear resistors (Metrosils).

10.22 DCVMR – DC VOLTAGE MONITORING RELAY

A DCVMR will be used to monitor the station DC supply. If the station DC drops below a critical threshold level, a trip to the circuit breaker will be issued to protect the primary plant. The relay shall be capable of monitoring an over-voltage or under-voltage condition with a subsequent trip output. The trip output shall be delayed preventing spurious operations. Indication LEDs shall be provided on the relay to show the supply voltage, over/under voltage, timing and active output states. The relay settings shall be tampering proof in the form of password protection or a clear sealable cover.

10.23 MAINFO - MULTI PURPOSE MAIN FEEDER RELAY

The MAINFO relay shall protect the incoming feeders of a substation from over loading and fault currents as well as any downstream equipment. Both directional and non-directional protection is required and therefore the MAINFO shall have the same protection elements as specified for the MAINI.

The IED shall also provide high speed, two-ended, phase segregated current differential protection of overhead lines and underground cables. The differential protection shall be current biased with two adjustable slopes. The IED shall also provide CT ratio correction. The IED's shall be connected using direct fibre (1300nm Single-Mode), or multiplexed digital links (G.703, V.35, and X.21 interfaces). It shall be possible to send multiple discreet inter-trip signals over the protection communication channel. The IED shall have 1A and 5A CT inputs on one device to allow for CT mismatching.

The IED shall monitor the tripping (opening) time of the CB to ensure that they do not exceed adjustable thresholds. The trip time shall be displayed on the IED LCD screen, and an external alarm generated should an adjustable time threshold be exceeded.

10.24 RADIALF - RADIAL FEEDER OVER CURRENT RELAY

The RADIALF relay shall protect the outgoing feeders of a substation from over loading and fault currents as well as any downstream equipment. Only non-directional protection is required and therefore the RADIAL shall have the same non-directional protection elements as specified for the MAINI.

The relay shall monitor the tripping (opening) time of the CB to ensure that they do not exceed adjustable thresholds. The trip time shall be displayed on the IED LCD screen, and an external alarm generated should an adjustable time threshold be exceeded

11 DOCUMENTATION

11.1 A technical product catalogue and two operating manuals shall be provided in hard and soft copies.

11.2 Full detailed dimensions drawings shall be provided.

11.3 A copy of all test reports shall be provided.

11.4 A copy of the proposed maintenance schedules shall be provided in hard and soft copies.

12 MARKING AND LABELLING

12.1 The following information shall appear in legible and indelible marking on the outside of the IED's.

12.1.1 The manufacturer's name or trademark.

12.1.2 Serial number for tracking

12.1.3 Year of manufacturing

13 TRAINING

13.1 The suppliers shall provide comprehensive training courses on the configuration, installation, operation and maintenance of equipment provided.

13.2 The suppliers shall provide technical support on system and equipment queries for the duration of the contract.

14 QUALITY MANAGEMENT

A quality management system/plan shall be set up to assure the quality during manufacture, installation, removal, transportation, and disposal. Guidance on the requirements for a quality management system may be found in the following standards: ISO 9001:2015. The details shall be subject to an agreement between the purchaser and supplier.

15 HEALTH AND SAFETY

A health and safety system/plan shall be set up to ensure proper management and compliance during manufacture, installation, removal, transportation, and disposal. Guidance on the requirements of a health and safety plan shall be found in ISO 45001:2018 standards. The details shall be subject to an agreement between City Power and the Supplier.

16 ENVIRONMENTAL MANAGEMENT

An environmental management system/ plan shall be set up to ensure the proper environmental management and compliance is adhered to during manufacturing, installation, removal, transportation, and disposal. Guidance on the requirements for an environmental management system shall be found in ISO 14001:2015 standards. The details shall be subject to an agreement between City Power and the Supplier. This is to ensure that the asset created conforms to environmental standards and City Power SHERQ Policy.

ANNEXURE A - Bibliography

None

ANNEXURE B - Revision information

DATE	REV. NO.	NOTES
March 2014	0	First issue
March 2015	1	Second issue
May 2018	2	Third issue
		Updated committee members
		Nominative reference; added ENA TS 50-19:2004
		Nominative reference; updated with IEC 60255-26-:2009
		Nominative reference; updated with IEC 61000-4-3 2010
		Nominative reference; updated with IEC 61000-4-8 2009
		Nominative reference; updated with IEC 61000-4-9 2016
		Nominative reference; updated with IEC 60255-26 2013
		Nominative reference; updated with IEC 61000-4-2: 2008
		Nominative reference; updated with IEC 60068-2-2 2007
		Nominative reference; updated with IEC 60255-21-3 1993
		Nominative reference; updated with IEC 60529: 2015
		Clause 10.7: replaced branding with end relay.
		Clause 10.8: replaced branding with end relay.
		Clause 10.23: Added entire clause as a new item.
		Clause 10.24: Added entire clause as a new item.
		Clause 11: Added entire clause as a new item
		Clause 12: Added entire clause as a new item.
		Clause 15: Added entire clause as a new item.
		Annex C: Added new schedules for clauses 10.23, 10.24, as items 24 and 25
		Fourth Issues
February 2023	3	

Added watch dog timer on clause6.

December 20244

Edit Annexure C

Increase I/O requirements.

Increased binary inputs.

Increase Comms requirements.

Removed RS232 from Rear data communication ports.

Rated current added 5A.

Binary and Auxiliary voltage range

Breaker condition monitoring

More than 8 LED's

Multi short auto reclose required.

Password protection requirement

ANNEXURE C - BYCH – TECHNICAL SCHEDULES

Schedule A: Purchaser's specific requirements

Schedule B: Guarantees and technical particulars of equipment offered.

ITEM	DESCRIPTION	SCHEDULE A	SCHEDULE B
1	DESCRIPTION TECHNICAL DETAIL FOR A HV BAY CONTROLLER MAJOR PROTECTION EQUIPMENT (BYCH).		
10.1.1	Manufacturer	State	
10.1.2	Type/Model	State	
	Minimum Functionality		
10.1.3	DigSilent StationWare settings file	State	
10.1.4	Graphical Man-Machine Interface (HMI) with mimic display	Yes	
10.1.5	HMI control of circuit breakers	≥ 2	
10.1.6	HMI control of 2 pole switching devices	≥ 10 devices	
10.1.7	SCADA control of circuit breakers and 2 pole devices	Yes	
10.1.8	Password protection	Yes	
10.1.9	Breaker Fail protection	Yes	
10.1.10	3 stage under frequency protection	Yes	
10.1.11	Breaker condition monitoring	Yes	
10.1.12	User programmable logic	Yes	
10.1.13	Fault waveform recording with a minimum of 4 records	Yes	
10.1.14	Sequential event recording with a minimum of 100 events	Yes	
10.1.15	Multi shot Auto Re-close	Yes	
10.1.16	Trip circuit supervision	Yes	
10.1.17	Synchronizing Check and Energisation Check (Dead Bus /Dead Line included)	Yes	
10.1.18	Integral Local/Remote selector switch	Yes	
10.1.19	Alarm annunciation on HMI and LED's	Yes	
10.1.20	Voltage and Current Measuring Functions	Yes	
10.1.21	3 phase maximum demand power, three phase real power, apparent power and power factor display on LCD.	Yes	
10.1.22	Internal hardware and Software Supervision	Yes	
10.1.23	Minimum Programmable Heavy Duty Tripping Output Relays	≥ 8	
10.1.24	Minimum number of Binary Inputs	≥ 40	
10.1.25	Minimum number of user programmable and configurable indication LED's	≥ 8	
10.1.26	User programmable logic	Yes	
10.1.27	Rear Data Communication ports for remote engineering access DNP3 and IEC61850 via ethernet	Yes	
10.1.28	Front Local Data Communication Port RS232 / USB /RJ45	State	
10.1.29	Internal clock synchronization	Yes	
10.1.30	Relay casing material	Steel or Aluminium	

	DESCRIPTION	SCHEDULE A	SCHEDULE B
	Technical Details		
10.1.31	Number of Voltage Inputs	>=3	
10.1.32	Rated Voltage Input (Un)	110V	
10.1.33	Rated Voltage Withstand: Continuously	State	
10.1.34	Number of Current Inputs	>=4	
10.1.35	Rated Frequency (fn)	50Hz	
10.1.36	Rated Current (In)	1A or 5A	
10.1.37	Thermal Current Withstand: Continuous	State	
10.1.38	Thermal Current Withstand: Continuous rating	State	
10.1.39	Thermal Current Withstand: 1s	State	
10.1.40	Input Impedance: (In = 1A)	State	
10.1.41	Output Contact Rated Voltage	230V ac and dc	
10.1.42	Power/ Signal Contact Thermal Withstand capability: Continuous	State	
10.1.43	Power/ Signal Contact Thermal Withstand capability: 3s	State	
10.1.44	Power/ Signal Contact Thermal Withstand capability: 0.5s	State	
10.1.45	Power Contact Thermal Breaking capability: L/R = 40ms @ 110VDC	State	
10.1.46	Binary Input Voltage Range	30V, 110V or 220V dc	
10.1.47	Rated Auxiliary Supply Voltage	30V, 110V or 220V dc	
10.1.48	Rated Auxiliary Supply Voltage Operation Range	80% - 120%	
10.1.49	CTs terminals connection type	Ring or Flat	
10.1.50	Maximum relay dimensions in mm (width, height, depth)	State	
10.1.51	Maximum Power Consumption	State	
10.1.52	Maximum Power Consumption (VA)	State	

Note: Ticks, Cross [✓, X], Astrick [*], Word [Noted] or TBA ["To Be Advice"] will not be accepted.

Tender Number: _____

Tenderer's Authorised Signatory: _____

Name in block letters

Signature

Full name of company: _____

ANNEXURE C - BYCM – TECHNICAL SCHEDULES

Schedule A: Purchaser's specific requirements

Schedule B: Guarantees and technical particulars of equipment offered

ITEM	DESCRIPTION	SCHEDULE A	SCHEDULE B
10.2	TECHNICAL DETAIL FOR A MV BAY CONTROLLER MAJOR PROTECTION EQUIPMENT (BYCM).		
10.2.1	Manufacturer	State	
10.2.2	Type/Model	State	
	Minimum Functionality		
10.2.3	DigSilent StationWare settings file	State	
10.2.4	SCADA control of circuit breakers and 2 pole devices	Yes	
10.2.5	Password protection	Yes	
10.2.6	Breaker Fail protection	Yes	
10.2.7	3 stage under frequency protection	Yes	
10.2.8	Breaker condition monitoring	Yes	
10.2.9	User programmable logic	Yes	
10.2.10	Fault waveform recording with a minimum of 4 records	Yes	
10.2.11	Sequential event recording with a minimum of 100 events	Yes	
10.2.12	Multi shot Auto Re-close	Yes	
10.2.13	Trip circuit supervision	Yes	
10.2.14	Synchronizing Check and Energisation Check (Dead Bus /Dead Line included)	Yes	
10.2.15	Integral Local/Remote selector switch	Yes	
10.2.16	Alarm annunciation on HMI and LED's	Yes	
10.2.17	Voltage and Current Measuring Functions	Yes	
10.2.18	3 phase maximum demand power, three phase real power, apparent power and power factor display on LCD.	Yes	
10.2.19	Internal hardware and Software Supervision	Yes	
10.2.20	Minimum Programmable Heavy Duty Tripping Output Relays	>=8	
10.2.21	Minimum Programmable Signal Output Relays	10 to 15	
10.2.22	Minimum number of Binary Inputs	>=40	
10.2.23	Minimum number of user programmable and configurable indication LED's	>=8	
10.2.24	User programmable logic	Yes	
10.2.25	Rear Data Communication ports for remote engineering access DNP3 and IEC61850 via ethernet	Yes	
10.2.26	Front Local Data Communication Port RS232 / USB/RJ45	State	
10.2.27	Relay casing material (Steel/ Aluminium)	State	
	Technical Details		
10.2.28	Number of Voltage Inputs	>=4	
10.2.27	Rated Voltage Input (Un)	>=110V	
10.2.28	Rated Voltage Withstand: Continuously	State	
10.2.29	Number of Current Inputs	>=4	

SPECIFICATION FOR PROTECTION RELAYS

REFERENCE

REV

CP_TSSPEC_214**2**

PAGE

21

OF

59

ITEM	DESCRIPTION	SCHEDULE A	SCHEDULE B
10.2.30	Rated Frequency (fn)	50Hz	
10.2.31	Rated Current (In)	1A or 5A	
10.2.32	Thermal Current Withstand: Continuous	State	
10.2.33	Thermal Current Withstand: 1s	State	
10.2.34	Input Impedance: (In = 1A)	State	
10.2.34	Output Contact Rated Voltage:	30/110/230V AC/DC	
10.2.36	Power/ Signal Contact Thermal Withstand capability: Continuous	State	
10.2.37	Power/ Signal Contact Thermal Withstand capability: 3s	State	
10.2.38	Power/ Signal Contact Thermal Withstand capability: 0.5s	State	
10.2.39	Power Contact Thermal Breaking capability: L/R = 40ms @ 110VDC	State	
	Binary Input Voltage Range	30V, 110V or 220V dc	
10.2.40	Rated Auxiliary Supply Voltage	30V, 110V or 220V dc	
10.2.41	Rated Auxiliary Supply Voltage Operation Range	80% - 120%	
10.2.42	CT and VT connection terminal type	Ring or Flat	
10.2.43	Maximum Power Consumption (VA)	State	

Note: Ticks, Cross [√, X], Astrick [*], Word [Noted] or TBA ["To Be Advice"] will not be accepted.

Tender Number: _____

Tenderer's Authorised Signatory: _____
Name in block letters Signature

Full name of company: _____

ANNEXURE C - MAINI – TECHNICAL SCHEDULES

Schedule A: Purchaser's specific requirements

Schedule B: Guarantees and technical particulars of equipment offered

ITEM	DESCRIPTION	SCHEDULE A	SCHEDULE B
10.3	TECHNICAL DETAIL FOR A MULTI PURPOSE MAIN INCOMER OVER CURRENT RELAY (MAINI).		
10.3.1	Manufacturer	State	
10.3.2	Type/Model	State	
	Minimum Functionality		
10.3.3	DigSilent StationWare settings file	State	
10.3.4	Multiple element directional and non-directional over-current protection	Yes	
10.3.5	Multiple element directional and non-directional earth fault protection	Yes	
10.3.6	Sensitive earth fault protection as per table1 Note: This functionality can be provided as a separate relay: if so then– see STBYEF relayand compete STBYEF technical schedule)	Yes	
10.3.7	LCD Display Interface	Yes	
10.3.8	Password protection	Yes	
10.3.9	Breaker Fail protection	Yes	
10.3.10	3 stage under frequency protection	Yes	
10.3.11	Breaker I ² t condition monitoring	Yes	
10.3.12	Internal trip timer (CB opening time) with alarm output (element or logics)	Yes	
10.3.13	Fault waveform recording with a minimum of 4 records	Yes	
10.3.14	Sequential event recording with a minimum of 100 events	Yes	
10.3.15	Multi shot Auto Re-close	Yes	
10.3.16	Trip circuit supervision	Yes	
10.3.17	Synchronizing Check and Energization Check (Dead Bus /Dead Line included)	Yes	
10.3.18	3 phase maximum demand power, three phase real power, apparent power and power factor display on LCD.	Yes	
10.3.19	Internal hardware and Software Supervision	Yes	
10.3.20	Minimum Programmable Heavy Duty Tripping Output Relays	>=8	
10.3.21	Minimum Programmable Signal Output	>=4	
10.3.22	Minimum Number of Binary Inputs	>=40	
10.3.23	Minimum number of user programmable and configurable indication LED's	>=8	

ITEM	DESCRIPTION	SCHEDULE A	SCHEDULE B
10.3.24	User programmable logic	Yes	
10.3.25	Rear Data Communication ports for remote engineering access DNP3 and IEC61850 via ethernet	Yes	
10.3.26	Front Local Data Communication Port RS232 / USB/ RJ45	State	
10.3.27	Internal clock synchronization	Yes	
10.3.28	Relay casing material	Steel or Aluminium	
	Technical Details		
10.3.29	Number of Voltage Inputs	>=3	
10.3.30	Rated Voltage Input (Un)	110V	
10.3.31	Rated Voltage Withstand: Continuously	State	
10.3.32	Number of Current Inputs	>=4	
10.3.33	Rated Frequency (fn)	50Hz	
10.3.34	Rated Current (In)	1A or 5A	
10.3.35	Thermal Current Withstand: Continuous	State	
10.3.36	Thermal Current Withstand: Continuous rating	State	
10.3.37	Thermal Current Withstand: 1s	State	
10.3.38	Input Impedance: (In = 1A)	State	
10.3.39	Output Contact Rated Voltage	230V ac and dc	
10.3.41	Power/ Signal Contact Thermal Withstand capability: Continuous	State	
10.3.42	Power/ Signal Contact Thermal Withstand capability: 3s	State	
10.3.43	Power/ Signal Contact Thermal Withstand capability: 0.5s	State	
10.3.44	Power Contact Thermal Breaking capability: L/R = 40ms @ 110VDC	State	
10.3.45	Binary Input Voltage Range	30V, 110V or 220V dc	
10.3.46	Rated Auxiliary Supply Voltage	30V, 110V or 220V dc	
10.3.47	Rated Auxiliary Supply Voltage Operation Range	80% - 120%	
10.3.48	CTs terminals connection type	Ring or Flat	
10.3.47	Maximum relay dimensions in mm (width, height, depth)	State	
10.3.48	Maximum Power Consumption	State	

Note: Ticks, Cross [✓, X], Astrick [*], Word [Noted] or TBA ["To Be Advice"] will not be accepted.

Tender Number: _____

Tenderer's Authorised Signatory: _____
 Name in block letters Signature

Full name of company: _____

ANNEXURE C - MAINF – TECHNICAL SCHEDULES

Schedule A: Purchaser's specific requirements

Schedule B: Guarantees and technical particulars of equipment offered

ITEM	DESCRIPTION	SCHEDULE A	SCHEDULE B
10.4	TECHNICAL DETAIL FOR A MULTI PURPOSE MAIN FEEDER OVER CURRENT RELAY (MAINF).		
10.4.1	Manufacturer	State	
10.4.2	Type/Model	State	
	Minimum Functionality		
10.4.3	DigSilent StationWare settings file	State	
10.4.4	Multiple element over-current protection	Yes	
10.4.5	Multiple element earth fault protection	Yes	
10.4.6	Sensitive earth fault protection as per table1 Note: This functionality can be provided as a separate relay: if so then– see STBYEF relay and compete STBYEF technical schedule)	Yes	
10.4.7	LCD Display Interface	Yes	
10.4.8	Password protection	Yes	
10.4.9	Breaker Fail protection	Yes	
10.4.10	3 stage under frequency protection	Yes	
10.4.11	Breaker I ² t condition monitoring	Yes	
10.4.12	Internal trip timer (CB opening time) with alarm output (element or logics)	Yes	
10.4.13	Fault waveform recording with a minimum of 4 records	Yes	
10.4.14	Sequential event recording with a minimum of 100 events	Yes	
10.4.15	Multi shot Auto Re-close	Yes	
10.4.16	Trip circuit supervision	Yes	
10.4.17	3 phase current display on LCD.	Yes	
10.4.18	Internal hardware and Software Supervision	Yes	
10.4.19	Minimum Programmable Heavy Duty Tripping Output Relays	>=8	
10.4.20	Minimum Programmable Signal Output Relays	>=4	
10.4.21	Minimum Number of Binary Inputs	>=40	
10.4.22	Minimum number of user programmable and configurable indication LED's	>=8	
10.4.23	User programmable logic	Yes	
10.4.24	Rear Data Communication ports for remote engineering access DNP3 and IEC61850 via ethernet	Yes	
10.4.25	Front Local Data Communication Port RS232 / USB/ RJ 45	State	
10.4.26	Relay casing material	Steel or Aluminium	

ITEM	DESCRIPTION	SCHEDULE A	SCHEDULE B
	Technical Details		
10.4.27	Number of Current Inputs	>=4	
10.4.28	Rated Frequency (fn)	50Hz	
10.4.29	Rated Current (In)	1A or 5A	
10.4.30	Thermal Current Withstand: Continuous	State	
10.4.31	Thermal Current Withstand: Continuous rating	State	
10.4.32	Thermal Current Withstand: 1s	State	
10.4.33	Input Impedance: (In = 1A)	State	
10.4.34	Output Contact Rated Voltage	230V ac and dc	
10.4.35	Power/ Signal Contact Thermal Withstand capability: Continuous	State	
10.4.36	Power/ Signal Contact Thermal Withstand capability: 3s	State	
10.4.37	Power/ Signal Contact Thermal Withstand capability: 0.5s	State	
10.4.38	Power Contact Thermal Breaking capability: L/R = 40ms @ 110VDC	State	
10.4.39	Binary Input Voltage Range	30V or 110 V or 220V dc	
10.4.40	Rated Auxiliary Supply Voltage	30V or 110 or 220V dc	
10.4.41	Rated Auxiliary Supply Voltage Operation Range	80% - 120%	
10.4.42	CTs terminals connection type	Ring or Flat	
10.4.43	Maximum relay dimensions in mm (width, height, depth)	State	
10.4.44	Maximum Power Consumption	State	

Note: Ticks, Cross [✓, X], Astrick [*], Word [Noted] or TBA ["To Be Advice"] will not be accepted.

Tender Number: _____

Tenderer's Authorised Signatory: _____
Name in block letters Signature

Full name of company: _____

ANNEXURE C - PFCR – TECHNICAL SCHEDULES

Schedule A: Purchaser's specific requirements

Schedule B: Guarantees and technical particulars of equipment offered

ITEM	DESCRIPTION	SCHEDULE A	SCHEDULE B
10.5	TECHNICAL DETAIL FOR A CAPACITOR BANK PROTECTION RELAY (PFCR).		
10.5.1	Manufacturer	State	
10.5.2	Type/Model	State	
	Minimum Functionality		
10.5.3	DigSilent StationWare settings file	State	
10.5.4	3 Stage - 3 Phase Over current Protection	Yes	
10.5.5	Ground over current protection	Yes	
10.5.6	Phase over current Protection	Yes	
10.5.7	Phase current unbalance	Yes	
10.5.8	Neutral current unbalance	Yes	
10.5.9	Power elements real and reactive	Yes	
10.5.10	Over/under voltage Protection	Yes	
10.5.11	Over/under Frequency Protection	Yes	
10.5.12	Voltage Differential Protection	Yes	
10.5.13	Current Unbalance Protection	Yes	
10.5.14	Automatic Capacitor Bank Control (Voltage, VAR, PF, etc.)	Yes	
10.5.15	Voltage and Current Measuring Functions	Yes	
10.5.16	Internal hardware and Software Supervision	Yes	
10.5.17	Password protection	Yes	
10.5.18	Breaker Fail protection	Yes	
10.5.19	Minimum Programmable Heavy Duty Output Relays	>=4	
10.5.20	Minimum Programmable Signal Output Relays	>=10	
	Minimum Number of Binary Inputs	>=6	
10.5.21	User programmable logic	Yes	
10.5.22	Minimum number of user programmable and configurable indication LED's	>=8	
10.5.23	Rear Data Communication ports for remote engineering access DNP3 and IEC61850 via ethernet	Yes	
10.5.24	Front Local Data Communication Port RS232 / USB/ RJ45	Yes	
10.5.25	Internal clock synchronization	Yes	
10.5.26	Relay casing material	Steel or Aluminium	
	Technical Details		
10.5.27	Number of Voltage Inputs	>=6	
10.5.28	Rated Voltage (Un)	110V	
10.5.29	Rated Voltage Withstand: Continuously	2 x Un	
10.5.30	Number of Current Inputs	4	

	DESCRIPTION	SCHEDULE A	SCHEDULE B
10.5.31	Rated Frequency (fn)	50Hz	
10.5.32	Rated Current (In)	1A or 5A	
10.5.33	Rated Current of Fifth Element (In)	0.2A/1A/5A	
10.5.34	Thermal Current Withstand: Continuous	State	
10.5.35	Thermal Current Withstand: Continuous for In = 0.2A	State	
10.5.36	Thermal Current Withstand: 1s	State	
10.5.37	Input Impedance: (In = 1A)	State	
10.5.38	Output Contact Rated Voltage	230V AC and DC	
10.5.39	Power/ Signal Contact Thermal Withstand capability: Continuous	State	
10.5.40	Power/ Signal Contact Thermal Withstand capability: 0.5s	State	
10.5.41	Binary Input Voltage Range	30V, 110V or 220V dc	
10.5.42	Rated Auxiliary Supply Voltage	30V, 110V or 220V dc	
10.5.43	Rated Auxiliary Supply Voltage Operation Range	80% - 120%	
10.5.44	Fault waveform recording with a minimum of 4 records	Yes	
10.5.45	Sequential event recording with a minimum of 100 time tagged events	Yes	
10.5.46	CT terminals connection type	Ring or Flat	
10.5.47	Maximum Power Consumption	State	
10.5.48	Maximum Power Consumption (VA)	State	

Note: Ticks, Cross [✓, X], Astrick [*], Word [Noted] or TBA ["To Be Advice"] will not be accepted.

Tender Number: _____

Tenderer's Authorised Signatory: _____
 Name in block letters Signature

Full name of company: _____

ANNEXURE C DIFFO– TECHNICAL SCHEDULES

Schedule A: Purchaser's specific requirements

Schedule B: Guarantees and technical particulars of equipment offered

ITEM	DESCRIPTION	SCHEDULE A	SCHEDULE B
10.6	TECHNICAL DETAIL FOR A FIBER OPTIC LINE DIFFERENTIAL RELAY (DIFFO).		
10.6.1	Manufacturer	State	
10.6.2	Type/Model	State	
	Minimum Functionality		
10.6.3	DigSilent StationWare settings file	State	
10.6.4	Phase segregated current differential protection over fibre	Yes	
10.6.5	Internal CT mismatch correction	Yes	
10.6.6	Internal CT vector compensation	Yes	
10.6.7	Internal inrush current detection	Yes	
10.6.8	LCD Display Interface	Yes	
10.6.9	Password protection	Yes	
10.6.10	Breaker Fail protection	Yes	
10.6.12	Fault waveform recording with a minimum of 4 records	Yes	
10.6.13	Sequential event recording with a minimum of 100 events	Yes	
10.6.14	3 phase current display on LCD.	Yes	
10.6.15	Internal hardware and Software Supervision	Yes	
10.6.16	Minimum Programmable Heavy Duty Tripping Output Relays	>=8	
10.6.17	Minimum Programmable Signal Output Relays	>=4	
10.6.18	Minimum Number of Binary Inputs	>=6	
10.6.19	Minimum number of user programmable and configurable indication LED's	>=8	
10.6.20	User programmable logic	Yes	
10.6.21	Rear Data Communication ports for remote engineering access DNP3 and IEC61850 via ethernet	Yes	
10.6.22	Front Local Data Communication Port RS232 / USB/RJ45	State	
10.6.23	Internal clock synchronization	Yes	
10.6.24	Relay casing material	Steel or Aluminium	
	Technical Details		
10.6.25	Number of Current Inputs	>=4	
10.6.26	Rated Frequency (fn)	50Hz	
10.6.28	Thermal Current Withstand: Continuous	State	
10.6.29	Thermal Current Withstand: 1s	State	
10.6.27	Input Impedance: (In = 1A)	State	
10.6.28	Output Contact Rated Voltage	230V ac and dc	
10.6.30	Power/ Signal Contact Thermal Withstand capability: Continuous	State	
10.6.31	Power/ Signal Contact Thermal Withstand capability: 3s	State	
10.6.32	Power/ Signal Contact Thermal Withstand capability: 0.5s	State	

SPECIFICATION FOR PROTECTION RELAYS

REFERENCE

REV

CP_TSSPEC_214**2**

PAGE

29

OF

59

10.6.33	Power Contact Thermal Breaking capability: L/R = 40ms @ 110VDC	State	
ITEM	DESCRIPTION	SCHEDULE A	SCHEDULE B
10.6.34	Binary Input Voltage Range	30V, 110V or 220V dc	
10.6.35	Rated Auxiliary Supply Voltage	30V, 110V or 220V dc	
10.6.36	Rated Auxiliary Supply Voltage Operation Range	80% - 120%	
10.6.37	CTs terminals connection type	Ring or Flat	
10.6.38	Maximum relay dimensions in mm (width, height, depth)	State	
10.6.39	Maximum Power Consumption	State	

Note: Ticks, Cross [✓, X], Astrick [*], Word [Noted] or TBA ["To Be Advice"] will not be accepted.

Tender Number: _____

Tenderer's Authorised Signatory: _____
Name in block letters Signature

Full name of company: _____

ANNEXURE C - DIFFPV – TECHNICAL SCHEDULES

Schedule A: Purchaser's specific requirements

Schedule B: Guarantees and technical particulars of equipment offered

ITEM	DESCRIPTION	SCHEDULE A	SCHEDULE B
10.7	TECHNICAL DETAIL FOR A PILOT WIRE LINE BALANCED VOLTAGE DIFFERENTIAL RELAY (DIFFPV).		
10.7.1	Manufacturer	State	
10.7.2	Type/Model	State	
	Minimum Functionality		
10.7.3	Current differential protection over copper wire pair	Yes	
10.7.4	Balanced voltage operating principle	Yes	
10.7.5	Compatible with remote end relays.	Yes	
10.7.6	Minimum Heavy Duty Tripping Output Relays	2	
10.7.7	Trip operation flag	Yes	
10.7.8	Relay casing material	Steel or Aluminium	
	Technical Details		
10.7.9	Operating time at 10 x In	< 100ms	
10.7.10	Number of Current Inputs	>=4	
10.7.11	Rated Frequency (fn)	50Hz	
10.7.12	Rated Current (In)	1A or 5A	
10.7.13	Thermal Current Withstand: Continuous	State	
10.7.14	Thermal Current Withstand: 0.5s	State	
10.7.15	Input Impedance: (In = 1A)	State	
10.7.16	50 Hz insulation level	4kV	
10.7.17	Output Contact Rated Voltage	230V ac and dc	
10.7.18	Power Contact Thermal Withstand capability: Continuous	State	
10.7.19	CT terminals connection type	Ring or Flat	
10.7.20	Maximum relay dimensions in mm (width, height, depth)	State	

Note: Ticks, Cross [✓, X], Astrick [*], Word [Noted] or TBA ["To Be Advice"] will not be accepted.

Tender Number: _____

Tenderer's Authorised Signatory: _____
Name in block letters Signature

Full name of company: _____

ANNEXURE C - PWSRV – TECHNICAL SCHEDULES

Schedule A: Purchaser's specific requirements

Schedule B: Guarantees and technical particulars of equipment offered

ITEM	DESCRIPTION	SCHEDULE A	SCHEDULE B
10.7.21	TECHNICAL DETAIL FOR A PILOT WIRE SUPERVISION RELAY (PWSRV) FOR THE LINE BALANCED VOLTAGE DIFFERENTIAL RELAY (DIFFPV).		
10.7.22	Manufacturer	State	
10.7.23	Type/Model	State	
	Minimum Functionality		
10.7.24	Supervision of ac circuit copper wire pair (pilot circuit) interconnecting protective relays	Yes	
10.7.25	Pilot circuit insulation	5kV	
10.7.26	DC injection method	Yes	
10.7.27	Compatible with remote end relay	Yes	
10.7.28	Minimum Alarm Output Relays	>=2	
10.7.29	Alarm flag for pilot short-circuit	Yes	
10.7.30	Alarm flag for pilot open-circuit	Yes	
10.7.31	Alarm and indication of power supply failure	Yes	
10.7.32	Relay casing material	Steel or Aluminium	
	Technical Details		
10.7.33	AC supervision voltage Vn	30V, 110V or 220V dc	
10.7.34	DC auxiliary voltage	30V, 110V or 220V dc	
10.7.35	Rated Frequency (fn)	50Hz	
10.7.36	Range of pilot loop resistance	0 to 10kΩ	
10.7.37	Allowable continuous ac pilot current	50mA	
10.7.38	Allowable short time ac pilot current	1500mA	
10.7.39	Output Contact Rated Voltage	250V AC/DC	
10.7.40	Output Contact Continuous rating	5A AC/DC	
10.7.41	Output Contact Break rating	25W, L/R = 0.04s	
10.7.42	All terminals connection type	Ring	
10.7.43	AC power consumption	State	
10.7.44	DC power consumption	State	
10.7.45	Maximum relay dimensions in mm (width, height, depth)	State	

Note: Ticks, Cross [✓, X], Astrick [*], Word [Noted] or TBA ["To Be Advice"] will not be accepted.

Tender Number: _____

Tenderer's Authorised Signatory: _____
Name in block letters Signature

Full name of company: _____

ANNEXURE C - DIFFPI – TECHNICAL SCHEDULES

Schedule A: Purchaser's specific requirements

Schedule B: Guarantees and technical particulars of equipment offered

ITEM	DESCRIPTION	SCHEDULE A	SCHEDULE B
10.8	TECHNICAL DETAIL FOR A PILOT WIRE LINE BALANCED CURRENT DIFFERENTIAL RELAY (DIFFPI).		
10.8.1	Manufacturer	State	
10.8.2	Type/Model	State	
10.8.3	Minimum Functionality		
10.8.4	Current differential protection over copper wire pair	Yes	
10.8.5	Balanced voltage operating principle	Yes	
10.8.6	Compatible with remote end relay	Yes	
10.8.7	Minimum Heavy Duty Tripping Output Relays	2	
10.8.8	Relay casing material	Steel or Aluminium	
10.8.9	Technical Details		
10.8.10	Operating time at 10 x In	< 100ms	
10.8.11	Number of Current Inputs	>=4	
10.8.12	Rated Frequency (fn)	50Hz	
10.8.13	Rated Current (In)	1A or 5A	
10.8.14	Thermal Current Withstand: Continuous	State	
10.8.15	Thermal Current Withstand: 0.5s	State	
10.8.16	Input Impedance: (In = 1A)	State	
10.8.17	50 Hz insulation level	5kV	
10.8.18	Output Contact Rated Voltage	230V ac and dc	
10.8.19	Power Contact Thermal Withstand capability: Continuous	State	
10.8.20	CT terminals connection type	Ring or Flat	
10.8.21	Maximum relay dimensions in mm (width, height, depth)	State	

Note: Ticks, Cross [✓, X], Astrick [*], Word [Noted] or TBA ["To Be Advice"] will not be accepted.

Tender Number: _____

Tenderer's Authorised Signatory: _____
Name in block letters Signature

Full name of company: _____

ANNEXURE C - PWSRI – TECHNICAL SCHEDULES

Schedule A: Purchaser's specific requirements

Schedule B: Guarantees and technical particulars of equipment offered

ITEM	DESCRIPTION	SCHEDULE A	SCHEDULE B
	TECHNICAL DETAIL FOR A PILOT WIRE SUPERVISION RELAY (PWSRI) FOR THE LINE BALANCED CURRENT DIFFERENTIAL RELAY (DIFFPI).		
10.8.22	Manufacturer	State	
10.8.23	Type/Model	State	
	Minimum Functionality		
10.8.24	Supervision of ac circuit copper wire pair (pilot circuit) interconnecting protective relays	Yes	
10.8.25	Pilot circuit insulation	5kV	
10.8.26	DC injection method	Yes	
10.8.27	Compatible with remote end relay	Yes	
10.8.28	Minimum Alarm Output Relays	2	
10.8.29	Alarm flag for pilot short-circuit	Yes	
10.8.30	Alarm flag for pilot open-circuit	Yes	
10.8.31	Alarm and indication of power supply failure	Yes	
10.8.32	Relay casing material	Steel or Aluminium	
	Technical Details		
10.8.33	AC supervision voltage Vn	110V or 220V	
10.8.34	DC auxiliary voltage	32 or 110V	
10.8.35	Rated Frequency (fn)	50Hz	
10.8.36	Range of pilot loop resistance	0 to 10kΩ	
10.8.37	Allowable continuous ac pilot current	50mA	
10.8.38	Allowable short time ac pilot current	1500mA	
10.8.39	Output Contact Rated Voltage	250V AC/DC	
10.8.40	Output Contact Continuous rating	5A AC/DC	
10.8.41	CT terminals connection type	Ring or Flat	
10.8.42	AC power consumption	State	
10.8.43	DC power consumption	State	
10.8.44	Maximum relay dimensions in mm (width, height, depth)	State	

Note: Ticks, Cross [✓, X], Astrick [*], Word [Noted] or TBA ["To Be Advice"] will not be accepted.

Tender Number: _____

Tenderer's Authorised Signatory: _____
Name in block letters Signature

Full name of company: _____

ANNEXURE C - DIFFT – TECHNICAL SCHEDULES

Schedule A: Purchaser's specific requirements

Schedule B: Guarantees and technical particulars of equipment offered

ITEM	DESCRIPTION	SCHEDULE A	SCHEDULE B
9	TECHNICAL DETAIL FOR A TRANSFORMER DIFFERENTIAL RELAY (DIFFT).		
10.9.1	Manufacturer	State	
10.9.2	Type	State	
	Minimum Functionality		
10.9.3	DigSilent StationWare settings file	State	
10.9.4	Integrated Two Winding Differential restrained and unrestrained protection	Yes	
10.9.5	Restricted Earth Fault Functions suitable for star (Y) and auto-transformers	Yes	
10.9.6	Under voltage protection	Yes	
10.9.7	Over/under frequency protection	Yes	
10.9.8	Neutral over current protection	Yes	
10.9.9	Second Harmonic Restraint for Transformer Inrush	Yes	
10.9.10	Fifth Harmonic Restraint with Adjustable Deactivation Level	Yes	
10.9.11	Internal CT Ratio Correction and Vector Group Matching	Yes	
10.9.12	Phase Current and Angle Display to Confirm Vector Group matching	Yes	
10.9.13	Earth fault current vector display to confirm restricted earth fault stability	Yes	
10.9.14	Fault recording with a minimum of 4 waveform records	Yes	
10.9.15	Sequential event recording with a minimum of 100 time tagged events	Yes	
10.9.16	Over-fluxing Protection V/F	Yes	
10.9.17	User configurable Indication LEDs	>=8	
10.9.18	Voltage and Current Measuring Functions	Yes	
10.9.19	Internal hardware and Software Supervision	Yes	
10.9.20	Minimum Programmable Heavy Duty Output Relays	>=4	
10.9.21	Minimum Programmable Signal Output Relays	>=5	
10.9.22	Minimum Number of Binary Inputs	>=20	
10.9.23	Minimum Number of Indication LED's	>=8	
10.9.24	Rear Data Communication ports for remote engineering access DNP3 and IEC61850 via ethernet	Yes	
10.9.25	Relay casing material	Steel or Aluminium	
10.9.26	Internal hardware and Software Supervision	Yes	

ITEM	DESCRIPTION	SCHEDULE A	SCHEDULE B
	Technical Details		
10.9.27	Password protection	Yes	
10.9.28	Breaker Fail protection	Yes	
10.9.29	Number of Voltage Inputs	>=4	
10.9.30	Rated Voltage (Un)	110V	
10.9.31	Rated Voltage Withstand: Continuously	State	
10.9.32	Number of phase current Inputs	>=6	
10.9.33	Number of neutral current Inputs	>=2	
10.9.34	Rated Frequency (fn)	50Hz	
10.9.35	Rated Current of phase elements (In)	1A or 5A	
10.9.36	Rated Current of Neutral Elements (In)	1A or 5A	
10.9.37	Thermal Current Withstand: Continuous	State	
10.9.38	Thermal Current Withstand: Continuous rating	State	
10.9.39	Thermal Current Withstand: 1s	State	
10.9.40	Input Impedance: (In = 1A)	State	
10.9.41	Output Contact Rated Voltage	230V ac and dc	
10.9.42	Power/ Signal Contact Thermal Withstand capability: Continuous	State	
10.9.43	Power/ Signal Contact Thermal Withstand capability: 0.5s	State	
10.9.44	Binary Input Voltage Range	30V, 110V or 220V dc	
10.9.45	Rated Auxiliary Supply Voltage	30V, 110V or 220V dc	
10.9.46	Rated Auxiliary Supply Voltage Operation Range	80% - 120%	
10.9.47	CTs terminals connection type	Ring or Flat	
10.9.48	Maximum Power Consumption	State	
10.9.49	Internal clock synchronization	Yes	
10.9.50	MAXIMUM Power Consumption	State	

Note: Ticks, Cross [✓, X], Astrick [*], Word [Noted] or TBA ["To Be Advice"] will not be accepted.

Tender Number: _____

Tenderer's Authorised Signatory: _____
 Name in block letters Signature

Full name of company: _____

ANNEXURE C - DIFFZ – TECHNICAL SCHEDULES

Schedule A: Purchaser's specific requirements

Schedule B: Guarantees and technical particulars of equipment offered

ITEM	DESCRIPTION	SCHEDULE A	SCHEDULE B
10	TECHNICAL DETAIL FOR A LINE IMPEDANCE AND DIFFERENTIAL RELAY (DIFFZ).		
10.10.1	Manufacturer	State	
10.10.2	Type	State	
	Minimum Functionality		
10.10.3	DigSilent StationWare settings file	State	
10.10.4	Phase Segregated Differential protection	Yes	
10.10.5	Single Mode 1310nm fibre optic connections	Yes	
10.10.6	4 Zone Phase Fault Impedance Protection	Yes	
10.10.7	4 Zone Earth Fault Impedance Protection	Yes	
10.10.8	Switch onto Fault Protection	Yes	
10.10.9	Phase and neutral over current protection	Yes	
10.10.10	Fault location	Yes	
10.10.11	Phase and neutral Negative Sequence current protection	Yes	
10.10.12	Sensitive earth fault protection	Yes	
10.10.13	Inter-trip Commands Across Communication Channel	Yes	
10.10.14	Communications assisted distance schemes	Yes	
10.10.15	Fuse Fail Supervision	Yes	
10.10.16	Primary Service Value Display	Yes	
10.10.17	CT saturation detection	Yes	
10.10.18	Internal CT Ratio Correction	Yes	
10.10.19	Phase Current and Angle Display	Yes	
10.10.20	Circuit Breaker Fail Protection	Yes	
10.10.21	Fault recording with a minimum of 4 waveform records	Yes	
10.10.22	Sequential event recording with a minimum of 100 events	Yes	
10.10.23	Internal Hardware and Software Supervision	Yes	
10.10.24	Minimum Programmable Heavy Duty Tripping Output Relays	>=4	
10.10.25	Minimum Programmable Signal Output Relays	>=10	
10.10.26	Minimum Number of Binary Inputs	>=5	
10.10.27	Minimum Number of Indication LED's	>=8	
10.10.28	Maximum Relay Trip Operating Time	< 20 ms	
10.10.29	User programmable logic	Yes	
10.10.30	Rear Data Communication ports for remote engineering access DNP3 and IEC61850 via ethernet	Yes	
10.10.31	Front Local Data Communication Port RS232 / USB /RJ45	Yes	
10.10.32	Internal clock synchronization	Yes	
10.10.33	Relay casing material	Steel or Aluminium	
	Technical Details		
10.10.34	Rated Current (In)	1A	
10.10.35	Phase impedance protection characteristic	Mho	
10.10.36	Ground impedance protection characteristic	Mho and Quadrilateral	

	DESCRIPTION	SCHEDULE A	SCHEDULE B
10.10.37	Phase and Neutral over current protection curves	IEC SI, VI, EI	
10.10.38	Thermal Current Withstand: Continuous	State	
10.10.39	Thermal Current Withstand: 10s	State	
10.10.40	Thermal Current Withstand: 1s	State	
10.10.41	CT Input Impedance: (In = 1A)	State	
10.10.42	Output Contact Rated Voltage	230V ac and dc	
10.10.43	Power/ Signal Contact Thermal Withstand capability: Continuous	State	
10.10.44	Power/ Signal Contact Thermal Withstand capability: 1s	State	
10.10.45	Power Contact Thermal Breaking capability: L/R = 40ms @ 110VDC	State	
10.10.46	Binary Input Voltage Range	30V, 110V or 220V dc	
10.10.47	Rated Auxiliary Supply Voltage	30V, 110V or 220V dc	
10.10.48	Rated Auxiliary Supply Voltage Operation Range	80% - 120%	
10.10.49	CT terminals connection type	Ring or Flat	
10.10.50	Maximum Power Consumption	State	

Note: Ticks, Cross [√, X], Astrick [*], Word [Noted] or TBA ["To Be Advice"] will not be accepted.

Tender Number: _____

Tenderer's Authorised Signatory: _____

Name in block letters Signature

Full name of company: _____

ANNEXURE C - DIFFB – TECHNICAL SCHEDULES

Schedule A: Purchaser's specific requirements

Schedule B: Guarantees and technical particulars of equipment offered

ITEM	DESCRIPTION	SCHEDULE A	SCHEDULE B
11	TECHNICAL DETAIL FOR A BUSBAR DIFFERENTIAL RELAY (DIFFB).		
10.11.1	Manufacturer	State	
10.11.2	Type	State	
	Minimum Functionality		
10.11.3	DigSilent StationWare settings file	State	
10.11.4	Low impedance (Numerical) type	Yes	
10.11.5	3 Phase segregated differential protection	Yes	
10.11.6	Stub bus (end zone) protection	Yes	
10.11.7	Phase current and angle comparison	Yes	
10.11.8	Selective zone tripping	Yes	
10.11.9	Automatic zone selection	Yes	
10.11.10	Breaker failure protection	Yes	
10.11.11	Minimum tripping time	< 20 ms	
10.11.12	Number of Zones	4 main + 1 check zone	
10.11.13	Number of Circuit Breakers in a Zone	1 to 19	
10.11.14	Current Transformer Supervision	Yes	
10.11.15	CT saturation detection	Yes	
10.11.16	Internal CT Ratio Correction	Yes	
10.11.17	Phase Current and Angle Display	Yes	
10.11.18	Circuit Breaker Fail Protection	Yes	
10.11.19	Fault recording with a minimum of 4 waveform records	Yes	
10.11.20	Sequential event recording with a minimum of 100 events	Yes	
10.11.21	Internal Hardware and Software Supervision	Yes	
10.11.22	Heavy Duty Trip Output Relays	>=3 per circuit breaker	
10.11.23	Programmable Signal Output Relays	>=10	
10.11.24	Binary Inputs	State	
10.11.25	User programmable logic	Yes	
10.11.26	Rear Data Communication ports for remote engineering access DNP3 and IEC61850 via ethernet	Yes	
10.11.27	Front Local Data Communication Port RS232 / USB/ RJ45	Yes	
10.11.28	Internal clock synchronization	Yes	
10.11.29	Relay casing material	Steel or Aluminium	

	DESCRIPTION	SCHEDULE A	SCHEDULE B
10.11.30	Technical Details		
10.11.31	Rated Current (In)	1A	
10.11.32	Thermal Current Withstand: Continuous	State	
10.11.33	Thermal Current Withstand: 10s	State	
10.11.34	Thermal Current Withstand: 1s	State	
10.11.35			
10.11.36	CT Input Impedance: (In = 1A)	State	
10.11.37	Output Contact Rated Voltage	230V ac/dc	
10.11.38	Power/ Signal Contact Thermal Withstand capability: Continuous	State	
10.11.39	Power/ Signal Contact Thermal Withstand capability: 1s	State	
10.11.40	Power Contact Thermal Breaking capability: L/R = 40ms @ 110VDC	State	
10.11.41	Binary Input Voltage Range	30, 110 or 220 V dc	
10.11.42	Rated Auxiliary Supply Voltage	30, 110 or 220 V dc	
10.11.43	Rated Auxiliary Supply Voltage Operation Range	80% - 120%	
10.11.44	CT terminals connection type	Ring or Flat	
10.11.45	Maximum Power Consumption	State	

Note: Ticks, Cross [√, X], Astrick [*], Word [Noted] or TBA ["To Be Advice"] will not be accepted.

Tender Number: _____

Tenderer's Authorised Signatory: _____
 Name in block letters Signature

Full name of company: _____

ANNEXURE C - ARCP – TECHNICAL SCHEDULES

Schedule A: Purchaser's specific requirements

Schedule B: Guarantees and technical particulars of equipment offered

ITEM	DESCRIPTION	SCHEDULE A	SCHEDULE B
12	TECHNICAL DETAIL FOR AN ARC PROTECTION RELAY (ARCP).		
10.12.1	Manufacturer	State	
10.12.2	Type	State	
	Minimum Functionality		
10.12.3	Operation on simultaneous current and light	Yes	
10.12.4	Master unit current sensing with information sent over communication channel to slave units	Yes	
10.12.5	Individual metal-clad switchgear cable chamber tripping	Yes	
10.12.6	3-phase current measurement or 2-phase and earth-fault current measurement	Yes	
10.12.7	Continuous self-supervision of sensor loop, operating voltages and cabling between central units and extension units		
10.12.8	Circuit Breaker Fail Protection	Yes	
10.12.9	Internal Hardware and Software Supervision	Yes	
10.12.10	Minimum Heavy Duty Tripping Output Relays per zone	>=3	
10.12.11	Maximum Trip Operating Time	< 10 ms	
10.12.12	Relay casing material	Steel or Aluminium	
	Technical Details		
10.12.13	Number of Current Inputs	3	
10.12.14	Rated Frequency (fn)	50Hz	
10.12.15	Rated Current (In)	1A or 5A	
10.12.16	Thermal Current Withstand: 1s	State	
10.12.17	Input Impedance: (In = 1A)	State	
10.12.18	Output Contact Rated Voltage	230V ac/dc	
10.12.19	Trip Contact Thermal Withstand capability: 3s	State	
10.12.20	Rated Auxiliary Supply Voltage	30V, 110V or 220V dc	
10.12.21	Rated Auxiliary Supply Voltage Operation Range	80% - 120%	
10.12.22	CT terminals connection type	Ring or Flat	
10.12.23	Maximum Power Consumption	State	

Note: Ticks, Cross [✓, X], Astrick [*], Word [Noted] or TBA ["To Be Advice"] will not be accepted.

Tender Number: _____

Tenderer's Authorised Signatory: _____
Name in block letters Signature

Full name of company: _____

ANNEXURE C - AVR – TECHNICAL SCHEDULES

Schedule A: Purchaser's specific requirements

Schedule B: Guarantees and technical particulars of equipment offered

ITEM	DESCRIPTION	SCHEDULE A	SCHEDULE B
13	TECHNICAL DETAIL FOR A TRANSFORMER AUTOMATIC VOLTAGE REGULATOR (AVR).		
10.13.1	Manufacturer	State	
10.13.2	Type	State	
	Minimum Functionality		
10.13.3	DigSilent StationWare settings file	State	
10.13.4	Three Phase Over-current and Under-voltage Blocking	Yes	
10.13.5	Line Voltage Drop Compensation	Yes	
10.13.6	Tap Position Indication	Yes	
10.13.7	Transformer Paralleling Control.	Yes	
10.13.8	Ohm, BCD, mA tap-changer inputs	Yes	
10.13.9	Local and remote Tap Change Control	Yes	
10.13.10	Definite and Inverse Time Voltage Control Characteristic	Yes	
10.13.11	External Blocking Input	Yes	
10.13.12	User programmable logic	Yes	
10.13.13	Minimum Number of Indication LED's	>=8	
10.13.14	Minimum Programmable Signal Output Relays	>=4	
10.13.15	Minimum Number of Binary Inputs	>=6	
10.13.16	Rear Data Communication ports for remote engineering access DNP3 and IEC61850 via ethernet	State	
10.13.17	Front Local Data Communication Port RS232 / USB/ RJ45	State	
10.13.18	Internal clock synchronization -	State	
10.13.19	Relay casing material	Steel or Aluminium	
10.13.20	Internal hardware and Software Supervision	Yes	
	Technical Details		
10.13.21	Selectable Voltage Input (Un)	110V	
10.13.22	Continuous Voltage Withstand	State	
10.13.23	Rated Frequency (fn)	50Hz	
10.13.24	Rated Current (In)	1A or 5A	
10.13.25	Thermal Current Withstand: Continuous	State	
10.13.26	Thermal Current Withstand: 10s	State	

ITEM	DESCRIPTION	SCHEDULE A	SCHEDULE B
10.13.27	Thermal Current Withstand: 1s	State	
10.13.28	Input Impedance: (In = 1A)	State	
10.13.29	Output Contact Rated Voltage	230V ac/dc	
10.13.30	Control/ Signal Contact Thermal Withstand capability: Continuous	State	
10.13.31	Control/ Signal Contact Thermal Withstand Capability: 3s	State	
10.13.32	Control/ Signal Contact Thermal Withstand Capability: 0.5s	State	
10.13.33	Binary Input Voltage Range	30V, 110V or 220V dc	
10.13.34	Rated Auxiliary Supply Voltage	30V, 110V or 220V dc	
10.13.35	Rated Auxiliary Supply Voltage Operation Range	80% - 120%	
10.13.36	Maximum Power Consumption	State	

Note: Ticks, Cross [✓, X], Astrick [*], Word [Noted] or TBA ["To Be Advice"] will not be accepted.

Tender Number: _____

Tenderer's Authorised Signatory: _____
Name in block letters Signature

Full name of company: _____

ANNEXURE C - STBYEF – TECHNICAL SCHEDULES

Schedule A: Purchaser's specific requirements

Schedule B: Guarantees and technical particulars of equipment offered

ITEM	DESCRIPTION	SCHEDULE A	SCHEDULE B
14	TECHNICAL DETAIL FOR STRANDBY EARTH FAULT RELAY (STBYEF).		
10.14.1	Manufacturer	State	
10.14.2	Type	State	
	Minimum Functionality		
10.14.3	DigSilent StationWare settings file	State	
10.14.4	EF and SEF over current protection	Yes	
10.14.5	Internal hardware and Software Supervision	Yes	
10.14.6	Minimum Programmable Heavy Duty Output Relays	>=2	
10.14.7	Minimum Programmable Signal Output Relays	>=2	
10.14.8	Minimum Number of Binary Inputs	>=2	
10.14.9	User programmable logic	Yes	
10.14.10	Minimum Number of Indication LED's	>=2	
10.14.11	Rear Data Communication ports for remote engineering access DNP3 and IEC61850 via ethernet	Yes	
10.14.12	Front Local Data Communication Port RS232 / USB/ RJ45	Yes	
10.14.13	Internal clock synchronization	Yes	
10.14.14	Relay casing material	Steel or Aluminium	
10.14.15	Internal hardware and Software Supervision	Yes	
	Technical Details		
10.14.16	Password protection	Yes	
10.14.17	Rated Current (In)	1A or 5A	
10.14.18	SEF Element (In) in accordance with table2	Yes	
10.14.19	Thermal Current Withstand: Continuous	State	
10.14.20	Thermal Current Withstand: Continuous for SEF input	State	
10.14.21	Thermal Current Withstand: 1s	State	
10.14.22	Input Impedance: (In = 1A)	State	
10.14.23	Output Contact Rated Voltage	230V ac/dc	
10.14.24	Power/ Signal Contact Thermal Withstand capability: Continuous	State	

SPECIFICATION FOR PROTECTION RELAYS

REFERENCE

REV

CP_TSSPEC_214**2**

PAGE

44

OF

59

ITEM	DESCRIPTION	SCHEDULE A	SCHEDULE B
10.14.25	Power/ Signal Contact Thermal Withstand capability: 0.5s	State	
10.14.26	Binary Input Voltage Range	30V or 110 or 220V dc	
10.14.27	Rated Auxiliary Supply Voltage	30V or 110 or 220V dc	
10.14.28	Rated Auxiliary Supply Voltage Operation Range	80% - 120%	
10.14.29	Fault recording with a minimum of 4 waveform records	Yes	
10.14.30	Sequential event recording with a minimum of 100 time tagged events	Yes	
10.14.31	CTs terminals connection type	Ring or Flat	
10.14.32	Maximum Power Consumption	State	

Note: Ticks, Cross [✓, X], Astrick [*], Word [Noted] or TBA ["To Be Advice"] will not be accepted.

Tender Number: _____

Tenderer's Authorised Signatory: _____
Name in block letters Signature

Full name of company: _____

ANNEXURE C – LO1 & LO2 & MTR – TECHNICAL SCHEDULES

Schedule A: Purchaser's specific requirements

Schedule B: Guarantees and technical particulars of equipment offered

ITEM	DESCRIPTION	SCHEDULE A	SCHEDULE B
15	TECHNICAL DETAIL FOR A LOCKOUT AND MASTER TRIP (LO1 & LO2 & MTR) ELECTROMECHANICAL RELAY		
10.15.1	Manufacturer	State	
10.15.2	Type	State	
	Minimum Functionality		
10.15.3	Mechanically Latched contacts	Yes	
10.15.4	Flagged Indication	Yes	
10.15.5	Hand Reset contacts	Yes	
10.15.6	Number of Power Normally open Contacts	>=3	
10.15.7	Number of Power Normally closed Contacts	>=3	
10.15.8	Instantaneous coil break contact	Yes	
	Technical Details		
10.15.9	Maximum Operation time	State	
10.15.10	Rated Supply Voltage	30V or 110V or 220V dc	
10.15.11	Rated Supply Voltage Operation Range	80% - 120%	
10.15.12	Output Contact Rated Voltage	230V ac/dc	
10.15.13	Contact dc current continuous capability	State	
10.15.14	Contact dc current 3 second capability	State	
10.15.15	Contact dc current Breaking capability: resistive/inductive	State	
10.15.16	Capacitive discharge immunity	State	
10.15.17	CTs terminals connection type	Ring or Flat	
10.15.18	Maximum Power Consumption	State	
10.15.19	Maximum relay dimensions in mm (width, height, depth)	State	

Note: Ticks, Cross [✓, X], Astrick [*], Word [Noted] or TBA ["To Be Advice"] will not be accepted.

Tender Number: _____

Tenderer's Authorised Signatory: _____
Name in block letters Signature

Full name of company: _____

ANNEXURE C – TAUX – TECHNICAL SCHEDULES

Schedule A: Purchaser's specific requirements

Schedule B: Guarantees and technical particulars of equipment offered

ITEM	DESCRIPTION	SCHEDULE A	SCHEDULE B
16	TECHNICAL DETAIL FOR A TRIP AUXILIARY RELAY (TAUX).		
10.16.1	Manufacturer	State	
10.16.2	Type	State	
	Minimum Functionality		
10.16.3	Flagged Indication hand reset	Yes	
10.16.4	Self - Reset contacts	Yes	
10.16.5	Number of Power Normally open Contacts	>=10	
10.16.6	High burden	Yes	
	Technical Details		
10.16.7	Maximum Operation time	<15ms	
10.16.8	Rated Supply Voltage	30/110/220V dc	
10.16.9	Rated Supply Voltage Operation Range	80% - 120%	
10.16.10	Output Contact Rated Voltage	230V ac/dc	
10.16.11	Contact dc current continuous capability	State	
10.16.12	Contact dc current 3 second capability	State	
10.16.13	Contact dc current Breaking capability: resistive/inductive	State	
10.16.14	Capacitive discharge immunity	State	
10.16.15	CT terminals connection type	Ring or Flat	
10.16.16	Maximum relay dimensions in mm (width, height, depth)	State	
10.16.17	Maximum Power Consumption	State	

Note: Ticks, Cross [✓, X], Astrick [*], Word [Noted] or TBA ["To Be Advice"] will not be accepted.

Tender Number: _____

Tenderer's Authorised Signatory: _____

Name in block letters

Signature

Full name of company: _____

ANNEXURE C – ALA – TECHNICAL SCHEDULES

Schedule A: Purchaser's specific requirements

Schedule B: Guarantees and technical particulars of equipment offered

ITEM	DESCRIPTION	SCHEDULE A	SCHEDULE B
17	TECHNICAL DETAIL FOR AN ALARM ANNUNCIATOR (ALA).		
10.17.1	Manufacturer	State	
10.17.2	Type	State	
	Minimum Functionality		
10.17.3	Programmable NO / NC Alarm channel activation	Yes	
10.17.4	Integral user configurable alarm labels	Yes	
	Technical Details		
10.17.5	Minimum Number of Alarm Inputs	>=8	
10.17.6	Minimum Number of Alarm LED's	>=8	
10.17.7	Binary Input Voltage Range	30V/ 110/ 220V dc	
10.17.8	Rated Supply Voltage	30V/ 110/ 220V dc	
10.17.9	Rated Supply Voltage Operation Range	80% - 120%	
10.17.10	Maximum unit dimensions in mm (width, height, depth)	State	
10.17.11	CT terminal connection type	Ring or Flat	
10.17.12	Maximum Power Consumption	State	

Note: Ticks, Cross [✓, X], Astrick [*], Word [Noted] or TBA ["To Be Advice"] will not be accepted.

Tender Number: _____

Tenderer's Authorised Signatory: _____
Name in block letters Signature

Full name of company: _____

ANNEXURE C – INTSP and INTRP – TECHNICAL SCHEDULES

Schedule A: Purchaser's specific requirements

Schedule B: Guarantees and technical particulars of equipment offered

ITEM	DESCRIPTION	SCHEDULE A	SCHEDULE B
18	TECHNICAL DETAIL FOR AN INTERTRIP SEND AND RECEIVE PILOT WIRE RELAY (INTSP and INTRP).		
10.18.1	Manufacturer	State	
10.18.2	Type	State	
	Minimum Functionality		
10.18.3	Insulation rating	15kV RMS	
10.18.4	Impulse rating	1.2/50 5kV	
10.18.5	AC immunity of receive element	300V @ 50Hz	
10.18.6	Operate time at nominal DC voltage	<30ms	
10.18.7	Hand reset operation flag annunciation	Yes	
10.18.8	Minimum Heavy Duty Tripping Output contacts (self- reset)	4	
10.18.9	Relay casing material	Steel or Aluminium	
	Technical Details		
10.18.10	Rated Frequency (fn)	50Hz	
10.18.11	Output Contact Rated Voltage	230V ac/dc	
10.18.12	Contact Thermal Withstand capability: Continuous	State	
10.18.13	Contact Thermal Withstand capability: 0.5s	State	
10.18.14	Contact Thermal Breaking capability: L/R = 40ms @ 125VDC	State	
10.18.15	Binary Input Voltage Range	30V/ 110V/ 220 DC	
10.18.16	Rated Auxiliary Supply Voltage	30V/ 110V/ 220 DC	
10.18.17	Rated Auxiliary Supply Voltage Operation Range	80% - 120%	
10.18.18	CT terminal connection type	Ring or Flat	
10.18.19	Maximum Power Consumption	State	
10.18.20	Maximum relay dimensions in mm (width, height, depth)	State	

Note: Ticks, Cross [✓, X], Astrick [*], Word [Noted] or TBA ["To Be Advice"] will not be accepted.

Tender Number: _____

Tenderer's Authorised Signatory: _____

Name in block letters

Signature

Full name of company: _____

ANNEXURE C – INTSF and INTRF – TECHNICAL SCHEDULES

Schedule A: Purchaser's specific requirements

Schedule B: Guarantees and technical particulars of equipment offered

ITEM	DESCRIPTION	SCHEDULE A	SCHEDULE B
19	TECHNICAL DETAIL FOR AN INTERTRIP SEND AND RECEIVE FIBRE OPTIC RELAY (INTSF and INTRF).		
10.19.1	Manufacturer	State	
10.19.2	Type	State	
	Minimum Functionality		
10.19.3	Signal transfer time with direct fibre connection	<20ms	
10.19.4	Hand reset operation flag annunciation	Yes	
10.19.5	Minimum no. of independent communication channels	>=8	
10.19.6	Minimum Heavy Duty Tripping Output contacts per channel (self-reset)	>=1	
10.19.7	Minimum binary inputs per channel	>=1	
10.19.8	Hardware Self-diagnosis and alarm	Yes	
10.19.9	Communication channel self-diagnosis and alarm	Yes	
10.19.10	Relay casing material	Steel or Aluminium	
	Technical Details		
10.19.11	LED's for each input and output activation	Yes	
10.19.12	Output Contact Rated Voltage	230V ac/dc	
10.19.13	Contact current continuous capability	State	
10.19.14	Contact current making capability	State	
10.19.15	Contact current Breaking capability: L/R = 40ms @ 125VDC	State	
10.19.16	Binary Input Voltage Range	30V/ 110/220 V dc	
10.19.17	Rated Auxiliary Supply Voltage	30V/ 110/220 V dc	
10.19.18	Rated Auxiliary Supply Voltage Operation Range	80% - 120%	
10.19.19	CT terminal connection type	Ring or Flat	
10.19.20	Maximum Power Consumption	State	

Note: Ticks, Cross [✓, X], Astrick [*], Word [Noted] or TBA ["To Be Advice"] will not be accepted.

Tender Number: _____

Tenderer's Authorised Signatory: _____
Name in block letters Signature

Full name of company: _____

ANNEXURE C – MFST – TECHNICAL SCHEDULES

Schedule A: Purchaser's specific requirements

Schedule B: Guarantees and technical particulars of equipment offered

ITEM	DESCRIPTION	SCHEDULE A	SCHEDULE B
20	TECHNICAL DETAIL FOR A MULTI FUNCTION SCADA TRANSDUCER (MFST).		
10.20.1	Manufacturer	State	
10.20.2	Type	State	
	Minimum Functionality		
10.20.3	Measurement selection single phase	V, I, F, P, Q, S, , Tan ϕ , Cos ϕ	
10.20.4	Measurement selection 3 phase, three/four wire unbalanced	V1 V2 V3, U12 U23 U31, I1 I2 I3, F, P1 P2 P3 Pt, Q1 Q2 Q3 Qt, S1 S2 S3 St, Tan ϕ , Cos(ϕ 1 ϕ 2 ϕ 3 ϕ t), ϕ 1 ϕ 2 ϕ 3 ϕ t, ϕ (U12/U23, U23/U31, U31/U12), ϕ (V1/V2, V2/V3, V3/V1)	
10.20.5	Accuracy Class	0.5	
10.20.6	Analog outputs	1 to 4	
10.20.7	Current Inputs	1A and 5A	
10.20.8	Voltage Inputs	100 to 480 V (ph-ph) or 100/ $\sqrt{3}$ to 480/ $\sqrt{3}$ V (ph-N)	
10.20.9	Operating Frequency	50Hz	
10.20.10	Mounting	Plate mounted with screws	
10.20.11	Rear Data Communication ports for remote engineering access DNP3 and IEC61850 via ethernet	Yes	
	Technical Details		
10.20.12	Analogue outputs (Io = output current)	State	
10.20.13	Analog output range	± 1 mA, ± 5 mA, ± 20 mA, ± 1 V, ± 10 V selectable	
10.20.14	Acceptable resistive load	15V/Io	
10.20.15	Acceptable capacitive load	0.1microfarad	
10.20.16	Overrun	1.2xIo	
10.20.17	Peak to peak residual wave	+/-0.2% of Io	
10.20.18	Programmable response time and accuracy (as per IEC60688)	100ms (class 0.5)	
10.20.19	Transfer curve (selectable)	Linear (2 slope)	
10.20.20	Current Input (In = Nominal Current)		

SPECIFICATION FOR PROTECTION RELAYS

REFERENCE

REV

CP_TSSPEC_214
2

PAGE

51

OF

59

ITEM	DESCRIPTION	SCHEDULE A	SCHEDULE B
10.20.21	Rated value	0 to 10A max	
10.20.22	Max measured current on primary	25000A	
10.20.23	Acceptable overload	50xIn for 1 sec	
10.20.24	Burden	<0.15VA	
10.20.25	Voltage Input		
10.20.26	Rated value	57.7Vac to 480Vac for 3 phase 57.7Vac to 276Vac for single phase	
10.20.27	Frequency	42.557.5 Hz	
10.20.28	Max measured voltage on primary	650 kV (ph-ph)	
10.20.29	Acceptable overloads	520Vac continuous, 800Vac for 10 sec for 3 phase 300Vac continuous, 460Vac for 10 sec for single phase	
10.20.30	Burden	<0.2A	
10.20.31	Input impedance	400kohm	
	Auxiliary power supply		
10.20.32	Rated Auxiliary Supply Voltage Operation Range	30V/ 110/ 220 dc	
10.20.33	CT terminal connection type	Ring or Flat	
10.20.34	Maximum relay dimensions in mm (width, height, depth)	State	
10.20.35	Maximum Power Consumption	State	

Note: Ticks, Cross [✓, X], Astrick [*], Word [Noted] or TBA ["To Be Advice"] will not be accepted.

Tender Number: _____

Tenderer's Authorised Signatory: _____
Name in block letters Signature

Full name of company: _____

ANNEXURE C – DIFFC – TECHNICAL SCHEDULES

Schedule A: Purchaser's specific requirements

Schedule B: Guarantees and technical particulars of equipment offered

ITEM	DESCRIPTION	SCHEDULE A	SCHEDULE B
21	TECHNICAL DETAIL FOR A CIRCULATING CURRENT RELAY (DIFFC).		
10.21.1	Manufacturer	State	
10.21.2	Type/Model	State	
	Minimum Functionality		
10.21.3	DigSilent StationWare settings file	State	
10.21.4	Multiple element over-current protection	Yes	
10.21.5	Multiple element earth fault protection	Yes	
10.21.6	Sensitive earth fault protection	Yes	
10.21.7	Breaker Fail protection	Yes	
10.21.8	3 stage under frequency protection	Yes	
10.21.9	Breaker I ² t condition monitoring	Yes	
10.21.10	Internal trip timer (CB opening time) with alarm output	Yes	
10.21.11	Fault waveform recording with a minimum of 4 records	Yes	
10.21.12	Sequential event recording with a minimum of 100 events	Yes	
10.21.13	Multi shot Auto Re-close	Yes	
10.21.14	Trip circuit supervision	>=2 circuits	
10.21.15	3 phase current display on LCD.	Yes	
10.21.16	Internal hardware and Software Supervision	Yes	
10.21.17	Minimum Programmable Heavy Duty Tripping Output Relays	>=2	
10.21.18	Minimum Programmable Signal Output Relays	>=6	
10.21.19	Minimum Number of Binary Inputs	>=6	
10.21.20	Minimum number of user programmable and configurable indication LED's	>=6	
10.21.21	User programmable logic	Yes	
10.21.22	Rear Data Communication ports for remote engineering access DNP3 and IEC61850 via ethernet	Yes	
10.21.23	Front Local Data Communication Port RS232 / USB/ RJ45	Yes	
10.21.24	Internal clock synchronization	Yes	
10.21.25	Relay casing material	Steel or Aluminium	
	Technical Details		
10.21.26	Number of Current Inputs	4	
10.21.27	Rated Frequency (fn)	50Hz	
10.21.28	Rated Current (In)	1A or 5A	
10.21.29	Thermal Current Withstand: Continuous	State	

ITEM	DESCRIPTION	SCHEDULE A	SCHEDULE B
10.21.30	Thermal Current Withstand: Continuous for $I_n = 0.2A$	State	
10.21.31	Thermal Current Withstand: 1s	State	
10.21.32	Input Impedance: ($I_n = 1A$)	State	
10.21.33	Output Contact Rated Voltage	230V AC/DC	
10.21.34	Power/ Signal Contact Thermal Withstand capability: Continuous	State	
10.21.35	Power/ Signal Contact Thermal Withstand capability: 3s	State	
10.21.36	Power/ Signal Contact Thermal Withstand capability: 0.5s	State	
10.21.37	Power Contact Thermal Breaking capability: L/R = 40ms @ 110VDC	State	
10.21.38	Binary Input Voltage Range	30V/ 110V/ 220V dc	
10.21.39	Rated Auxiliary Supply Voltage	30V/ 110V/ 220V dc	
10.21.40	Rated Auxiliary Supply Voltage Operation Range	80% - 120%	
10.21.41	CT terminals connection type	Ring or Flat	
10.21.42	Maximum relay dimensions in mm (width, height, depth)	State	
10.21.43	Maximum Power Consumption	State	

Note: Ticks, Cross [✓, X], Astrick [*], Word [Noted] or TBA ["To Be Advice"] will not be accepted.

Tender Number: _____

Tenderer's Authorised Signatory: _____
 Name in block letters Signature

Full name of company: _____

ANNEXURE C – TAUX – TECHNICAL SCHEDULES

Schedule A: Purchaser's specific requirements

Schedule B: Guarantees and technical particulars of equipment offered

ITEM	DESCRIPTION	SCHEDULE A	SCHEDULE B
22	TECHNICAL DETAIL FOR A DC VOLTAGE MONITORING RELAY (DCVMR)		
10.22.1	Manufacturer	State	
10.22.2	Type/Model	State	
	Minimum Functionality		
10.22.3	Monitoring function	Under-voltage monitoring	
10.22.4	Operating principle	Output contact relays energize if the measured value falls below the adjusted threshold value and the timer times-out.	
	Technical Details		
10.22.5	Measuring inputs pulse rating $t < 1$ s	≥ 600 V	
10.22.6	Measuring inputs continuous rating	≥ 300 V	
10.22.7	Threshold pickup setting value	Adjustable within the selected measuring range.	
10.22.8	Accuracy within the control supply voltage tolerance.	$\leq 1\%$	
10.22.9	Contact outputs (change over)*	≥ 2	
10.22.10	Contact output rating*	230 V AC or DC	
10.22.11	Contact output current rating *	≥ 6 A continuous ≥ 30 A make ≥ 100 A for 1 s	
10.22.12	Contact output break capacity *	≥ 250 V, 0.2 A, L/R = 40ms	
10.22.13	Rated control supply voltage	30V/ 110V/ 220V dc	
10.22.14	CT connection Type	Ring or Flat	
10.22.15	Selectable measuring ranges	Yes	
10.22.16	Measuring range A	20-60 V DC	
10.22.17	Measuring range B	60-250 V DC	
10.22.18	Mounting.	State	
10.22.19	Operating delay time	1 to 30 s adjustable	
10.22.20	Transient overvoltage protection	Yes	
10.22.21	Rated frequency	50 Hz	
10.22.22	Settings tamper protection	State	
10.22.23	Status indication LED's	≥ 3	
10.22.24	Interference immunity	IEC 61000-6-2	
10.22.25	Maximum Power Consumption	State	

CVMR output contacts cannot meet the minimum requirements, then an auxiliary relay may be supplied to meet the cation.

Note: Ticks, Cross [✓, X], Astrick [*], Word [Noted] or TBA ["To Be Advice"] will not be accepted.

Tender Number: _____

Tenderer's Authorised Signatory: _____
Name in block letters Signature

Full name of company: _____

ANNEXURE C – MAINFO – TECHNICAL SCHEDULES

Schedule A: Purchaser's specific requirements

Schedule B: Guarantees and technical particulars of equipment offered

ITEM	DESCRIPTION	SCHEDULE A	SCHEDULE B
23	TECHNICAL DETAIL FOR A MULTI PURPOSE MAIN FEEDER RELAY (MAINFO).		
10.23.1	Manufacturer	State	
10.23.2	Type/Model	State	
	Minimum Functionality		
10.23.3	DigSilent StationWare settings file	State	
10.23.4	Phase Segregated Differential protection	Yes	
10.23.5	Single Mode 1300nm fibre optic connections	Yes	
10.23.6	Inter-trip Commands Across Communication Channel	Yes	
10.23.7	Internal CT Ratio Correction	Yes	
10.23.8	Multiple element directional and non-directional over-current protection	Yes	
10.23.9	Multiple element directional and non-directional earth fault protection	Yes	
10.23.10	Sensitive earth fault protection Note: This functionality can be provided as a separate relay: if so then– see STBYEF relay and compete STBYEF technical schedule)	Yes	
10.23.11	LCD Display Interface	Yes	
10.23.12	Password protection	Yes	
10.23.13	Breaker Fail protection	Yes	
10.23.14	Internal trip timer (CB opening time) with alarm output (Element or Logics)	Yes	
10.23.15	Fault waveform recording with a minimum of 4 records	Yes	
10.23.16	Sequential event recording with a minimum of 100 events	Yes	
10.23.17	Trip circuit supervision	Yes	
10.23.18	3 phase maximum demand power, three phase real power, apparent power and power factor display on LCD.	Yes	
10.23.19	Internal hardware and Software Supervision	Yes	
10.23.20	Minimum Programmable Heavy Duty Tripping Output Relays	>=2	
10.23.21	Minimum Programmable Signal Output	>=4	
10.23.22	Minimum Number of Binary Inputs	>=11	
10.23.23	Minimum number of user programmable and configurable indication LED's	>=6	
10.23.24	User programmable logic	Yes	
10.23.25	Rear Data Communication ports for remote engineering access DNP3 and IEC61850 via ethernet	Yes	
10.23.26	Front Local Data Communication Port RS232 / USB/ RJ45	Yes	
10.23.27	Internal clock synchronization	Yes	
10.23.28	Relay casing material	Steel or Aluminium	
10.23.29	Technical Details		
10.23.30	Number of Voltage Inputs	>=3	
10.23.31	Rated Voltage Input (Un)	110V	

ITEM	DESCRIPTION	SCHEDULE A	SCHEDULE B
10.23.32	Rated Voltage Withstand: Continuously	State	
10.23.33	Number of Current Inputs	State	
10.23.34	Rated Frequency (fn)	50Hz	
10.23.35	Rated Current (In)	1A or 5A	
10.23.36	Thermal Current Withstand: Continuous	State	
10.23.37	Thermal Current Withstand: Continuous for In = 0.2A	State	
10.23.38	Thermal Current Withstand: 1s	State	
10.23.39	Input Impedance: (In = 1A)	State	
10.23.40	Output Contact Rated Voltage	230V ac/dc	
10.23.41	Power/ Signal Contact Thermal Withstand capability: Continuous	State	
10.23.42	Power/ Signal Contact Thermal Withstand capability: 3s	State	
10.23.43	Power/ Signal Contact Thermal Withstand capability: 0.5s	State	
10.23.44	Power Contact Thermal Breaking capability: L/R = 40ms @ 110VDC	State	
10.23.45	Binary Input Voltage Range	30V/ 110V/ 220V dc	
10.23.46	Rated Auxiliary Supply Voltage	30V/ 110V/ 220V dc	
10.23.47	Rated Auxiliary Supply Voltage Operation Range	80% - 120%	
10.23.48	CTs terminals connection type	Ring or Flat	
10.23.49	Maximum relay dimensions in mm (width, height, depth)	State	
10.23.50	Maximum Power Consumption	State	

Note: Ticks, Cross [✓, X], Astrick [*], Word [Noted] or TBA ["To Be Advice"] will not be accepted.

Tender Number: _____

Tenderer's Authorised Signatory: _____
 Name in block letters Signature

Full name of company: _____

ANNEXURE C – RADIALF – TECHNICAL SCHEDULES

Schedule A: Purchaser's specific requirements

Schedule B: Guarantees and technical particulars of equipment offered

ITEM	DESCRIPTION	SCHEDULE A	SCHEDULE B
24	TECHNICAL DETAIL FOR A RADIAL FEEDER RELAY (RADIALF).		
10.24.1	Manufacturer	State	
10.24.2	Type/Model	State	
	Minimum Functionality		
10.24.3	DigSilent StationWare settings file	State	
10.24.4	Multiple element over-current protection	Yes	
10.24.5	Multiple element earth fault protection	Yes	
10.24.6	Sensitive earth fault protection Note: This functionality can be provided as a separate relay: if so then— see STBYEF relay and compete STBYEF technical schedule)	Yes	
10.24.7	LCD Display Interface	Yes	
10.24.8	Password protection	Yes	
10.24.9	Breaker Fail protection	Yes	
10.24.10	Internal trip timer (CB opening time) with alarm output (element or logics)	Yes	
10.24.11	Fault waveform recording with a minimum of 4 records	Yes	
10.24.12	Sequential event recording with a minimum of 100 events	Yes	
10.24.13	Trip circuit supervision	Yes	
10.24.14	3 phase current display on LCD.	Yes	
10.24.15	Internal hardware and Software Supervision	Yes	
10.24.16	Minimum Programmable Heavy Duty Tripping Output Relays	≥ 2	
10.24.17	Minimum Programmable Signal Output Relays	≥ 4	
10.24.18	Minimum Number of Binary Inputs	≥ 11	
10.24.19	number of user programmable and Nonfigurable indication LED's	≥ 6	
10.24.20	User programmable logic	Yes	
10.24.21	Rear Data Communication ports for remote engineering access DNP3 and IEC61850 via ethernet	Yes	
10.24.22	Front Local Data Communication Port RS232 / USB/ RJ45	Yes	
10.24.23	Internal clock synchronization	Yes	

ITEM	DESCRIPTION	SCHEDULE A	SCHEDULE B
10.24.24	Relay casing material	Steel or Aluminium	
10.24.25	Technical Details		
10.24.26	Number of Current Inputs	≥ 4	
10.24.27	Rated Frequency (fn)	50Hz	
10.24.28	Rated Current (In)	1A or 5A	
10.24.29	Thermal Current Withstand: Continuous	State	
10.24.30	Thermal Current Withstand: Continuous rating	State	
10.24.31	Thermal Current Withstand: 1s	State	
10.24.32	Input Impedance: (In = 1A)	State	
10.24.33	Output Contact Rated Voltage	230V ac/dc	
10.24.34	Power/ Signal Contact Thermal Withstand capability: Continuous	State	
10.24.35	Power/ Signal Contact Thermal Withstand capability: 3s	State	
10.24.36	Power/ Signal Contact Thermal Withstand capability: 0.5s	State	
10.24.37	Power Contact Thermal Breaking capability: L/R = 40ms @ 110VDC	State	
10.24.38	Binary Input Voltage Range	30V/ 110V/ 220V dc	
10.24.39	Rated Auxiliary Supply Voltage	30V/ 110V/ 220V dc	
10.24.40	Rated Auxiliary Supply Voltage Operation Range	80% - 120%	
10.24.41	CTs terminals connection type	Ring or Flat	
10.24.42	Maximum relay dimensions in mm (width, height, depth)	State	
10.24.43	Maximum Power Consumption	State	

Note: Ticks, Cross [✓, X], Astrick [*], Word [Noted] or TBA ["To Be Advice"] will not be accepted.

Tender Number: _____

Tenderer's Authorised Signatory: _____
Name in block letters Signature

Full name of company: _____

Items – PROTECTION EQUIPMENT
Deviation schedule

Any deviations offered to this specification shall be listed below with reasons for deviation. In addition, evidence shall be provided that the proposed deviation will at least be more cost-effective than that specified by City Power.

Item	Sub clause of CP_TSSPEC_214	Proposed deviation

Tender Number: _____

Tenderer's Authorised Signatory: _____
Name in block letters Signature

Full name of company: _____