

## ENGINEERING SERVICES DEPARTMENT



### PRESSURE RELIEF VALVE SPECIFICATION SHEET

<b>Project</b>	PTFE Filter Destruction Project		<b>Unit Tag Number</b>	MG833-95			
<b>Datasheet Document No.</b>	ENS-FDP-SPE-24025		<b>Revision</b>	3			
<b>Description</b>	Pressure relief valve servicing the methane gas supply line 15-833-MGVP-063 to the Depolymerisation Reactor R82014 in the PTFE Filter Destruction Facility <sup>[1]</sup> .						
<b>Plant location</b>	Necsa, Pelindaba, North-West Province						
<b>Equipment Location</b>	PTFE Filter Destruction Facility - Outside laboratory 131, north side of Building V-H2						
<b>Safety Classification</b>	Non-classified (N) and SC-2 (C)						
<b>Quality Classification</b>	Non-classified (N) and QC-2 (C)						
<b>Fluid</b>	Methane						
<b>Fluid state</b>	Gas						
<b>Set pressure</b>	110 kPa <sup>[1]</sup>						
<b>Over pressure</b>	10 kPa <sup>[2]</sup>						
<b>FLUID PROPERTIES</b>	<b>UNITS</b>	<b>MINIMUM</b>	<b>NORMAL</b>	<b>MAXIMUM</b>			
Operating temperature	°C	-2.6 <sup>[3]</sup>	25	40 <sup>[3]</sup>			
Working pressure	kPa (g)	-	100	20341 <sup>[4]</sup>			
Back pressure	kPa (g)	-	Note 1	-			
Mass flow rate <sup>Note 2</sup>	kg/h	-	213,40 <sup>[5]</sup>	-			
Volume flow rate	m <sup>3</sup> /h	-	157,15 <sup>[5]</sup>	-			
Inlet density <sup>Note 3</sup>	kg/m <sup>3</sup>	-	1,36 <sup>[5]</sup>	-			
Viscosity	cP	-	0,021 <sup>[6]</sup>	-			
Compressibility factor	(z)	-	0,994 <sup>[5]</sup>	-			
Specific heat capacity (C <sub>p</sub> )	kJ/kg.K	-	2,2537 <sup>[5]</sup>	-			
Specific heat capacity (C <sub>v</sub> )	kJ/kg.K	-	1,7354 <sup>[5]</sup>	-			
<b>VALVE PROPERTIES</b>							
<b>Material of Construction</b>							
<b>Body</b>	<b>Bellows</b>	<b>Packing</b>	<b>Seat</b>	<b>Plug/Ball/Disk</b>	<b>Bonnet/Cap</b>		
SS	Supplier to advise	SS	PTFE	SS	SS		
<b>Valve Type</b>		Supplier to advise.					
<b>Orifice area (mm<sup>2</sup>)</b>		171,29 <sup>[5]</sup> (Note 4)					
<b>Process connections</b>							
		<b>Flange Spec.</b>	<b>Flange Rating</b>	<b>Pipe Size (NB)</b>			
Inlet		ASTM A182-F316/316L, RF, ASME B16.5	API526 (Or supplier to advise)	Supplier to Advise			
Outlet		ASTM A182-F316/316L, RF, ASME B16.5	API526 (Or supplier to advise)	Supplier to Advise			
<b>Valve rating</b>		API526 (Or supplier to advise)					

## REFERENCE DRAWINGS AND DOCUMENTS

- [1] ENS-FDP-PID-24005, PTFE Filter Destruction Project P&ID Diagram - Gas Supply System 833
- [2] API 520: Sizing, Selection, and Installation of Pressure-Relieving Devices in Refineries, Part I-Sizing and Selection
- [3] SHEQ-2011-REP-01017,2011 : Pelindaba Site, Site Description Rev 2, Necsa
- [4] ENS-FDP-REP-24023: PTFE Gas Supply System Pressure Protection Calculations: Pressure Relief Valves Sizing
- [5] ENS-FDP-CLC-24018: PTFE Gas Supply System Pressure Protection Calculations Pressure Relief Valves Sizing.
- [6] Daniel Gaddis, 2019: Tubular Exchangers Manufacturers Association, 10th Edition

## NOTES

Note 1: The backpressure is not specified here since it is reliant on the sizing (diameter) of the relief valve vent line, which is currently not known. Suitable line sizing is to be recommended by the valve supplier, taking note that the proposed routing of the vent line is from the valve outlet near ground level to the building ventilation stack on top of the building. The tie-in point for the arrangement mentioned above is just before the stack directly discharges to the atmosphere. The building height is 13,5 m, total length of the vent line is estimated to be 22 m, and atmospheric pressure is 88 kPa.

Supplier to provide value for the PRV backpressure, after confirming sizing and routing of the vent line.

Note 2: The normal flow rate was calculated based on the scenario that an upstream pressure regulator (PCV83346B) with a  $C_v$  value = 0,08 fails open.

Note 3: The inlet density was calculated at the absolute upstream relieving pressure of the PRV.

Note 4: Orifice sizing is based on the procedure according to API Standard 520 Part I with the assumption that a conventional spring-loaded pressure relief valve is used with gas venting at the normal flow rate specified. Valve supplier to advise further.

Note 5: Inspection and testing shall be done in supplier facility.

	Name	Signature	Date
Compiled by	Mr W Ludwick		
Process	Mr MK Nkadimeng		
Process	Mr BM Khumalo		
Mechanical	Mr M Msane		
Mechanical	Mr S Mngoma		
Instrumentation	Dr G Manuel		
Electrical	Mr WJ van den Berg		
Approved by	Dr K Moodley		