

**COAL SCREENING ON BOTH CONVEYOR 18 AND E1 AT THE COAL STOCK YARD
FOR A PERIOD OF 36 MONTHS AT CAMDEN POWER STATION.**

MPCAM11114GX

Addendum 3

Please note the following questions and answers for further clarity:

Q1: Part C3: Scope of Work – Page 24

There are 2 descriptions for the conveyors 800t/hr or 400 t/hr, while at the briefing and elsewhere its 500t/hr.?

Please see the new BOQ and use the quantities as is in the BOQ to eliminate the confusion.

The contractor will only supply screens as specified on the Scope of Work and no Front-End Loaders will be required from them, Eskom will supply.

Q2 Bill no 1:

1. FIXED CHARGES

Establishment for instance 1.2.1 Transport to Site.

Q1 - Will that be paid in full once the plant is mobilised – or will this be paid pro-rata over 36 months? OR does this apply to TIME RELATED CHARGES only?

THIS WILL BE PAID ONCE ALL ITEMS IN THE PRELIMINARIES FIXED CHARGES HAS BEEN MET AND APPROVED BY THE CONTRACTS MANAGER, THIS COULD BE AT COMMENCEMENT OF THE CONTRACT OR LATER ON DURING THE CONTRACT DEPENDANT ON THE SUBMISSION, APPROVAL AND FINALISATION.

TIME RELATED CHARGES WILL BE PAID DURING THE 36 MONTHS EQUALLY

Q3 Bill no 2 Conveyor 18 & no 3 E1

1. To confirm the measurement for payment will be calculated by controlled weighing equipment? Yes, the Mass Meters.

2. Under SPECIAL NOTES: The notes wrt 6 diesel mobile screens?

Please ignored as its 2 x screens 500t/hr with a 3rd on standby and will be fed by front end loaders which will be provide by Eskom.

Q4. 30% subcontracting:

1. We foresee it difficult to subcontract 30% with such a narrow scope of supplying 2 no coal screens with 1 on standby – while attracting a 2,5 % penalty.

Is this condition practical for this tender & can the penalty be zeroed?

Please see the revised SDL&I requirements and this is a legal requirement and cannot be zeroed.

Q5. Gateway criteria:

1. Our company is doing its annual update with CIDB at the moment and while it meets the criteria for both 9CE and 9ME, the process is likely not to have been concluded with CIDB by 3 June.

Would it be sufficient to attach evidence that our submission is in progress and that likely it will be by the time of award (this is similar to a practice that SANRAL allows from time to time).

Please note the CIDB Level is 7ME for this tender. The assumption is that if you have 9ME you do qualify for this tender.

Q6. CPA:

1_C1 Contract Data – the CPA proportions state .75 for labour and 0.1 for fuel.

The Ratios are distorted as there is no plant element and the make-up of our rates are not relating to .75 being labour.

CPA Table to be used

Proportion	Linked to OR index for	Index prepared by
0.75	Labour	SEIFSA Table C3
0.10	Transport	SEIFSA Table L3
.015	Non-adjustable	
1.00 (Total)		

NOTE: fuel is a free issue by Eskom.

THE END.