



**LIGHTING LEGEND**

- ELECTRICAL DISTRIBUTION BOARD
- 1500mm x 54W T5 OPEN CHANNEL FLUORESCENT LUMINAIRE C/W ECG.
- AS ABOVE BUT WITH EMG BATTERY BACKUP (50% FOR 1HR) AND SELF TEST INVERTER.
- 1500mm x 54W CHANNEL FITTING WITH WRAP AROUND ACRYLIC DIFFUSER.
- AS ABOVE BUT WITH EMG BATTERY BACKUP (50% FOR 1HR) AND SELF TEST INVERTER.
- LED DOWNLIGHTER.
- WALL MOUNTED LED BULKHEAD FITTING WITH 24W LED LAMP.
- CEILING / SOFFIT MOUNTED LED BULKHEAD FITTING WITH 24W LED LAMP.
- AS ABOVE BUT WITH EMG BATTERY BACKUP (50% FOR 1HR) AND SELF TEST INVERTER.
- MOTION SENSOR FOR CONTROL OF LOCAL LIGHTING (SET TO 30min).
- LIGHT SWITCH MOUNTED AT 1000mm AFFL TO CENTRE 100mm AWAY FROM DOOR FRAME.

No.	DATE	AMENDMENT	
A	2021.05.11	ISSUED FOR TENDER	D.A.

Copyright vests in the Department of Public Works

as-built drawings

certified as-built drawings as per Centralised Drawing Archive AS-BUILT DRAWING REQUIREMENTS

name: \_\_\_\_\_

date: \_\_\_\_\_

professional registration no.: \_\_\_\_\_

cad file name: E6(28)(B) page type: A 1



consultant

discipline: ELECTRICAL

service

TROMPSBURG  
SPECIAL NEEDS SCHOOL  
ELECTRICAL AND ELECTRONIC

WCS number: EDIT

drawing title: TYPICAL STUDENT ACCOMMODATION LIGHTING LAYOUT

ref.no. EDIT designed K.NEL  
scale 1:200 drawn D.ALBIN  
date 2018.11.02 checked K.NEL  
DPW drawing number

**FOR TENDER**

E6(28)(B)