

### **Annexure C3.2 - Scope of Work-10409897**

Remove and replace electrical control panels with new panel and contactors and wiring to be done poly plant crane 2-ton Verlinde crane change single speed motors on long travel with two speed motors and do wiring for this, place brake back on cross travel motor test for working and also change the load limiter, also reduce the limit chain. Replace pendant with lockable e stop and cable for back up. Replace pendant cable on Thickening plant crane 5-ton Verlinde crane. Replace panel complete with contactors and do wiring of Thickener 1 Stahl 3.2-ton hoist. Calibrate and repair on the load limiters on the thickening plant crane, also address all the defects that are associated with the crane.

Successful candidate must submit a safety file and attend induction before work commences.

Crane photos.



## Site Information – Annexure C 4

**RAND WATER ZUIKERBOSCH – Non Compulsory Site Briefing 02.09.2025 @ 10:00 we meet at Risk Control Parking Area, we will leave strictly at 10:00 to Rand Water Panfontein – Panfontein is situated approximately 3km from Rand Water Zuikerbosch**

Vischagat Road, Three Rivers East  
Vereeniging, 1939  
GPS Coordinates: S 26° 41.520 and E 28° 00.061

Working Hours Mon-Thurs – 07:00-16:00  
Fri – 07:00-14:00

### **THE IMPORTANCE OF WEARING PPE**

Everyone accessing the plant will be expected to wear safety shoes, failure to which no access will be granted.

### **THE IMPORTANCE OF CARRYING YOUR DRIVER'S LICENSE**

Everyone accessing the site using personal or company vehicles is requested to always carry their valid driver's license.

### **VALID CAR DISCS ARE ESSENTIAL**

Every company or personal vehicle accessing the site must have a valid car disc. The biometric system will scan and cross-reference these discs to ensure compliance with local regulations. Failure to have a valid car disc may result in the vehicle being refused entry.

### **DATA SECURITY**

The site complies with the principle of Personal Access to Information Act (PAIA) and as such all data collected will be treated with the utmost confidentiality and used solely for security and access control purposes. |